

## SERVICE MANUAL

# 3561A DYNAMIC SIGNAL ANALYZER

## VOLUME I





## SERVICE MANUAL

# MODEL 3561A DYNAMIC SIGNAL ANALYZER

Serial Prefix: 2338A

### IMPORTANT NOTICE

*This manual applies to instruments with the above serial number and greater. As changes are made in the instrument to improve performance and reliability, the appropriate pages will be revised to include this information.*

### WARNING

*To prevent potential fire or shock hazard, do not expose instrument to rain or moisture.*

Manual Part No. 03561-90010

Microfiche Part No. 03561-90060



**HEWLETT  
PACKARD**

### **CERTIFICATION**

*Hewlett-Packard Company certifies that this product met its published specifications at the time of shipment from the factory. Hewlett-Packard further certifies that its calibration measurements are traceable to the United States National Bureau of Standards, to the extent allowed by the Bureau's calibration facility, and to the calibration facilities of other International Standards Organization members.*

### **WARRANTY**

This Hewlett-Packard product is warranted against defects in material and workmanship for a period of one year from date of shipment [except that in the case of certain components listed in Section I of this manual, the warranty shall be for the specified period] . During the warranty period, Hewlett-Packard Company will, at its option, either repair or replace products which prove to be defective.

For warranty service or repair, this product must be returned to a service facility designated by -hp-. Buyer shall prepay shipping charges to -hp- and -hp- shall pay shipping charges to return the product to Buyer. However, Buyer shall pay all shipping charges, duties, and taxes for products returned to -hp- from another country.

HP software and firmware products which are designated by HP for use with a hardware product, when properly installed on that hardware product, are warranted not to fail to execute their programming instructions due to defects in materials and workmanship. If HP receives notice of such defects during the warranty period, HP shall repair or replace software media and firmware which do not execute their programming instructions due to such defects. HP does not warrant that the operation of the software, firmware or hardware shall be uninterrupted or error free.

### **LIMITATION OF WARRANTY**

The foregoing warranty shall not apply to defects resulting from improper or inadequate maintenance by Buyer, Buyer-supplied software or interfacing, unauthorized modification or misuse, operation outside of the environmental specifications for the product, or improper site preparation or maintenance.

**NO OTHER WARRANTY IS EXPRESSED OR IMPLIED. HEWLETT-PACKARD SPECIFICALLY DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.**

### **EXCLUSIVE REMEDIES**

**THE REMEDIES PROVIDED HEREIN ARE BUYER'S SOLE AND EXCLUSIVE REMEDIES. HEWLETT-PACKARD SHALL NOT BE LIABLE FOR ANY DIRECT, INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, WHETHER BASED ON CONTRACT, TORT, OR ANY OTHER LEGAL THEORY.**

### **ASSISTANCE**

*Product maintenance agreements and other customer assistance agreements are available for Hewlett-Packard products.*

*For any assistance, contact your nearest Hewlett-Packard Sales and Service Office. Addresses are provided at the back of this manual.*



## **SAFETY SUMMARY**

The following general safety precautions must be observed during all phases of operation, service, and repair of this instrument. Failure to comply with these precautions or with specific warnings elsewhere in this manual violates safety standards of design, manufacture, and intended use of the instrument. Hewlett-Packard Company assumes no liability for the customer's failure to comply with these requirements. This is a Safety Class 1 instrument.

### **GROUND THE INSTRUMENT**

To minimize shock hazard, the instrument chassis and cabinet must be connected to an electrical ground. The instrument is equipped with a three-conductor ac power cable. The power cable must either be plugged into an approved three-contact electrical outlet or used with a three-contact to two-contact adapter with the grounding wire (green) firmly connected to an electrical ground (safety ground) at the power outlet. The power jack and mating plug of the power cable meet International Electrotechnical Commission (IEC) safety standards.

### **DO NOT OPERATE IN AN EXPLOSIVE ATMOSPHERE**

Do not operate the instrument in the presence of flammable gases or fumes. Operation of any electrical instrument in such an environment constitutes a definite safety hazard.

### **KEEP AWAY FROM LIVE CIRCUITS**

Operating personnel must not remove instrument covers. Component replacement and internal adjustments must be made by qualified maintenance personnel. Do not replace components with power cable connected. Under certain conditions, dangerous voltages may exist even with the power cable removed. To avoid injuries, always disconnect power and discharge circuits before touching them.

### **DO NOT SERVICE OR ADJUST ALONE**

Do not attempt internal service or adjustment unless another person, capable of rendering first aid and resuscitation, is present.

### **USE CAUTION WHEN EXPOSING OR HANDLING THE CRT**

Breakage of the Cathode-ray Tube (CRT) causes a high-velocity scattering of glass fragments (implosion). To prevent CRT implosion, avoid rough handling or jarring of the instrument. Handling of the CRT shall be done only by qualified maintenance personnel using approved safety mask and gloves.

### **DO NOT SUBSTITUTE PARTS OR MODIFY INSTRUMENT**

Because of the danger of introducing additional hazards, do not install substitute parts or perform any unauthorized modification to the instrument. Return the instrument to a Hewlett-Packard Sales and Service Office for service and repair to ensure that safety features are maintained.

### **DANGEROUS PROCEDURE WARNINGS**

Warnings, such as the example below, precede potentially dangerous procedures throughout this manual. Instructions contained in the warnings must be followed.

#### **WARNING**

Dangerous voltages, capable of causing death, are present in this instrument. Use extreme caution when handling, testing, and adjusting.



## **TABLE OF CONTENTS**

### **SECTION I GENERAL INFORMATION**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
1-1	INTRODUCTION .....	1-1
1-2	MANUAL/INSTRUMENT IDENTIFICATION .....	1-2
1-3	INSTRUMENT DESCRIPTION .....	1-3
1-4	OPTIONS .....	1-3
1-5	SAFETY CONSIDERATIONS .....	1-3
1-6	OPERATOR MAINTENANCE .....	1-4
1-7	POWER REQUIREMENTS .....	1-4
1-8	AVAILABLE SERVICE KIT .....	1-6
1-9	PERFORMANCE SPECIFICATIONS .....	1-6
1-10	RECOMMENDED TEST EQUIPMENT .....	1-9
1-11	STORAGE AND SHIPMENT .....	1-11

### **SECTION II PERFORMANCE TEST**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
2-1	INTRODUCTION .....	2-1
2-2	CALIBRATION CYCLE .....	2-1
2-3	REQUIRED TEST EQUIPMENT .....	2-2
2-4	PERFORMANCE TEST SUMMARY .....	2-3
2-5	OPERATIONAL VERIFICATION SUMMARY .....	2-4
2-6	dc Offset .....	2-4
2-7	Amplitude Accuracy/Flatness .....	2-5
2-8	Amplitude Linearity .....	2-8
2-9	Noise Level/Spurious Signal Level .....	2-11
2-10	Frequency Accuracy .....	2-13
2-11	Input Coupling Insertion Loss .....	2-15
2-12	Anti Alias Filter Response .....	2-17
2-13	A-Weight Filter Response .....	2-19
2-14	Phase Accuracy .....	2-21
2-15	Input Impedance .....	2-24
2-16	Floating Ground Capacitance .....	2-27
2-17	Harmonic Distortion .....	2-29
2-18	Two Tone Intermodulation Distortion .....	2-32
2-19	Noise Source Output Impedance .....	2-36
2-20	Noise Source Amplitude Accuracy/Flatness .....	2-38
2-21	External Sample .....	2-42
2-22	Internal Self Test .....	2-44

### **SECTION III ADJUSTMENTS**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
3-1	INTRODUCTION .....	3-1
3-2	SAFETY CONSIDERATIONS .....	3-1
3-3	EQUIPMENT REQUIRED .....	3-2
3-4	ADJUSTMENT LOCATIONS .....	3-2
3-5	ADJUSTMENT SUMMARY .....	3-2
3-6	A71 POWER SUPPLY LOW LINE DETECT ADJUSTMENT PROCEDURE .....	3-3
3-7	A90 CRT DISPLAY ADJUSTMENT PROCEDURE .....	3-4
3-8	A40 REFERENCE OSCILLATOR ADJUSTMENT PROCEDURE .....	3-8
3-9	A15 DIGITIZER ASSEMBLY ADJUSTMENT PROCEDURE .....	3-10
3-10	A10 INPUT ASSEMBLY ADJUSTMENT PROCEDURE .....	3-16
3-11	A50 NOISE SOURCE ADJUSTMENT PROCEDURE .....	3-22

### **SECTION IV REPLACEABLE PARTS**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
4-1	INTRODUCTION .....	4-1
4-2	STANDARD ABBREVIATIONS .....	4-1
4-3	ORDERING INFORMATION .....	4-2
4-4	MANUFACTURER'S CODE LIST .....	4-2
4-5	REPLACEABLE PARTS LIST .....	4-2
4-6	DIRECT MAIL ORDER SYSTEM .....	4-4

### **SECTION V BACKDATING**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
5-1	INTRODUCTION .....	5-1
5-2	MANUAL CHANGES .....	5-1
5-3	A10 Input Amplifier Assembly Backdating .....	5-2
5-4	A15 Digitizer Assembly Backdating .....	5-3
5-5	A20 Digital Filter Assembly Backdating .....	5-4
5-6	A30 FFT/RAM Assembly Backdating .....	5-4
5-7	A40 Processor/ROM Assembly Backdating .....	5-4
5-8	A50 Local Oscillator/Noise Source Assembly Backdating .....	5-7/5-8
5-9	A82 Rear Panel Assembly Backdating .....	5-13
5-10	A99 Motherboard Assembly Backdating .....	5-14

### **SECTION VI FAULT ISOLATION**

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
6-1	INTRODUCTION .....	6-1
6-2	SAFETY CONSIDERATIONS .....	6-3
6-3	RECOMMENDED TEST EQUIPMENT: FAULT ISOLATION .....	6-4
6-4	SELF CALIBRATION .....	6-4
6-5	Calibration Procedure .....	6-4
6-6	Calibration Failures .....	6-5
6-7	TROUBLESHOOTING GUIDELINES .....	6-6

Paragraph	Title	Page
6-8	FAULT ISOLATION PROCEDURE .....	6-11
6-9	Using the Fault Isolation Procedure .....	6-11
6-10	TEST A: Bias Power Supply A71, A99 .....	6-12
6-11	TEST B: Main Power Supply A70, A71, A72, A99 .....	6-14
6-12	TEST C: Display Driver A60, A90, A99 .....	6-19
6-13	TEST D: Processor/ROM A40 .....	6-23
6-14	TEST E: FFT/RAM A30 .....	6-29
6-15	TEST F: Digital Filter A20 .....	6-35
6-16	TEST G: Input Amplifier/Digitizer A10, A15 .....	6-39
6-17	TEST H: Local Oscillator/Noise Source A50 .....	6-45
6-18	TEST I: CMOS/Bubble Memory A66, A65 .....	6-49
6-19	DIAGNOSTIC/SELF TEST DESCRIPTIONS .....	6-50
6-20	Introduction .....	6-50
6-21	Test Menu Explanation .....	6-52
6-22	General Error Code Format .....	6-54
6-23	Test 0: Power-On Test .....	6-55
6-24	Test 1 Quick Functional Test .....	6-61
6-25	Test 12 A30 FFT Test .....	6-63
6-26	Test 13 A20 Timing Counter Test .....	6-64
6-27	Test 14 A20 Digital Filter/DMA Channel R Test .....	6-65
6-28	Test 18 A20 DMA Channel G And Trigger Test .....	6-67
6-29	Test 19 A65/A66 CMOS Memory Test .....	6-69
6-30	Test 20 A65 Bubble Memory Test .....	6-69
6-31	Test 50 Display Pattern Test .....	6-71
6-32	Test 52 A10 Calibrator Adjustment .....	6-71
6-33	Test 53 A10 20dB Flatness Adjustment .....	6-72
6-34	Test 54 A10 40dB Flatness Adjustment .....	6-74
6-35	Test 110 A10 Front End Control Register Test .....	6-75
6-36	Test 111 - 116 A15 Timing and Control Circuit Setups .....	6-76
6-37	Test 118 Display Calibration Constants .....	6-76
6-38	Test 119 Clear Calibration Constant .....	6-77
6-39	Test 120 A20 Digital Filter DSA .....	6-77
6-40	Test 121 A20 Timing Counter DSA .....	6-77
6-41	Test 122 A20 DMA Channel G DSA .....	6-78
6-42	Test 123 A20 DMA Channel R DSA .....	6-78
6-43	Test 150 A50 Local Oscillator DSA .....	6-78
6-44	Test 151 A50 Analog Source Test .....	6-79
6-45	Test 152 A50 Noise Source DSA Setup 1 .....	6-79
6-46	Test 153 A50 Noise Source DSA Setup 2 .....	6-80
6-47	Test 154 A50 HP-IB I/O Verification Test Routine .....	6-80
6-48	Test 167 A65 Bubble Memory Read DSA .....	6-83
6-49	Test 168 A65 Bubble Memory Bootloop Routine .....	6-84
6-50	Test 169 A65 Bubble Memory Reseed Routine .....	6-92
6-51	Test 170 A65 Format Nonvolatile Memory Routine .....	6-93
6-52	OVERALL INSTRUMENT THEORY OF OPERATION .....	6-94
6-53	Introduction to Theory of Operation .....	6-94
6-54	Control Circuits and Bus Structure .....	6-94
6-55	Measurement Data Flow .....	6-95

## SECTION VII

### SCHEMATICS/SERVICE

Paragraph	Title	Page
7-1	INTRODUCTION .....	7-1
7-2	SAFETY CONSIDERATIONS .....	7-2
7-3	SCHEMATIC NOTES .....	7-3
7-4	A10 INPUT AMPLIFIER ASSEMBLY .....	7-7
7-5	Input Amplifier Circuit Description .....	7-7
7-6	Troubleshooting the Input Amplifier .....	7-12
7-7	A15 DIGITIZER ASSEMBLY .....	7-23
7-8	Digitizer Circuit Description .....	7-23
7-9	Troubleshooting the Digitizer .....	7-27
7-10	A20 DIGITAL FILTER ASSEMBLY .....	7-39
7-11	Digital Filter Circuit Description .....	7-39
7-12	Troubleshooting the A20 Assembly .....	7-44
7-13	A30 FFT/RAM ASSEMBLY .....	7-71
7-14	FFT/RAM Circuit Description .....	7-71
7-15	Troubleshooting the A30 Assembly .....	7-74
7-16	A40 PROCESSOR/ROM ASSEMBLY .....	7-95
7-17	Processor/ROM Circuit Description .....	7-95
7-18	Troubleshooting the Processor/ROM .....	7-100
7-19	A50 LOCAL OSCILLATOR/NOISE SOURCE ASSEMBLY .....	7-123
7-20	Local Oscillator/Noise Source Circuit Description .....	7-123
7-21	Troubleshooting the Local Oscillator/Noise Source .....	7-128
7-22	A60 DIGITAL DISPLAY DRIVER ASSEMBLY .....	7-153
7-23	Digital Display Driver Circuit Description .....	7-153
7-24	Troubleshooting the Digital Display Driver .....	7-157
7-25	A65/A66 CMOS/BUBBLE MEMORY ASSEMBLY .....	7-181
7-26	CMOS/Bubble Memory Circuit Description .....	7-181
7-27	Troubleshooting The A65/66 Assemblies .....	7-183
7-28	A70, A71, A72 POWER SUPPLY ASSEMBLIES AND PART OF .....	7-203
	A99 MOTHERBOARD ASSEMBLY	
7-29	Power Supply Circuit Description .....	7-203
7-30	Troubleshooting the Power Supply .....	7-207
7-31	A80 AND A81 KEYBOARD ASSEMBLIES .....	7-221
7-32	Keyboard Driver Circuit Description .....	7-221
7-33	Removing the Front Panel .....	7-222
7-34	Troubleshooting the Keyboard Assemblies .....	7-224
7-35	A82 ASSEMBLY: REAR PANEL .....	7-226
7-36	A90 ANALOG DISPLAY DRIVER ASSEMBLY AND PART OF .....	7-235
	A99 MOTHERBOARD ASSEMBLY	
7-37	Analog Display Driver Circuit Description .....	7-235
7-38	Troubleshooting the Analog Display Driver .....	7-238
7-39	A99 MOTHERBOARD ASSEMBLY .....	7-251
7-40	Motherboard Circuit Descriptions .....	7-251

## LIST OF TABLES

Table	Title	Page
1-1	Manual Section Descriptions .....	1-2
1-2	-hp-3561A Options .....	1-3
1-3	-hp-3561A Service Kit Contents .....	1-6
1-4	-hp-3561A Performance Specifications .....	1-7
1-5	Recommended Test Equipment .....	1-12
2-1	Performance Test Summary .....	2-3
2-2	Operational Verification Summary .....	2-4
2-3	Amplitude Accuracy/Flatness Measurement .....	2-5
2-4	Amplitude Linearity Measurement .....	2-8
2-5	Noise Level/Spurious Signal Measurement .....	2-11
2-6	Anti Alias Filter Response Measurement .....	2-17
2-7	A-Weight Filter Response Measurement .....	2-19
2-8	Phase Accuracy Measurement .....	2-21
2-9	Harmonic Frequencies Measurement One .....	2-29
2-10	Harmonic Frequencies Measurement Two .....	2-29
2-11	Intermodulation Products Measurement One .....	2-32
2-12	Intermodulation Products Measurement Two .....	2-32
2-13	Noise Source Flatness Measurement .....	2-38
3-1	-hp-3561A List of Adjustments .....	3-2
4-1	Reference Designations and Abbreviations .....	4-1
4-2	Manufactures Code List .....	4-2
4-3	Replaceable Parts .....	4-5
5-1	Revision A Assemblies Versus Revision B Assemblies .....	5-1
6-1	Recommended Test Equipment for Fault Isolation .....	6-4
6-2	Cal Failures .....	6-6
6-3	Failure Symptom Table .....	6-7
6-4	Fault Isolation Procedure Summary .....	6-4
6-12	-hp-3561A Diagnostic/Self Tests .....	6-51
7-1	Schematic Diagrams .....	7-1
7-2	Attenuator Settings vs. Range Settings .....	7-8
7-3	A-Weight Filter Characteristics .....	7-10
7-4	A10 Assembly Signal Descriptions .....	7-11
7-5	Signal Amplitudes vs. Range Setting .....	7-12
7-6	A10 Assembly Signal Connections .....	7-17
7-7	ADC Input Switch Control .....	7-25
7-8	A15 Assembly Signal Descriptions .....	7-26
7-9	A15 Assembly Signal Connections .....	7-33
7-10	Digital Filter Operation .....	7-40
7-11	A20 Assembly Signal Descriptions .....	7-42
7-12	A20 Troubleshooting Order .....	7-44
7-13	A20 Failure Symptoms .....	7-44
7-14	A20 Diagnostic Test Return Code Descriptions .....	7-45
7-15	A20 Processor Interface Signatures .....	7-47
7-16	Test 123 Channel R Address Bus Latch Signatures .....	7-54
7-17	Test 120 Digital Filter Signatures .....	7-55
7-18	Test 122 Channel G Address Bus Latch Signatures .....	7-57
7-19	A20 Assembly Signal Connections .....	7-58
7-20	A30 Assembly Signal Descriptions .....	7-74
7-21	A30 Circuit Troubleshooting Order .....	7-76
7-22	RAM Bus Arbitrator Signals with DF3BR Grounded .....	7-79
7-23	RAM Address and Data Bus Signatures .....	7-83
7-24	FFT/Processor Interface Signatures .....	7-83
7-25	Power on Test RAM Failures .....	7-85

<b>Table</b>	<b>Title</b>	<b>Page</b>
7-26	FFT Processor and ROM Signatures .....	7-86
7-27	A30 Assembly Signal Connections .....	7-87
7-28	A40 Assembly Signal Descriptions .....	7-98
7-29	A40 Circuit Troubleshooting Order .....	7-100
7-30	Processor Loop Test Input Signals .....	7-104
7-31	A40W2 Test Signatures .....	7-107
7-32	Power-on Test ROM Return Codes .....	7-109
7-33	Processor I/O and Address Bus Signatures .....	7-110
7-34	Processor Data Bus and RAM Address Bus Signatures .....	7-111
7-35	A40 Assembly Signal Connections .....	7-112
7-36	A50 Assembly Signal Descriptions .....	7-127
7-37	A50 Circuit Troubleshooting Order .....	7-128
7-38	Local Oscillator Signatures For Functional Circuits A, C, D, and F .....	7-131
7-39	Local Oscillator Signatures For Functional Circuit G .....	7-133
7-40	Local Oscillator Signatures For Functional Circuits H, I, J, and L .....	7-134
7-41	Local Oscillator Interface Signatures For Functional Circuit X .....	7-135
7-42	Noise Source Signatures for Functional Circuits O, P, R, and T .....	7-137
7-43	Noise Source Signatures For Functional Circuits Q, Y, and EE .....	7-138
7-44	Noise Source Signatures For Functional Circuits W and AA .....	7-139
7-45	A50 Assembly Signal Connections .....	7-144
7-46	A60 Assembly Signal Descriptions .....	7-156
7-47	A60 Circuit Troubleshooting Order .....	7-157
7-48	RAM Byte Address and Bit Address Signatures .....	7-164
7-49	RAM Address Signatures .....	7-167
7-50	Power On Test Return Codes for the Display RAM .....	7-167
7-51	A60 Processor Interface Signatures .....	7-170
7-52	A60 Assembly Signal Connections .....	7-170
7-53	A65 Assembly Signal Descriptions .....	7-183
7-54	A66 Circuit Troubleshooting Order .....	7-184
7-55	Test 20 RETURN CODE Descriptions .....	7-189
7-56	A65 Circuit Troubleshooting Order .....	7-1
7-57	A66/65 Assembly Signal Connections .....	7-197
7-58	Keyboard Failure Symptoms .....	7-224
7-59	Keyboard DSA Troubleshooting Information .....	7-227
7-60	A90 Assembly Signal Descriptions .....	7-237
7-61	Possible Values for A99 C5, C6, C7, C8 .....	7-246
7-62	Optimum Values for A99 C5, C6, C7, C8 .....	7-246
7-63	A90 Assembly Signal Connections .....	7-247
7-64	Signal Interconnect .....	7-251

## LIST OF ILLUSTRATIONS

Figure	Title	Page
1-1	-hp-3561A With Accessories Supplied .....	1-1
1-2	Line Voltage Ranges .....	1-7
1-3	Switch Position and Fuse Selection vs. Voltage Range .....	1-7
1-4	BNC Resistor Connector .....	1-12
2-1	Amplitude Accuracy/Flatness Test Setup .....	2-6
2-2	Amplitude Linearity Test Setup .....	2-9
2-3	Noise Level/Spurious Signal Test Setup .....	2-12
2-4	Frequency Accuracy Test Setup .....	2-14
2-5	Input Coupling Insertion Loss Test Setup .....	2-16
2-6	Anti-Alias Filter Response Test Setup .....	2-18
2-7	A-Weight Filter Response Test Setup .....	2-20
2-8	Phase Accuracy Test Setup .....	2-22
2-9	Input Resistance Test Setup .....	2-25
2-10	Input Capacitance Test Setup .....	2-26
2-11	Floating Ground Capacitance Test Setup .....	2-28
2-12	Harmonic Distortion Test Setup .....	2-30
2-13	Intermodulation Distortion Test Setup .....	2-33
2-14	Noise Source Impedance Test Setup .....	2-36
2-15	Noise Source Amplitude Accuracy Test Setup .....	2-39
2-16	External Sample Test .....	2-42
2-17	Cal Signal In External Sample Mode .....	2-43
3-1	100 Volt Input Voltage Selection Switch Setting .....	3-3
3-2	A71R1 Adjustment Location .....	3-4
3-3	A90 Adjustment and TP Locations .....	3-4
3-4	A60J100 Jumper Position .....	3-4
3-5	A99L101 Adjustment Reference .....	3-6
3-6	Display Alignment Pattern .....	3-7
3-7	A40 Adjustment Locator .....	3-8
3-8	Correctly and Incorrectly Adjusted A40C201 .....	3-9
3-9	Digitizer Adjustment Setup .....	3-10
3-10	A15 Adjustment Locator .....	3-11
3-11	Correctly and Incorrectly Adjusted A15R115 .....	3-13
3-12	Correctly and Incorrectly Adjusted A15R201 .....	3-14
3-13	Correctly and Incorrectly Adjusted A15R200 .....	3-14
3-14	A15R202 DC Offset Adjustment .....	3-15
3-15	A10 Assembly Adjustment Locations .....	3-16
3-16	Response of A10 ZERO Adjustment .....	3-18
3-17	Response of A10 A-Weight Filter Adjustment .....	3-21
3-18	A50R400 Adjustment Location .....	3-22
3-19	A50R400 Adjustment Reference .....	3-23
4-1	Mechanical Exploded View .....	4-49
5-1	A10 Assembly Revision A Component Locator .....	5-2
5-2	A40 Assembly Revision A Component Locator .....	5-5/5-6
5-3	A50 Assembly Revision A Component Locator .....	5-7/5-8
5-4	A50 Assembly RC Filter Deletion .....	5-9
5-5	A50 GCLOCK GENERATOR K Revision A Modification .....	5-11
5-6	A82 Assembly Revision A Component Locator .....	5-13
5-7	A99 Assembly Revision A Component Locator .....	5-14
6-1	Fault Isolation Procedure Flow Chart .....	6-2
6-2	A71 Component Locator .....	6-13
6-31	-hp-3561A Test Menu .....	6-53
6-32	Front Panel LED Error Indicators For Test 0 .....	6-57
6-33	HP-IB Connector Pinout Configuration .....	6-81

<b>Figure</b>	<b>Title</b>	<b>Page</b>
6-34	Reseed Module Installed Properly .....	6-92
6-36	-hp-3561A Simplified Block Diagram .....	6-94
6-37	Assembly and Cable Locations (Top View of Instrument) .....	6-98
6-38	-hp-3561A Detailed Block Diagram .....	6-99/6-100
7-1	Cal Signal Waveform .....	7-13
7-2	A-Weight Filter Response .....	7-15
7-3	Front End Control Register Waveforms .....	7-16
7-4	A/D Converter Signal Timing .....	7-24
7-5	A15 Assembly Clock Waveforms .....	7-27
7-6	A15 Assembly Analog Waveforms in Test 115 .....	7-28
7-7	Second Pass ADC Input Waveforms in Test 115 .....	7-29
7-8	Track and Hold Waveforms .....	7-30
7-9	Test Pattern Output in Test 112 .....	7-31
7-10	-hp-3561A Display in Test 113 .....	7-32
7-11	A15 Status Output .....	7-33
7-12	A20 Clock Waveforms .....	7-46
7-13	A20 Counter Clock Waveforms .....	7-48
7-14	Test 121 Counter Input Waveforms .....	7-50
7-15	A20 Counter Output Waveforms .....	7-51
7-16	Test 123 RAM Bus Interface Waveforms .....	7-52
7-17	Test 123 Channel R DMA Counter Waveforms .....	7-53
7-18	Test 122 Channel G DMA Counter Waveforms .....	7-56
7-19	"DONEG" Waveforms .....	7-57
7-20	Convert/Sync2 Waveforms in Test 122 .....	7-58
7-21	RAM Access State Machine Timing .....	7-72
7-22	RAM State Machine Waveforms .....	7-76
7-23	RAM Bus Arbitrator Waveforms .....	7-79
7-24	DF3BG With DF3BR Grounded .....	7-80
7-25	RAM Refresh Counter Waveforms .....	7-81
7-26	A40 Clock Waveforms .....	7-101
7-27	Clock Divider and Interrupt Waveforms .....	7-102
7-28	Processor Loop Test Waveforms .....	7-105
7-29	Correct Waveform at A50TP"DAC OUT" .....	7-140
7-30	Correct Waveform at A50U401(6) .....	7-141
7-31	Correct Waveform at A50U404(6) .....	7-141
7-32	Correct Waveform at A50U901(4) .....	7-141
7-33	Clock and Timing Waveforms .....	7-158
7-34	Position Address Waveforms .....	7-162
7-35	Row and Column Address Counter Waveforms .....	7-165
7-36	RAM Data Reader Waveforms .....	7-168
7-37	Beeper Timing Waveforms .....	7-169
7-38	Correct Waveforms at A66U100(4,5) .....	7-185
7-39	Correct Waveforms at A66 TP103 .....	7-186
7-40	A65 Failure Isolation Chart .....	7-187/7-188
7-41	Correct Waveforms at A65 TP301 and TP302 .....	7-190
7-42	Correct Waveform at A65 U302(6) .....	7-191
7-43	Correct Waveform at A65 U300(5) .....	7-192
7-44	Correct Waveforms at A65 U201(8,11) .....	7-192
7-45	Correct Waveform at A65 TP304 .....	7-193
7-46	Correct Output Waveform at A65 U200 .....	7-193
7-47	Correct Waveforms at A65 U2 .....	7-196
7-48	Correct Waveform at A65 U1, U100, TP1, TP2, TP4, TP104 .....	7-196



<b>Figure</b>	<b>Title</b>	<b>Page</b>
7-49	A70 Assembly Troubleshooting Waveforms .....	7-210
7-50	Correct Waveform at A71CR100 .....	7-212
7-51	Front Panel Disassembly Screw Locations .....	7-223
7-52	Correct Power-up CRT Display .....	7-225
7-53	"S" Ramp .....	7-236
7-54	PLANE2 Video Drive Waveforms .....	7-240
7-55	PLANE1 Video Drive Waveforms .....	7-240
7-56	Slow Sweep Horizontal Drive Waveforms .....	7-241
7-57	Fast Sweep Waveforms In Open Loop Mode .....	7-242
7-58	Fast Sweep Waveforms In Closed Loop Mode .....	7-243
7-59	High Voltage Waveforms .....	7-244
7-60	Measuring The CRT Anode Voltage .....	7-245
7-61	Retrace Pulse Width Measurement .....	7-246

**SECTION I**  
**GENERAL INFORMATION**

---

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
1-1	INTRODUCTION .....	1-1
1-2	MANUAL/INSTRUMENT IDENTIFICATION .....	1-2
1-3	INSTRUMENT DESCRIPTION .....	1-3
1-4	OPTIONS .....	1-3
1-5	SAFETY CONSIDERATIONS .....	1-3
1-6	OPERATOR MAINTENANCE .....	1-4
1-7	POWER REQUIREMENTS .....	1-4
1-8	AVAILABLE SERVICE KIT .....	1-6
1-9	PERFORMANCE SPECIFICATIONS .....	1-6
1-10	RECOMMENDED TEST EQUIPMENT .....	1-9
1-11	STORAGE AND SHIPMENT .....	1-11

## SAFETY SYMBOLS


### General Definitions of Safety Symbols Used On Equipment or In Manuals.



Instruction manual symbol: the product will be marked with this symbol when it is necessary for the user to refer to the instruction manual in order to protect against damage to the instrument.




Indicates dangerous voltage (terminals fed from the interior by voltage exceeding 1000 volts must be so marked).



Protective conductor terminal. For protection against electrical shock in case of a fault. Used with field wiring terminals to indicate the terminal which must be connected to ground before operating equipment.



Low-noise or noiseless, clean ground (earth) terminal. Used for a signal common, as well as providing protection against electrical shock in case of a fault. A terminal marked with this symbol must be connected to ground in the manner described in the installation (operating) manual, and before operating the equipment.



Frame or chassis terminal. A connection to the frame (chassis) of the equipment which normally includes all exposed metal structures.



Alternating current (power line).



Direct current (power line).



Alternating or direct current (power line).

#### WARNING

The WARNING sign denotes a hazard. It calls attention to a procedure, practice, condition or the like, which, if not correctly performed or adhered to, could result in injury or death to personnel.












The CAUTION sign denotes a hazard. It calls attention to an operating procedure, practice, condition or the like, which, if not correctly performed or adhered to, could result in damage to or destruction of part or all of the product.

#### NOTE :

The NOTE sign denotes important information. It calls attention to procedure, practice, condition or the like, which is essential to highlight.

Figure 5-1a A10 Assembly Revision A Component Locator



<p>250 V OPERATION</p>  <p>PLUG*: CEE7-V11 CABLE*: HP 8120-1692</p>	<p>250 V OPERATION</p>  <p>PLUG*: CEE22-V1 CABLE*: HP 8120-1860</p>	<p>250 V OPERATION</p>  <p>PLUG*: DHCR 107 CABLE*: HP 8120-2956</p>	<p>250 V OPERATION</p>  <p>PLUG*: SEV 1011.1959-24507 TYPE 12 CABLE*: HP 8120-2104</p>
<p>250 V OPERATION</p>  <p>PLUG*: NZSS 198/A5 C112 CABLE*: HP 8120-0898</p>	<p>250 V OPERATION</p>  <p>PLUG*: BS 1383A CABLE*: HP 8120-1703</p>	<p>250 V - 8A**</p>  <p>PLUG*: NEMA G-15P CABLE*: HP 8120-0896</p>	<p>125 V - 8A**</p>  <p>PLUG*: NEMA 5-15P CABLE*: HP 8120-1521</p>
<p>STD-B-1195 (REV.)</p> <p>*The number shown for the plug is the industry identifier for the plug only. The number shown for the cable is an HP part number for a complete cable including the plug. **UL listed for use in the United States of America</p>			

# **SECTION I**

## **GENERAL INFORMATION**

---

### **1-1 INTRODUCTION**

This service manual provides all the information required by service personnel to test, adjust, and service the -hp-3561A Dynamic Signal Analyzer. Figure 1-1 shows the -hp-3561A with the accessories supplied.

The Service Manual is divided into seven sections, each covering a particular topic for the servicing of the -hp-3561A. A brief description of each section is given in Table 1-1.

This service manual is designed for troubleshooting the -hp-3561A in a two step process. In step one, the information given in Section 6 is used to isolate the failure to the circuit board level. Once the failure is isolated to a circuit board, the information given in Section 7 is used to further isolate the failure to the component level. The troubleshooting procedure given below describes the standard troubleshooting process.

### **HOW TO USE THE TROUBLESHOOTING PROCEDURES**

Troubleshooting Procedure:

1. Observe the failure symptoms.
  - Does the failure affect any front panel keys?
  - Does the failure result in a Cal Failure message?
  - Does the power up test fail with an Error Return Code?
2. Check paragraph 6-7, Troubleshooting Guidelines, for the failure symptom.  
If the symptom is listed, start the fault isolation procedure with the indicated test.
3. If the failure results in a Cal Failure message, refer to paragraph 6-6, Calibration Failures. Start the fault isolation procedure with the indicated test.
4. If the power up test fails with an Error Return Code, start the fault isolation test with TEST B.
5. When in doubt, start the fault isolation test with TEST A.
6. Proceed with the fault isolation test until the failure is isolated to a circuit board.
  - If the failure is not detected by the fault isolation procedure, the performance test (Section 2) can be used to further test the -hp-3561A operation.
7. Once the Failure is isolated to a circuit board, proceed to isolate the failure to a component using the information given in Section 7.
  - If the circuit board is out of adjustment, refer to the adjustment procedures given in Section 3.

**Table 1-1 Manual Section Descriptions**

<b>Section</b>	<b>Title</b>	<b>Description</b>
I	GENERAL INFORMATION	This section contains information on how to use this manual. Also included are Safety Considerations, Recommended Test Equipment, and the -hp-3561A performance specifications.
II	PERFORMANCE TEST	The Performance Test section contains the procedure used to verify the instrument's performance specifications which are listed in Table 1-4. Also included is the Operational Verification procedure, which can be used for post repair verification or incoming inspection.
III	ADJUSTMENTS	This section describes the adjustment procedures which will return the instrument to peak operating condition after repairs are completed or for periodic preventative maintenance.
IV	REPLACEABLE PARTS	In this section, the replaceable parts are listed in order of their reference designation. This section also contains the information on how to order these parts.
V	BACKDATING	The Backdating section has the modification information necessary to adapt this service manual to -hp-3561As which were manufactured before the printing of this manual.
VI	FAULT ISOLATION	The Fault Isolation section contains the information needed to isolate failures to the circuit board level. Also included is an explanation of the Cal Failure messages, a description of the various internal diagnostic test routines, and an overall instrument theory of operation.
VII	SERVICE	This section contains the schematic diagrams, assembly level theory of operation, component level troubleshooting and component locators. They are organized in assembly reference designation order from A10 through A99.

## **1-2 MANUAL/INSTRUMENT IDENTIFICATION**

The instrument identification serial number is located on the rear panel of the instrument. Hewlett-Packard uses a two-section serial number consisting of a four digit prefix and a five digit suffix separated by a letter designating the country in which the instrument was manufactured (A = U.S.A.; G = West Germany; J = Japan; U = United Kingdom). The prefix is the same for all identical instruments and changes only when a major instrument change is made. The suffix, however, is assigned sequentially and is unique to each instrument. The contents of this manual apply directly to instruments having the same serial number prefix as listed on the title page of this manual.

Instruments manufactured after the printing of this manual may have a serial prefix that is not listed on the title page. This unlisted prefix indicates that the instrument is different from those documented in this manual. The manual for this instrument is supplied with a yellow Manual Changes supplement which contains change information that documents the differences.

In addition to change information, the supplement may contain information for correcting errors in the manual. To keep this manual as accurate and current as possible, Hewlett-Packard recommends that you periodically request the latest Manual Changes supplement.

Listed on the title page of this manual is a manual part number and a microfiche part number. The manual part number can be used to order extra copies of this service manuals. The microfiche part number can be used to order 4 by 6 inch microfilm transparencies of this service manual.

### 1-3 INSTRUMENT DESCRIPTION

The -hp-3561A is a high performance, single channel Dynamic Signal Analyzer designed for portable or bench use. Its frequency coverage of 0 to 100kHz with a dynamic range of 80dB makes it suitable for vibration and rotational machinery analysis, as well as audio and general purpose electronic measurements.

Fast Fourier Transform (FFT) and Digital Filter technology is used in the -hp-3561A as well as a raster scan CRT and a line switching power supply. HP-IB is standard with the ability to plot directly to an HP-GL plotter with its own built-in software eliminating the need for a controller.

### 1-4 OPTIONS

There are four options available to the -hp-3561A. They are available either when the instrument is ordered or for later installation. These options are listed in Table 1-2.

**Table 1-2 -hp-3561A Options**

Option	Description
001	Bubble Memory
908	Rack Mounting Kit
910	Extra Operating Manual
910	Extra Service Manual

### 1-5 SAFETY CONSIDERATIONS

The -hp-3561A is a Safety Class 1 instrument (provided with a protective earth terminal). Although this instrument has been designed in accordance with international safety standards, this manual contains information, cautions and warnings which must be followed to ensure safe operation and to retain the -hp-3561A in safe operating condition. Service and adjustments should be performed only by qualified personnel who are aware of the hazards involved.



## 1-6 OPERATOR MAINTENANCE

Operator maintenance is limited to replacing the line fuse and cleaning the fan filter. There are no operator controls or user serviceable parts inside the -hp-3561A. Only trained service personnel should perform instrument repairs.

### WARNING

*To avoid serious injury, disconnect the ac line power cord before removing or installing the ac line fuse.*

### WARNING

*Only fuses with the required rated current and specified type should be used for replacement. The use of repaired fuses and short circuiting of fuse holders is not permitted. Whenever it is likely that the protection offered by the fuse has been impaired, the -hp-3561A must be made inoperative and secured against any unintended operation.*

### WARNING

*Under no circumstances should an operator remove any covers, screws, or in any other way enter the -hp-3561A. There are no operator controls inside the -hp-3561A.*

## 1-7 POWER REQUIREMENTS

### CAUTION

*Before applying ac line power to the -hp-3561A, ensure that the voltage selection switches on the bottom of the instrument are set for the proper line voltage and that the correct line fuse is installed in the rear panel fuse holder.*

The -hp-3561A can be operated from any single phase ac power source supplying 100V, 120V, 220V, or 240V (-10% to +5%). For 100/120V power, the -hp-3561A can be operated in the frequency range of 48-440 Hz. For 220/240V power, the -hp-3561A can be operated in the frequency range of 48-66 Hz. Power consumption is less than 120VA. Refer to Figure 1-2 for the line voltage ranges and Figure 1-3 for the switch positions and fuse selection verses voltage range.

Figure 1-2 Line Voltage Ranges





Figure 1-3 Switch Position and Fuse Selection versus Voltage Range

Line Setting	Fuse Type	-hp- Part No.
110 V/120 V	3 A 250 V Normal Blow	2110-0003
220 V/240 V	1.5 A TD 250 V Time Delay	2110-0304



## 1-8 AVAILABLE SERVICE KIT

A Service Kit, HP part number 03561-84401, is needed to repair the -hp-3561A. This service kit can be ordered through your local HP sales office. Refer to Section 5, Replaceable Parts, for ordering instructions. Included in the kit are special adapter cables, extender boards and a circuit module for servicing the Bubble Memory option. Table 1-3 lists the contents of the -hp-3561A Service Kit.

**Table 1-3 -hp-3561A Service Kit Contents**

Description	Qty.	-hp- Part Number
BNC-J Cable Adapter	1	03585-61616
J Male-Male Adapter	1	1250-0669
Bubble Memory Reseed Module	1	1818-3304
PC Extender Board 25 Dual Pin	1	03561-66595
PC Extender Board 22 Dual Pin	1	03561-66596
Adjustment Tool .1 inch Hex	1	8710-1388

## 1-9 PERFORMANCE SPECIFICATIONS

The -hp-3561A performance specifications are listed in Table 1-4. These specifications are the performance standards or limits against which the -hp-3561A is to be tested.

Table 1-4 -hp-3561A Performance Specifications

**3561A SPECIFICATIONS**

Specifications describe the instrument's warranted performance. Supplemental characteristics are intended to provide information useful in applying the instrument by giving typical, but non-warranted, performance specifications. Supplemental characteristics are denoted as 'typical,' 'nominal,' or 'approximately.'

Frequency and Time		TYPICAL REAL TIME BANDWIDTH:	Operating mode	Real time bandwidth	Spectra/sec
MEASUREMENT MODES:	<b>Narrowband:</b> 125 $\mu$ Hz to 100,000 Hz frequency range. Resolution is frequency span/400. All window, trigger and averaging types are available.		HP-IB transfer	750 Hz	1.9
	<b>Phase:</b> Phase spectrum is available with or without triggering. When triggered, phase is referenced to the trigger		Single display	3 kHz	7.5
	<b>1/2 Octave:</b> 0.8 Hz to 80 kHz - see separate Octave section.		Fast Averaging	7.5 kHz	20
	<b>Full Octave:</b> 1 Hz to 63 kHz - see separate Octave section				
	<b>Time Capture:</b> Time record can be extended from 1k to 40k samples of continuous input data. Up to 40x zoom expansion factor can be applied to this data				
	<b>External Sampling:</b> Input sample rate can be externally controlled up to 256 kHz. TTL compatible sample rate input on rear panel. (Note: Some specs may be degraded in external sample mode).				
FREQUENCY SELECTION:	<b>0 to 100 kHz:</b> Measurement is made over the full frequency range of the analyzer with 250 Hz resolution				
	<b>Define Start or Center:</b> Measurement is made over the selected frequency span. Start or center frequency can be set anywhere in the 0 to 100 kHz range with resolution of 0.25 Hz.				
	<b>Define Span:</b> Measurement frequency spans are provided in a 1, 2, 2.5, 5, 10 sequence. (Other spans exist between these intervals, but are too numerous to list in the space available.)				
	<b>Define Time Length:</b> Measurement time can be set from 0.004 seconds to 651 minutes per time record. Time setting is rounded up to agree with next available span.				
ACCURACY:	<b>Frequency Accuracy:</b> $\pm 0.003\%$ of frequency reading				
RESOLUTION:	<b>Frequency Resolution:</b> Span/400				
SPANS:		Zoom	Baseband		
	# spans available	43	52		
	min span	0.25 Hz	0.01 Hz		
	max span	100 kHz	100 kHz		
	time record length resolution	400/span span/400	400/span span/400		
MEASUREMENT WINDOWS:	Windows are weighting functions which are applied to input data to reduce measurement errors due to leakage.				
	<b>Flat Top:</b> Provides optimum amplitude accuracy.				
	<b>Hann:</b> Provides an amplitude accuracy/frequency resolution compromise. Useful for general purpose and measurements using random noise.				
	<b>Uniform:</b> Equal weighting of the time record for measuring transients, or response measurements using the internal periodic noise source.				
	<b>Exponential:</b> Variable exponential decay weighting is applied to the time record. Useful for transients which have a duration greater than the time record.				
	<b>Window Parameters:</b>				
		Flat Top	Hann	Uniform	
	Noise Equiv. BW (% of span)	0.955	0.375	0.25	
	3dB BW (% of span)	0.90	0.37	0.25	
	Shape factor (60dB BW/3dB BW)	2.6	9.1	716	

## Amplitude and Input

**AMPLITUDE:**

**Input Range:** The calibrated input range is 27 dBV (+22.4 V) to -51 dBV (3 mV) maximum input level (single tone RMS). Range is adjustable in 1 dB (10%) increments.

**Autorange:** The optimum input range is automatically selected prior to processing. This feature can be deactivated.

**Amplitude Overload/Underload:** Overload occurs when the input level exceeds input range by nominally 1.0 dB or 10%. Overload measurements can be automatically rejected during averaging. The HALF range indicator lights when input signal is within 6 dB of full scale.

**Dynamic Range:** Distortion, spurious and alias products  $\geq 80$  dB below input range.

**DC Response:** (With Auto-Cal on)  
+27 dBV to -35 dBV:  $>30$  dB below input range  
-36 dBV to -51 dBV:  $>20$  dB below input range

**Amplitude Marker Resolution:**  
Log: 0.01 dB  
Linear: 4 digits

**Amplitude Accuracy:**  
Full Scale Accuracy at calculated frequency points  
Overall accuracy is the sum of absolute accuracy, window flatness and noise level.

**Absolute Accuracy:**  
 $\pm 0.15$  dB  $\pm 0.015\%$  of input range.  
+27 dBV to -40 dBV  
 $\pm 0.25$  dB  $\pm 0.025\%$  of input range.  
-41 dBV to -51 dBV

**Window flatness:**  
Flat top: +0, -0.01 dB  
Hanning: +0, -1.5 dB  
Uniform: +0, -4.0 dB

**Noise Level:** Flat top filter, 50 $\Omega$  source impedance,  
20 Hz to 1 kHz (1 kHz span)  $< -131$  dBV  
(-141 dBV/ $\sqrt{\text{Hz}}$ )  
2 kHz to 100 kHz (100 kHz span)  $< -120$  dBV  
(-150 dBV/ $\sqrt{\text{Hz}}$ )

**Phase Marker Resolution:** 0.1 degree

**Phase Accuracy:**  $\pm 2^\circ$ , dc-10 kHz.  $\pm 10^\circ$  10 kHz - 100 kHz referenced to the trigger point.

**INPUT:**

**Input Impedance:** 1M $\Omega$   $\pm 5\%$  shunted by 95 pF maximum  
Floating Ground to Case Capacitance:  $< 0.25$   $\mu$ F

**DC Isolation:** Input low may be connected to chassis ground or floated up to 30 volts RMS (42 Vpk).

**Input Coupling:** The input signal may be ac or dc coupled. Low frequency 3 dB roll off  $< 1.0$  Hz for ac.

**Anti-Alias Filter Roll-Off:** Analog and digital anti-aliasing filters roll off at a nominal rate of 130 dB/octave with a cut-off frequency at 105 kHz nominally.

**A-Weight Filter:** The hardware A-weight input filter conforms to ANSI Standard S1.4-1971.(R1976)

**ICP Current:** Nominal 4 mA current source provided on input BNC connector. Compatible with Integrated Circuit Piezoelectric accelerometers. Open circuit voltage is 24 volts nominal.

Table 1-4 -hp-3561A Performance Specifications (Cont'd)

### Octave Analysis

The measurement is made in synthesized  $\frac{1}{3}$  or full (1/1) octave bands. Filter bandwidth, center frequency, and bandshape meet ANSI Class III (Class II for full octave) specifications.

	# Bands Available	# Bands Displayed
1/3	51	33
1/1	17	11

#### 1/3 and 1/1 Octave Analysis Parameters:

	Band center Frequency Range	Data Collection Time	Band #'s Displayed
1/3 Octave	50 Hz to 80 kHz	0.4 sec	17 to 49
	25 Hz to 40 kHz	0.8 sec	14 to 46
	12.5 Hz to 20 kHz	1.6 sec	11 to 43
	6.3 Hz to 10 kHz	3.2 sec	8 to 40
	3.15 Hz to 5 kHz	6.4 sec	5 to 37
	1.6 Hz to 2.2 kHz	12.8 sec	2 to 34
1/1 Octave	0.8 Hz to 1.25 kHz	25.6 sec	-1 to 31
	63 Hz to 63 kHz	0.4 sec	18 to 48
	31.5 Hz to 31.5 kHz	0.8 sec	15 to 45
	16 Hz to 16 kHz	1.6 sec	12 to 42
	8 Hz to 8 kHz	3.2 sec	9 to 39
	4 Hz to 4 kHz	6.4 sec	6 to 36
	2 Hz to 2 kHz	12.8 sec	3 to 33
	1 Hz to 1 kHz	25.6 sec	0 to 30

**Computation Time:** 1/3 octave and 1/1 octave computation is made in less than 0.80 seconds

### Trigger

#### TRIGGER MODES:

**Free Run:** A new measurement is initiated by completion of the previous measurement.

**External:** A new measurement is initiated by a TTL pulse applied to the rear panel external trigger input.

**Internal:** Allows measurements to be initiated by pressing manual arm.

**Input:** A new measurement is initiated when the input signal meets the defined trigger level conditions.

**Source:** New measurements are synchronized with the internal source.

**HP-IB:** A new measurement is initiated by sending a group execute trigger from an external controller over the HP-IB.

#### TRIGGER ARM:

**Auto Arm:** Measurements are initiated automatically when trigger conditions are met.

**Manual Arm:** Enables a single measurement when the trigger conditions are met.

#### TRIGGER LEVEL:

Triggering can be set to occur when the input reaches a user definable input level. Definable from 0 to 110% of full range setting. Positive and negative levels and slopes can be set.

#### TRIGGER DELAY:

**Pra-Trigger:** The measurement can be based on input data from 1/1024 to 8 time records before trigger conditions have been met, with resolution of 1/1024 of a record. Time capture mode can be used for pre-trigger delays of up to 40 records.

**Post-Trigger:** The measurement is initiated from 1/1024 to 1023 time records after trigger conditions have been met. Resolution is 1/1024 of a record.

### Measurement Averaging

#### AVERAGING TYPES:

**RMS:** For each calculated frequency point the displayed amplitude is averaged in a root mean square fashion.

**Peak Hold:** Same as RMS except the maximum amplitude value is stored for each frequency bin. Phase is not available.

**RMS Exponential Weighting:** After each spectrum measurement the average is updated by weighting the new spectrum and the previous average as follows, where  $k$  is a user defined factor.

$$A_j = (1-k)A_{j-1} + (k)A_{new}$$

**Time:** For each calculated frequency point the displayed amplitude and phase are averaged linearly. In this mode, a trigger signal is required, and signals that are not synchronous with the trigger will average toward zero.

**Number of Averages:** 1 to 16,383.

#### AVERAGE CONTROL:

**Start:** Starts a new average or measurement.

**Pause/Cont.:** Pauses the average, or continues a paused average.

**Overload Reject:** Automatically detects and rejects overloaded blocks from the average.

**Fast Display:** Provides maximum averaging rate by not displaying intermediate results.

**Normal Display:** The average is computed and displayed for each new spectrum.

**Repeat Display:** The Repeat Display function inhibits the display of intermediate average results. Only the final computed average is displayed, and then the measurement is restarted. Available in RMS and time average modes only.

### Source

Band limited, band translated pseudo random, random, impulse or TTL "sync" signals are available on the rear panel. Impulse produces nominal 2 V peak into 50  $\Omega$ , with no attenuation.

**Impedance:** 50  $\pm 5$  ohms.

#### LEVEL AND ACCURACY:

Baseband	All spans*	0.7 V rms $\pm 10\%$
Zoom	All spans	0.5 V rms $\pm 15\%$

\* Random Source in 0-100 kHz span has level accuracy of  $\pm 20\%$ .

#### FLATNESS:

		Periodic	Random**
Baseband	0-50 kHz	$\pm 0.7$ dB	$\pm 0.7$ dB
	0-100 kHz	$\pm 0.8$ dB	$\pm 1.6$ dB
zoom	all spans	$\pm 2.0$ dB	$\pm 2.0$ dB

\*\* Random Source flatness approaches these specs as number of RMS Averages increases.

Note: All zoom flatness specs are valid if center frequency  $> 0.7 \times \text{span}$

#### ATTENUATION:

(nominal 1.5 dB steps)	max attenuation
pseudo random, random	40.5 dB
impulse	30 dB

Table 1-4 -hp-3561A Performance Specifications (Cont'd)

## Display

Magnitude, Phase, Time and Math traces may be selected. Units available are: Horizontal: Hz, Seconds, RPM, and Orders with linear or logarithmic spacing. Vertical: Volts, dBV, dBm (selectable R), and user defined units.

### MAGNITUDE:

**Log:** 0.5 to 40 dB/division. Units of dBV, dB relative, dBm (user defined impedance) and dBEU are provided.

**Linear:** Constant volts/division, milliwatts/division, or user defined units/division.

### PHASE:

**Resolution:** 0.1 degree with marker

**Display Range:**  $\pm 240$  degrees about user definable center reference ( $\pm 320$  degrees)

### TIME:

**Resolution** = Time Record Length (sec)/400

**Display Range:**  $\pm 110\%$  of input range.

### MATH:

Arithmetic operations can be performed on new and recalled traces. Addition, subtraction, multiplication, division, single and double integration, differentiation and user definable constants are provided. 1/BW is provided for PSD computations.

### FORMAT:

**Single:** Selected data is displayed on full CRT trace height.

**Front-Back:** Two selected traces are displayed simultaneously, full CRT height. Back trace has no marker and is displayed at "half bright" intensity

**Upper-Lower:** Two one-half height traces can be displayed.

**Map:** 1 to 60 amplitude spectra may be displayed simultaneously in a "spectral map" display. These may be consecutive measurement spectra, stored traces, or transformed from time capture records.

### SCALE:

Linear or Log magnitude scales may be selected. Full scale, dB/div, and degrees/div are user definable. Center scale definable in time or phase traces.

**Autoscale:** Provides a one time automatic scaling of data to optimize display scale and units per division for best view.

## Internal Memory

	Traces + States (non-volatile)	Time Buffer (volatile)
Standard	2 traces + 6 states	40 time records
Option 001	traces + states + (1 + 2 $\times$ time capture records) = 127	40 time records

## Marker

**Single:** Provides precision readout of X and Y axis values of currently displayed units. MKR  $\rightarrow$  Peak, MKR  $\rightarrow$  Center Frequency, MKR  $\rightarrow$  Full Scale and Peak-track are provided. Relative marker provides measurements relative to a reference which can be set with the single marker or user-defined X and Y axis unit settings.

**Band Power:** Two independently controllable markers may be used to calculate power in a given band.

**Harmonic:** Up to 20 harmonics of the selected fundamental are marked. T.H.D. is calculated and displayed

**Sideband:** Up to 10 modulation sidebands can be marked. Carrier frequency is user definable. The ratio of sideband to carrier power is displayed

**Amplitude Marker Resolution:** log 0.01 dB  
linear: 4 digits

## Plot

Controls HP-GL compatible digital plotters and raster graphics printers directly. Replicates display contents. "MARKER plot" allows marker position and amplitude to be annotated on plots at user defined locations.

## General

### Specifications apply when:

Warm-up time: None with AUTO-CAL enabled, or 30 minutes without AUTO-CAL enabled  
Within 5°C and 2 hrs of last internal calibration.  
Ambient temperature: 0° to 55° C  
Relative Humidity: < 95% at 40° C.  
Altitude: < 4570m (15,000 ft.)

**Storage:** Temperature: -40° to +75° C.  
Altitude: < 15,240m (50,000 ft.)

**Power:** 100/120 VAC + 5% - 10%, 48-440 Hz  
220/240 VAC + 5% - 10%, 48-66 Hz  
150 VA maximum

**Weight:** 15 kg (33 lbs) net  
21.6 kg (47.5 lbs) shipping

**Dimensions:** Without handle: 197mm (7.8") high  
335mm (13.2") wide  
595mm (23.4") deep

**HP-IB:** Implementation of IEEE Std 488-1978  
SH1 AH1 T5 TEO L4 LEO SR1 RL1 PPO DC1 DT1 CO

**Accessories Included:** Front (bail) handle, pouch, front cover, Operating and Service manuals

### Accessories:

Transit case for 3561A: HP # 9211-2459  
Rack Adapter for 3561A: HP #10491B, also requires fixed slides (1490-0714) or pivot slides (1490-0768).

## 1-10 RECOMMENDED TEST EQUIPMENT


The equipment required to maintain the -hp-3561A is listed in Table 1-5, Recommended Test Equipment. If the recommended model number is not available, a substitute can be used if it meets or exceeds the listed critical specifications. When substitutes are used, the user may have to modify the performance and adjustment procedures to accommodate the different operating characteristics of the substitute.

**Figure 1-4 Series Resistor BNC Case**

Resistance	Tolerance	Power	-hp- Part Number
1 k $\Omega$	1%	.25 W	0757-0280
100 k $\Omega$	1%	.25 W	0757-0465

**Assembly**

1. Cut resistor leads to 12mm on each end.
2. Solder one resistor lead to the center conductor of the BNC FEMALE connector.
3. Solder the CONDUCTOR CENTER PIN to the other lead of the resistor.
4. Screw the SLEEVE and the BNC MALE connector into place. Tighten securely.



## 1-11 STORAGE AND SHIPMENT

### Environment

The -hp-3561A should be stored in a clean, dry environment. The following are environmental limitations that apply to both storage and shipment:

Temperature .....-40°C to +75°C  
Humidity .....Up to 95%  
Altitude .....Up to 15,300 meters (50,000 feet)

The instrument should also be protected from temperature extremes which cause condensation within the instrument.

### Original Packaging

Containers and materials equivalent to those used in factory packaging are available through Hewlett-Packard offices. If the instrument is being returned to Hewlett-Packard for service, attach a tag indicating the type of service required, return address, model and full serial number.

### Other Packaging

The following general instructions should be used for repackaging with commercially available materials:

1. Wrap the instrument with heavy paper or plastic.
2. Use a strong shipping container. A doublewall carton made of 350 pound test material is adequate.
3. Use a layer of shock absorbing material 70 to 100 mm (3 to 4 inches) thick around all sides of the instrument to provide firm cushioning and prevent movement inside of the container. Protect the control panel with cardboard.



*Styrene pellets in any shape should never be used as packing material. The pellets do not adequately cushion or prevent the instrument from shifting in the carton. The pellets also create static electricity which can damage electronic components.*

4. Seal the shipping container securely.
5. Mark the shipping container FRAGILE to ensure careful handling.
6. In any correspondence, refer to the instrument by model and full serial number.



Table 1-5 Recommended Test Equipment

Description	Qty	Critical Specifications	Recommended Model	Use *
AC Calibrator	1	Frequency Range: 10 Hz - 100 kHz Amplitude Range: 3 - .003 Vrms Amplitude Accuracy: .02 dB Phase Locking Capability	FLUKE 5200A  Alternatives: -hp-745	P,O A
Frequency Synthesizer	1	Frequency Range: 1 Hz - 1 MHz Frequency Accuracy: 5 ppm Amplitude Range: +8 - -50 dBV Amplitude Accuracy: 0.2 dB 1 Hz - 100 kHz 1.0 dB 100 kHz - 1 MHz Harmonic Distortion: All harmonics < -60 dB below carrier.	-hp-3325A Option 001 Alternatives: -hp-3336C -hp-3320B -hp-3330B	P,O A,T F
Digital Voltmeter	1	5 Digit Input Impedance: > 1 MΩ AC Voltage- Frequency Range: 30 Hz - 1 MHz Amplitude Range: 0.1 - 500 Vrms Amplitude Accuracy: .05% DC Voltage- Amplitude Accuracy: .05%	-hp-3455A	P,O A,T F
Oscilloscope	1	Bandwidth: > 50 MHz Two Channel External Trigger	-hp-1980 A,T  Alternatives: -hp-1740	P,O  F
High Voltage Probe	1	Division Ratio: 1000:1 Maximum Voltage: > 8000 Vrms Impedance 1000 MΩ	-hp-34111A	T,A
Signature Analyzer	1	Maximum Clock: > 25 MHz Clock Set-up Time: < 20 nSec	-hp-5006A  Alternatives: -hp-5005A -hp-5005B -hp-3466A	T  T
Digital Multimeter	1	Volts AC Volts DC Ohms	Alternatives: -hp-3438A -hp-3468A -hp-3478A	T
-hp-3561A Service Kit	1	No Substitute (See Table 1-2 for individual part numbers)	03561-84401	T,A F

\* P = Performance Test  
 O = Operational Verification  
 A = Adjustment  
 T = Troubleshooting  
 F = Fault Isolation

Table 1-5 Recommended Test Equipment (cont)

Description	Qty	Critical Specifications	Recommended Model	Use *
Low Distortion Oscillator	1	Frequency Range: 1 Hz - 1 MHz Amplitude Range: 2 Vrms Distortion: < -80 dB (.01%)THD	-hp-339	P,A T,F
Resistor	2	Accuracy: 1% Power: .25 W Value: 100 k $\Omega$	See Figure 1-4	P
Resistor	1	Accuracy: 1% Power: .25 W Value: 1 k $\Omega$		P
Probe, Oscilloscope	1	Impedance: 10 M $\Omega$ Division Ratio: 10:1 Maximum Voltage: 500 Vdc	-hp-10014A Alternatives: -hp-10016B -hp-10004A -hp-10005D	T,A
Termination	1	50 ohm Feedthrough	-hp-10100C	P,O,A, T,F
Termination	1	600 ohm Feedthrough	-hp-11095A	P,O,A, T,F
Variable AC Power Supply		Voltage Range: 80 - 120VAC Frequency Range: 50 Hz or 60 Hz Voltage Accuracy: $\pm 2$ %	**	A
Controller	1	HP Series 200 Computer	-hp-9836	T***
Boot Loop Program	1	Runs on HP Series 200 Computer	03561-19400	T***

\* P = Performance Test  
 O = Operational Verification  
 A = Adjustment  
 T = Troubleshooting  
 F = Fault Isolation

\*\* No specific model number is recommended, any Variable AC Power Supply which meets the listed critical specifications may be used.

\*\*\* Required for -hp-3561A Option 001 only

**SECTION II**  
**PERFORMANCE TEST**

---

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
2-1	INTRODUCTION .....	2-1
2-2	CALIBRATION CYCLE .....	2-1
2-3	REQUIRED TEST EQUIPMENT .....	2-2
2-4	PERFORMANCE TEST SUMMARY .....	2-3
2-5	OPERATIONAL VERIFICATION SUMMARY .....	2-4
2-6	dc Offset .....	2-4
2-7	Amplitude Accuracy/Flatness .....	2-5
2-8	Amplitude Linearity .....	2-8
2-9	Noise Level/Spurious Signal Level .....	2-11
2-10	Frequency Accuracy .....	2-13
2-11	Input Coupling Insertion Loss .....	2-15
2-12	Anti Alias Filter Response .....	2-17
2-13	A-Weight Filter Response .....	2-19
2-14	Phase Accuracy .....	2-21
2-15	Input Impedance .....	2-24
2-16	Floating Ground Capacitance .....	2-27
2-17	Harmonic Distortion .....	2-29
2-18	Two Tone Intermodulation Distortion .....	2-32
2-19	Noise Source Output Impedance .....	2-36
2-20	Noise Source Amplitude Accuracy/Flatness .....	2-38
2-21	External Sample .....	2-42
2-22	Internal Self Test .....	2-44

## **SECTION II**

# **PERFORMANCE TEST**

---

### **2-1 INTRODUCTION**

This section contains the procedures for the performance tests which will verify the 3561A's conformance to its published specifications listed in Table 1-4. A complete performance test consists of running the tests listed in paragraph 2-4, PERFORMANCE TEST SUMMARY, and requires approximately five hours to complete. If complete performance testing is not required, an operational verification can be performed. The operational verification does not verify conformance to published specifications, however, it does provide a high level of confidence regarding correct instrument operation. An operational verification consists of running all of the tests listed in paragraph 2-5, OPERATIONAL VERIFICATION SUMMARY, and requires approximately one hour to complete.

For your convenience, a Performance Test Record card is provided at the end of this section to record the 3561A's performance test, or operational verification test results. This card can be removed from the manual and used as a permanent record of the test results. The Performance Test Record may be reproduced without the written permission of Hewlett-Packard.

### **2-2 CALIBRATION CYCLE**

The hp-3561A Dynamic Signal Analyzer requires a complete Performance Test every twelve months to verify conformance to its published specifications. The operational verification can be used as part of installation, incoming inspection, or after a repair to verify general operation.

## 2-3 REQUIRED TEST EQUIPMENT

The equipment required to test the -hp-3561A is listed in Table 1-5. If the recommended equipment is not available, a substitute, which meets or exceeds the "Required Characteristics" given in the table, may be used. When substitutions are made the user may have to modify the performance test procedures to accommodate the different operating characteristics of the substitute. The equipment required for each test is listed at the beginning of each individual test section.

When the recommended test equipment of Table 1-5 is used to complete the performance tests, the instruments listed below must be set to the preset conditions listed before beginning the tests. If any equipment parameters are not specified in the individual test, the unspecified parameter should be set to the condition listed below.

### -hp-3325A Frequency Synthesizer

FUNCTION .....SINEWAVE (~)  
 FREQUENCY .....1 kHz  
 AMPLITUDE .....1 mVrms  
 PHASE .....0 degrees  
 dc OFFSET .....0 V  
 MODULATION.....OFF  
 SWEEP.....OFF

### -hp-3455A Digital Voltmeter

FUNCTION .....AC V (~ V)  
 RANGE .....AUTO  
 TRIGGER.....INTERNAL  
 SAMPLE RATE .....MAXIMUM  
 HIGH RESOLUTION.....ON  
 AUTO CAL.....ON

### Fluke 5200 AC Calibrator

FREQUENCY .....1 kHz  
 AMPLITUDE . .01 Vrms (equivalent to -40 dBV)  
 VOLTAGE ERROR-% .....OFF  
 VERNIER .....0  
 MODE.....OPER  
 CONTROL .....LOCAL  
 PHASE LOCK .....OFF  
 SENSE .....INTERNAL

## 2-4 PERFORMANCE TEST SUMMARY

The tests listed in Table 2-1 must be completed to verify that the -hp-3561A meets its published specifications. Because some tests depend on previous test results, the tests must be performed in the order listed. No warm up time is required. If any of the tests fail, the -hp-3561A must be either repaired or adjusted. The "What if the Test Fails" column of Table 2-1 indicates the troubleshooting procedures or adjustments most likely to correct the failure.

**Table 2-1 Performance Test Summary**

Paragraph Number	Test Name	What if the Test Fails			
		Adjustments		Troubleshooting	
		Assembly	Paragraph	Assembly	Paragraph
2-6	dc Offset	A10	3-17	A10	7-4
		A15	3-12	A15	7-7
2-7	Amplitude Accuracy/ Flatness	A10	3-13	A10	7-4
		A15	3-9	A15	7-7
2-8	Amplitude Linearity	A15	3-9	A10	7-4
				A15	7-7
2-9	Noise Level/ Spurious Signal Level	A15	3-9	A10	7-4
				A15	7-7
				A20	7-10
2-10	Frequency Accuracy	A40	3-8	A40	7-16
2-11	Input Coupling Insertion Loss			A10	7-4
2-12	Anti-Alias Filter Response			A15	7-7
2-13	A-Weight Filter Response	A10	3-18	A10	7-4
2-14	Phase Accuracy			A15	7-7
				A20	7-10
2-15	Input Impedance			A10	7-4
2-16	Floating Ground Capacitance			A10	7-4
2-17	Harmonic Distortion	A15	3-9	A10	7-4
				A15	7-7
2-18	Two-Tone Intermodulation Distortion	A15	3-9	A10	7-4
				A15	7-7
2-19	Noise Source Output Impedance			A50	7-19
				A82	7-35
2-20	Noise Source Amplitude	A50	3-19	A50	7-19
	Accuracy/Flatness	A50	3-19	A82	7-35





† 2. When the calibration is complete, press the -hp-3561A START key to initiate a measurement.

† 3. When the average is complete, move the marker to 0 Hz and record the the marker amplitude (Y:) reading on the Performance Test Record.

† 4. Set the -hp-3561A controls as follows:

RANGE ..... DEFINE RANGE .. .....-25 dBV

† 5. Repeat steps 2 and 3.

† 6. Set the -hp-3561A controls as follows:

RANGE ..... DEFINE RANGE .. .....-51 dBV

† 7. Repeat steps 2 and 3.

## 2-7 Amplitude Accuracy/Flatness †

This test measures the amplitude accuracy of the -hp-3561A against the amplitude reference of the ac calibrator. To insure that the ac calibrator output is set to the center of an -hp-3561A measurement bin, the ac calibrator is frequency locked to the frequency synthesizer. The amplitude accuracy is measured at each of the points listed in Table 2-3.

**Table 2-3 Amplitude Accuracy/Flatness Measurement**

Signal Frequency	Range Setting	ac Calibrator Amplitude	Tolerance
† 1 kHz	8 dBV	( 2.5119 Vrms )	± .15 dB
† 99 kHz	8 dBV	( 2.5119 Vrms )	± .15 dB
† 1 kHz	-11 dBV	( .28184 Vrms )	± .15 dB
† 99 kHz	-11 dBV	( .28184 Vrms )	± .15 dB
1 kHz	-22 dBV	( 79.433 mVrms )	± .15 dB
50 kHz	-22 dBV	( 79.433 mVrms )	± .15 dB
90 kHz	-22 dBV	( 79.433 mVrms )	± .15 dB
100 kHz	-22 dBV	( 79.433 mVrms )	± .15 dB
1 kHz	-51 dBV	( 2.8184 mVrms )	± .25 dB
1 kHz	-49 dBV	( 3.5481 mVrms )	± .25 dB
1 kHz	-47 dBV	( 4.4668 mVrms )	± .25 dB
1 kHz	-45 dBV	( 5.6234 mVrms )	± .25 dB
1 kHz	-43 dBV	( 7.0795 mVrms )	± .25 dB
1 kHz	-41 dBV	( 8.9125 mVrms )	± .25 dB
1 kHz	-39 dBV	( 11.220 mVrms )	± .15 dB
1 kHz	-29 dBV	( 35.481 mVrms )	± .15 dB
1 kHz	-27 dBV	( 44.668 mVrms )	± .15 dB
1 kHz	-25 dBV	( 56.234 mVrms )	± .15 dB

† When performing an operational verification rather than a full performance test, complete these measurements only.

## Specification

For an input sine wave with an amplitude equal to the range setting, the marker amplitude reading will not deviate from the actual signal amplitude by more than:


Range Setting	Accuracy
+23 dBV to -39 dBV	.15 dB (1.74%)
-40 dBV to -51 dBV	.25 dB (2.92%)

## REQUIRED TEST EQUIPMENT

Frequency Synthesizer .....	-hp-3325A
AC Calibrator .....	FLUKE 5200A

## INITIAL TEST SETUP

**Figure 2-1 Amplitude Accuracy/Flatness Test Setup**



**PROCEDURE**

- † 1. Connect the test instruments as shown in Figure 2-1 and set the instrument controls as follows:

## Frequency Synthesizer

Function . . . . . Square Wave  
 Frequency . . . . . 1 kHz  
 Amplitude . . . . . 1 Vrms

## AC Calibrator

Frequency . . . . . 1 kHz  
 Amplitude . . . . . 2.5119 Vrms (8 dBV)  
 Phase Lock . . . . . ON  
 Sense . . . . . INTERNAL  
 Mode . . . . . OPER

## -hp-3561A

PRESET  
 RANGE . . . . . DEFINE RANGE . . . . . 8 dBV  
 FORMAT . . . . . SINGLE  
 AVerage . . . . . RMS  
                     DEFINE NUM  
                     AVGS . . . . . 4 ENTER  
 INPUT . . . . . SINGLE CAL

- † 2. When the calibration is complete, press the -hp-3561A START key to initiate measurement.
- † 3. When the average is complete, move the marker to 1 kHz and record the marker amplitude (Y:) reading on the Performance Test Record.
- † 4. Set the ac calibrator controls as follows:  
 Frequency 99 kHz
- † 5. Set the frequency synthesizer controls as follows:  
 Frequency . . . . . 99 kHz
- † 6. Press the -hp-3561A START key to initiate a measurement.
- † 7. When the average is complete, move the marker to 99 kHz and record the marker amplitude (Y:) reading on the Performance Test Record.
- † 8. Set the ac calibrator controls as follows:  
 Frequency . . . . . 1 kHz  
 Amplitude . . . . . 2 8184 Vrms (-11 dBV)

- † 9. Set the frequency synthesizer controls as follows:

Frequency ..... 1 kHz

- † 10. Set the -hp-3561A controls as follows:

RANGE ..... DEFINE RANGE ... -11 dBV

- † 11. Press the -hp-3561A START key to initiate a measurement.

- † 12. When the average is complete, move the marker to 1 kHz and record the marker amplitude (Y:) reading on the Performance Test Record.

- † 13. Repeat steps 8 through 12 for each of the remaining measurements listed in Table 2-3. For each measurement, set the ac calibrator and the frequency synthesizer to the signal frequency listed in the Table. Set the -hp-3561A range setting and the ac calibrator amplitude to the corresponding values listed. Record the marker amplitude (Y:) reading on the Performance Test Record for each measurement.

## 2-8 Amplitude Linearity

This test measures the amplitude linearity of the -hp-3561A against the amplitude reference of the ac calibrator. The ac calibrator is used to input a signal to the -hp-3561A at each of the amplitudes listed in Table 2-4. All values of Table 2-4 are measured at frequencies of 1 kHz and 99 kHz.

**Table 2-4 Amplitude Linearity Measurement**

Amplitude	
Vrms	(dBV)
10.0 Vrms	(+ 20 dBV)
1.00 Vrms	(+ 0 dBV)
100.0 mVrms	(-20 dBV)
10.0 mVrms	(-40 dBV)
3.1623 mVrms	(-50 dBV)
1.00 mVrms	(-60 dBV)

## SPECIFICATION

The marker amplitude reading will not deviate from the actual signal amplitude by more than:


Range Setting	Accuracy
+ 23 dBV to -40 dBV	.15 dB $\pm$ .015 % of Range Setting
-41 dBV to -51 dBV	.25 dB $\pm$ .025 % of Range Setting

## REQUIRED TEST EQUIPMENT

Frequency Synthesizer ..... -hp-3325A  
AC Calibrator ..... FLUKE 5200A

## INITIAL TEST SETUP

**Figure 2-2 Amplitude Linearity Test Setup**



## PROCEDURE

1. Connect the test instruments as shown in Figure 2-2 and set the instrument controls as follows:

### Frequency Synthesizer

Function . . . . .	Square Wave
Frequency . . . . .	1 kHz
Amplitude . . . . .	1 Vrms

AC Calibrator

Frequency ..... 1 kHz  
Amplitude ..... 10 Vrms  
Phase Lock ..... ON  
Sense ..... INTERNAL  
Mode ..... OPER

-hp-3561A

PRESET  
RANGE ..... DEFINE RANGE .....10 Vrms  
FREQuency ..... DEFINE SPAN .....10 kHz  
FORMAT ..... SINGLE  
VERTical SCALE .. DEFINE dB/DIV .....20 dB  
AVeraGe ..... RMS  
                    DEFINE NUM  
                    AVGS .....10 ENTER  
INPUT ..... SINGLE CAL

- 2. When the calibration is complete, press the -hp-3561A START key to initiate a measurement.
- 3. When the average is complete, move the marker to 1 kHz and record the marker amplitude (Y:) reading on the Performance Test Record.

- 4. Set the ac calibrator controls as follows:

Amplitude ..... 1.00 Vrms

- 5. Press the -hp-3561A START key to initiate a measurement.
- 6. When the average is complete, record the marker amplitude (Y:) reading on the Performance Test Record.
- 7. Repeat steps 4 through 6, for the remaining ac calibrator amplitudes listed in Table 2-4. Record the marker amplitude (Y:) reading for each of the amplitude settings in the corresponding position of the Performance Test Record.

- 8. Set the ac calibrator controls as follows:

Frequency ..... 99 kHz  
Amplitude ..... 10 Vrms

- 9. Set the frequency synthesizer controls as follows:

Frequency ..... 99 kHz

10. Set the -hp-3561A controls as follows:

FREQUENCY ..... DEFINE SPAN ..... 100 kHz

11. Set the ac calibrator controls as follows:

Amplitude ..... 10 Vrms

12. Press the -hp-3561A START key to initiate a measurement.
13. When the average is complete, move the marker to 99 kHz, and record the marker amplitude (Y:) reading on the Performance Test Record.
14. Repeat steps 11 through 13, for the remaining ac calibrator amplitudes listed in Table 2-4. Record the marker amplitude (Y:) reading for each of the amplitude settings in the corresponding position of the Performance Test Record.

## 2-9 Noise Level/Spurious Signal Level †

This test measures the level of the noise floor and any spurious signals generated within the -hp-3561A. The input is terminated with a 50  $\Omega$  load, and the noise level or spurious signal level is read from the display marker in each of the measurements listed in Table 2-5. In all measurements both the noise level and discrete signals should be below the value given on the Performance Test Record.

**Table 2-5 Noise Level/Spurious Signal Measurement**

Start Frequency	Frequency Span	Window / Bandwidth	Noise Level
20 Hz	2 kHz	Uniform / 5.0 Hz	$\leq -131$ dBV
2 kHz	25 kHz	Uniform / 62.5 Hz	$\leq -131$ dBV
25 kHz	25 kHz	Uniform / 62.5 Hz	$\leq -131$ dBV
50 kHz	25 kHz	Uniform / 62.5 Hz	$\leq -131$ dBV
75 kHz	25 kHz	Uniform / 62.5 Hz	$\leq -131$ dBV
† 20 Hz	1 kHz	Flat Top / 9.5475 Hz	$\leq -131$ dBV
† 2 kHz	100 kHz	Flat Top / 954.75 Hz	$\leq -120$ dBV

† When performing an operational verification rather than a full performance test, complete these measurements only.

## SPECIFICATION

When the input is terminated with a 50  $\Omega$  load, the amplitude of all spurious signals will be greater than 80 dB below the range setting and the average noise level will be less than:


Frequency	Noise Level	
2 kHz to 100 kHz	$-150 \text{ dBV}/\sqrt{\text{Hz}}$	(-120 dBV for a 955 Hz Bandwidth)
20 Hz to 1 kHz	$-141 \text{ dBV}/\sqrt{\text{Hz}}$	(-131 dBV for a 9.55 Hz Bandwidth)

**REQUIRED TEST EQUIPMENT**

50  $\Omega$  Termination .....-hp-11048C

**INITIAL TEST SETUP**

**Figure 2-3 Noise Level/Spurious Signal Test Setup**



**PROCEDURE**

† 1. Connect the test instruments as shown in Figure 2-3 and set the instrument controls as follows:

-hp-3561A

PRESET	
RANGE .....	DEFINE RANGE .. -51 dBV
FORMAT .....	SINGLE
VERTical SCALE ..	DEFINE FULL SCL .. -71 dBV
FREQuency .....	DEFINE START ... 20 Hz
	DEFINE SPAN .... 2 kHz
WINDOW .....	UNIFORM
AVerage .....	RMS
	DEFINE NUM
	AVGS ..... 20 ENTER
INPUT .....	SINGLE CAL



2. When the calibration is complete, press the -hp-3561A START key to initiate a measurement.
3. When the average is complete, set the -hp-3561A controls as follows:  
MarKeR ..... MKR —> PEAK
4. Record the marker amplitude (Y:) reading on the Performance Test Record.
5. Set the -hp-3561A controls as follows:  
FREQuency ..... DEFINE SPAN .... 25 kHz  
  DEFINE START ... 2 kHz
6. Repeat steps 2 through 4.
7. Set the -hp-3561A start frequency to 25 kHz, 50 kHz, and 75 kHz. For each start frequency, repeat steps 2 through 4 to measure the peak signal level. For each measurement, record the marker amplitude (Y:) reading in the corresponding position of the Performance Test Record.
8. Set the -hp-3561A controls as follows:  
FREQuency ..... DEFINE SPAN .... 1 kHz  
  DEFINE START ... 20 Hz  
WINDOW ..... FLAT TOP
9. Repeat steps 2 through 4.
10. Set the -hp-3561A controls as follows:  
FREQuency ..... DEFINE SPAN .... 100 kHz  
  DEFINE START ... 2 kHz
11. Repeat steps 2 through 4.

## 2-10 Frequency Accuracy †

This test measures the frequency accuracy of the -hp-3561A against the frequency reference of the frequency synthesizer. Complete the entire test for both a performance test and an operational verification.

### SPECIFICATION


The frequency reading will not deviate from the actual signal frequency by more than .003 % (equivalent to  $\pm 3$  Hz at 100 kHz).

**REQUIRED TEST EQUIPMENT**

Frequency Synthesizer .....-hp-3325A  
50  $\Omega$  Termination.....-hp-11048C

**INITIAL TEST SETUP**

**Figure 2-4 Frequency Accuracy Test Setup**



**PROCEDURE**

- † 1. Connect the test instruments as shown in Figure 2-4 and set the instrument controls as follows:

Frequency Synthesizer

Frequency ..... 99.99 kHz  
Amplitude ..... 1 Vrms (0 dBV)

-hp-3561A

PRESET  
RANGE ..... DEFINE RANGE .....0 dBV  
FORMAT ..... SINGLE  
FREQuency ..... DEFINE SPAN .....100 Hz  
                                DEFINE CENTER.. 99.99 kHz  
WINDOW ..... UNIFORM  
INPUT..... SINGLE CAL

† 2. When the calibration is complete, set the -hp-3561A controls as follows:

MarKeR ..... MKR —> PEAK

† 3. Record the marker frequency (X:) reading on the Performance Test Record.

### **2-11 Input Coupling Insertion Loss**

This test measures the insertion loss at 1 Hz due to the ac coupling capacitor. The amplitude of a 1 Hz signal from the frequency synthesizer is measured in both the ac and dc coupled modes. The insertion loss is then calculated as:

dc Coupled Amplitude - ac Coupled Amplitude = Insertion Loss

### **SPECIFICATION**


The insertion loss at 1 Hz due to the ac coupling capacitor will be less than 3 dB.

### **REQUIRED TEST EQUIPMENT**

Frequency Synthesizer .....-hp-3325A  
50  $\Omega$  Termination.....-hp-11048C

## INITIAL TEST SETUP

Figure 2-5 Input Coupling Insertion Loss Test Setup



## PROCEDURE

1. Connect the test instruments as shown in Figure 2-5 and set the instrument controls as follows:

### Frequency Synthesizer

Frequency ..... 1 Hz  
 Amplitude ..... 1 Vrms (0 dBV)

### -hp-3561A

#### PRESET

FORMAT ..... SINGLE  
 RANGE ..... DEFINE RANGE .. 0 dBV  
 FREQUENCY ..... DEFINE SPAN .... 100 Hz  
 INPUT ..... SINGLE CAL

2. When the calibration is complete, move the marker to 1 Hz and set the -hp-3561A controls as follows:

RELative MarKeR . REL MKR ON  
 MKR — > REF  
 INPUT ..... COUPLE AC

3. When the measurement is complete, record the marker relative amplitude (Yr:) reading as the insertion loss value on the Performance Test Record.

## 2-12 Anti-Allas filter Response

This test measures the response of the 100 kHz low pass anti-alias filter. All measurements are made relative to the filter attenuation of a signal with a 100 kHz actual frequency. Due to internal sampling at a 256 kHz rate, signals with frequencies greater than 156 kHz may be shifted down (aliased) into the 100 kHz frequency range of the -hp-3561A. The signal frequencies listed in Table 2-6 will be shifted to the corresponding alias frequencies listed in the table.

### NOTE

*Some spurious signals due to the -hp-3325A may show up in the 0 - 100 kHz span of the -hp-3561A. Ignore signals at frequencies other than those listed in Table 2-6 when performing this test.*

**Table 2-6 Anti-Allas Filter Response Measurement**

Signal Frequency	Alias Frequency
156 kHz	100 kHz
185 kHz	71 kHz
206 kHz	50 kHz
267 kHz	11 kHz
924 kHz	100 kHz

### SPECIFICATION


All signals aliased into the 0 - 100 kHz frequency span will be attenuated to more than 80 dB below the range setting.

### REQUIRED TEST EQUIPMENT

Frequency Synthesizer .....-hp-3325A  
 50  $\Omega$  Termination.....-hp-11048C

## INITIAL TEST SETUP

**Figure 2-6 Anti-Alias Filter Test Setup**



## PROCEDURE

1. Connect the test instruments as shown in Figure 2-6 and set the instrument controls as follows:

### Frequency Synthesizer

Frequency ..... 100 kHz  
 Amplitude ..... 1 Vrms (0 dBV)

### -hp-3561A

PRESET  
 RANGE ..... DEFINE RANGE .. .....0 dBV  
 FORMAT ..... SINGLE  
 AVeraGe ..... DEFINE NUM  
                   AVGS .....20 ENTER  
                   RMS  
 INPUT..... SINGLE CAL

2. When the calibration is complete, press the -hp-3561A START key to initiate a measurement.
3. When the average is complete, move the marker to 100 kHz and set the -hp-3561A controls as follows:

RELative MarKeR . REL MKR ON  
                   DEFINE MAG REF .....MKR VALUE  
 VERTical SCALE .. DEFINE FULL SCL .....-20 dBV

4. Set the frequency synthesizer controls as follows:  
Frequency . . . . . 156 kHz
5. Press the -hp-3561A START key to initiate a measurement.
6. When the average is complete, move the marker to 100 kHz and record the marker relative amplitude (Yr:) on the Performance Test Record.
7. Repeat steps 4 through 6, setting the frequency synthesizer to each of the frequencies listed in the signal frequency column of Table 2-6. For each frequency setting, move the marker to the corresponding frequency listed in the alias frequency column of Table 2-6. Record the marker relative amplitude (Yr:) reading in the corresponding position of the Performance Test Record for each measurement.

### 2-13 A-Weight Filter Response

This test measures the filter shape of the -hp-3561A's internal A-Weight Filter. The frequency synthesizer is used to input a sine wave at each of the frequencies listed in Table 2-7. The A-Weight filter is switched into the main signal path to compensate for the frequency response of the human ear when making acoustic measurements.

**Table 2-7 A-Weight Filter Response Measurement**

Frequency	Amplitude	Tolerance
10 Hz	-70.4 dB	$\pm 4$ dB
80 Hz	-22.5 dB	$\pm 1$ dB
400 Hz	-4.8 dB	$\pm 1$ dB
1000 Hz	0 dB	$\pm 1$ dB
2500 Hz	1.3 dB	$\pm 1$ dB
5000 Hz	0.5 dB	+1, -2 dB
20000 Hz	-9.3 dB	+3, $-\infty$ dB

### SPECIFICATIONS


The A-Weight filter will conform to ANSI Standard SI.4-1971 (1976) for Type 1 A-Weight Filter.

### REQUIRED TEST EQUIPMENT

Frequency Synthesizer . . . . . -hp-3325A  
50  $\Omega$  Termination . . . . . -hp-11048C

## INITIAL TEST SETUP

**Figure 2-7 A-Weight Filter Response Test Setup**



## PROCEDURE

1. Connect the test instruments as shown in Figure 2-7 and set the instrument controls as follows:

Frequency Synthesizer

Frequency . . . . . 1 kHz  
Amplitude . . . . . 1 Vrms (0 dBV)

-hp-3561A

PRESET

RANGE . . . . . DEFINE RANGE . . . . . 5 dBV  
FORMAT . . . . . SINGLE  
FREQUENCY . . . . . DEFINE SPAN . . . . . 2 kHz  
AVerage . . . . . RMS  
                                DEFINE NUM  
                                AVGS . . . . . 4 ENTER  
INPUT . . . . . SINGLE CAL

2. When the calibration is complete, press the -hp-3561A START key to initiate a measurement.



3. When the average is complete, move the marker to 1 kHz and set the -hp-3561A controls as follows:

```

RELative MarKeR . REL MKR ON
                  DEFINE MAG REF .....MKR VALUE
INPUT..... A WT FLT ON
FREQuency ..... DEFINE SPAN .....400 Hz

```

4. Set the frequency synthesizer controls as follows:

```

Frequency ..... 10 Hz

```

5. Press the -hp-3561A START key to initiate a measurement.
6. When the average is complete, move the marker to 10 Hz and record the marker relative amplitude (Yr:) reading on the Performance Test Record.
7. Repeat steps 4 through 6, setting the frequency synthesizer and the marker to 80 Hz and 400 Hz. Record the marker relative amplitude (Yr:) reading for each frequency in the corresponding Position of the Performance Test Record
8. Set the -hp-3561A controls as follows:

```

FREQuency ..... DEFINE SPAN .....50 kHz

```

9. Repeat steps 4 through 6, setting the frequency synthesizer and the marker to each of the remaining frequencies listed in Table 2-7. Record the marker relative amplitude (Yr:) reading for each frequency in the corresponding position of the Performance Test Record.

## 2-14 Phase Accuracy †

This test measures the phase accuracy of the -hp-3561A. The frequency synthesizer is used to input a square wave to the -hp-3561A signal input and external trigger input. All phase measurements are made relative to the phase of the trigger signal.

**Table 2-8 Phase Accuracy Measurement**

	Frequency	Slope	Trigger Type
†	99 kHz	POS	INPUT
†	99 kHz	POS	EXTERNAL
	99 kHz	NEG	INPUT
	99 kHz	NEG	EXTERNAL
	9 kHz	POS	INPUT
	9 kHz	POS	EXTERNAL

† When performing an operational verification rather than a full performance test, complete these measurements only.

SPECIFICATION

The marker phase reading will not deviate from the actual phase of the signal relative to the trigger by more than:


Frequency Range	Phase Deviation
0 - 10 kHz	$\leq 2 \text{ deg}$
10 kHz - 100 kHz	$\leq 10 \text{ deg}$

REQUIRED TEST EQUIPMENT

- Frequency Synthesizer .....-hp-3325A
- 50  $\Omega$  Termination.....-hp-11048C

INITIAL TEST SETUP

Figure 2-8 Phase Accuracy Test Setup



**PROCEDURE**

- † 1. Connect the test instruments as shown in Figure 2-8 and set the instrument controls as follows:

## Frequency Synthesizer

Frequency . . . . . 99 kHz  
 Amplitude . . . . . 5 Vp-p  
 dc Offset . . . . . 2.5 Vdc  
 Function . . . . . SQUARE WAVE

## -hp-3561A

## PRESET

RANGE . . . . . DEFINE RANGE . . . . . 15 dBV  
 FORMAT . . . . . SINGLE  
 DEFINE TRACE . . . . . PHASE  
 WINDOW . . . . . UNIFORM  
 AVerage . . . . . TIME  
                                 DEFINE NUM  
                                 AVGS . . . . . 4 ENTER  
 TRIGger SElect . . . . . TRIGGER  
                                 SETUP SELECT . . . . . DEFINE % OF RNG . . . . . 10%  
   SLOPE POS  
 INPUT . . . . . SINGLE CAL

- † 2. When the calibration is complete, set the -hp-3561A controls as follows:

TRIGger SElect . . . . . INPUT TRIGGER

- † 3. Press the -hp-3561A START key to initiate a measurement.

- † 4. When the average is complete, move the marker to 99 kHz and record the marker phase (Y:) reading on the Performance Test Record.

- † 5. Set the -hp-3561A controls as follows:

TRIGger SElect . . . . . EXTERNAL  
                                 TRIGGER

- † 6. Press the -hp-3561A START key to initiate a measurement.

- † 7. When the average is complete, move the marker to 99 kHz and record the marker phase (Y:) reading on the Performance Test Record.

8. Set the -hp-3561A controls as follows:

TRIGger SElect . . . . . SETUP SELECT . . . . . SLOPE NEG

9. Repeat Steps 2 through 7.

- 10. Set the frequency synthesizer controls as follows:  
  
Frequency . . . . . 9 kHz
- 11. Set the -hp-3561A controls as follows:  
  
TRIGger SElect . . . SETUP SELECT . . .SLOPE POS
- 12. Repeat steps 2 through 7, setting the marker to 9 kHz. Record the marker phase (Y:) reading in the corresponding 9 kHz position of the Performance Test Record.

**2-15 Input Impedance**

This test measures the input impedance of the -hp-3561A as a parallel resistance (R) and capacitance (C). The digital voltmeter is used to measure the input resistance directly. The input capacitance is then measured by inputting a 100 kHz signal from the frequency synthesizer. The equations used to calculate the capacitance are given on the Performance Test Record.

**SPECIFICATION**


Input Resistance (R) = 1 MΩ ± 50 kΩ ( 5% )  
Input Capacitance (C) ≤ 95 pf

**REQUIRED TEST EQUIPMENT**

Frequency Synthesizer . . . . .-hp-3325A  
Digital Voltmeter . . . . .-hp-3455A  
100 kΩ Resistor 1% . . . . .see Figure 1-4

## INITIAL EQUIPMENT SETUP

**Figure 2-9 Input Resistance Test Setup**



## PROCEDURE

1. Connect the test instruments as shown in Figure 2-9 and set the instrument controls as follows:

Digital Voltmeter

FUNCTION ..... 2WIRE kΩ  
 RANGE ..... AUTO  
 TRIGGER ..... INTERNAL

-hp-3561A


PRESET  
 RANGE ..... DEFINE RANGE ..... 20 dBV  
 Ground Switch ... CHASSIS

2. Record the digital voltmeter reading on the Performance Test Record.
3. Set the -hp-3561A controls as follows:

RANGE ..... DEFINE RANGE ..... 0 dBV

4. Record the digital voltmeter reading on the Performance Test Record.
5. Set the -hp-3561A controls as follows:  
     RANGE ..... DEFINE RANGE ..... -13 dBV
6. Record the digital voltmeter reading on the Performance Test Record.
7. Connect the test instruments as shown in Figure 2-10.

**Figure 2-10 Input Capacitance Test Setup**



8. Set the frequency synthesizer controls as follows:  
     Frequency ..... 100 kHz  
     Amplitude ..... 1 Vrms ( 0 dBV )
9. Set the -hp-3561A controls as follows:  
     PRESET  
     RANGE ..... DEFINE RANGE ..... 1 Vrms  
     FORMAT ..... SINGLE  
     INPUT ..... SINGLE CAL
10. When the calibration is complete, move the marker to 100 kHz and record the marker amplitude (Y:) reading in the V1 position of the Performance Test Record.
11. Remove the 100 k $\Omega$  resistor from the signal path and connect the BNC cable with the 50  $\Omega$  termination directly to -hp-3561A input connector.
12. Record the marker amplitude (Y:) reading in the V2 position of the Performance Test Record.

- 13. Use the equations given on the Performance Test Record to calculate the capacitance.

**2-16 Floating Ground Capacitance**


This test measures the capacitance between the floating ground and the chassis ground when the front panel ground switch is in the FLOAT position. The equations used to calculate the capacitance are given on the Performance Test Record.

**SPECIFICATION**

The capacitance between the floating ground and the chassis ground will be less than or equal to .25  $\mu$ f.

**REQUIRED TEST EQUIPMENT**

Frequency Synthesizer .....	-hp-3325A
50 $\Omega$ Termination .....	-hp-11048C
600 $\Omega$ Termination .....	-hp-11095A

**INITIAL TEST SETUP****Figure 2-11 Floating Ground Capacitance Test Setup****PROCEDURE**

1. Connect the test instruments as shown in Figure 2-11 and set the instrument controls as follows:

**Frequency Synthesizer**

Frequency . . . . . 1 kHz  
 Amplitude . . . . . 1 Vrms (0 dBV)

**-hp-3561A****PRESET**

RANGE . . . . . DEFINE RANGE . . . . . 1 Vrms  
 FREQUENCY . . . . . DEFINE SPAN . . . . . 10 kHz  
 FORMAT . . . . . SINGLE  
 Ground Switch . . . . . CHASSIS  
 INPUT . . . . . SINGLE CAL



- 2. When the calibration is complete, move the marker to 1 kHz. Record the marker amplitude (Y:) reading in the V1 position of the Performance Test Record.
- 3. Set the -hp-3561A controls as follows:  
  
Ground Switch . . . FLOAT
- 4. Record the marker amplitude (Y:) reading in the V2 position of the Performance Test Record.
- 5. Use the equations given on the Performance Test Record to calculate the capacitance.

**2-17 Harmonic Distortion**

This test measures the harmonic distortion generated in the -hp-3561A. In the first measurement, a low noise oscillator is used to input a sinewave at a frequency of 99 kHz ÷ N (for N equal to 2, 3, 4, and 5). The amplitude of the Nth harmonic is measured at 99 kHz on the -hp-3561A display. In the second measurement, the low noise oscillator is used to input a sinewave at 1 kHz. The first five harmonics generated within the -hp-3561A are then measured on the -hp-3561A display.

**Table 2-9 Harmonic Frequencies Measurement One**

Signal Frequency	Harmonic Number	Harmonic Frequency
49500 Hz	2nd	99 kHz
33000 Hz	3rd	99 kHz
24750 Hz	4th	99 kHz
19800 Hz	5th	99 kHz

**Table 2-10 Harmonic Frequencies Measurement Two**

Signal Frequency	Harmonic Number	Harmonic Frequency
1 kHz	2nd	2 kHz
1 kHz	3rd	3 kHz
1 kHz	4th	4 kHz
1 kHz	5th	5 kHz
1 kHz	6th	6 kHz

**SPECIFICATION**


The relative amplitude of all harmonics will be greater than 80 dB below the amplitude of the fundamental.

**REQUIRED TEST EQUIPMENT**

Low Distortion Oscillator . . . . .-hp-339A  
600 Ω Termination . . . . .-hp-11095A

INITIAL TEST SETUP

Figure 2-12 Harmonic Distortion Test Setup



PROCEDURE

1. Connect the test instruments as shown in Figure 2-12 and set the instrument controls as follows:

Low Noise Oscillator

Frequency ..... 49 kHz  
Amplitude ..... 1 Vrms

-hp-3561A

PRESET  
FORMAT ..... SINGLE  
RANGE ..... DEFINE RANGE ..... 0 dBV  
FREQUENCY ..... DEFINE CENTER ..... 49.5 kHz  
                                DEFINE SPAN ..... 10 kHz  
INPUT ..... SINGLE CAL

2. When the calibration is complete, move the marker to 49.5 kHz. Adjust the low noise oscillator frequency vernier for a 49.5 kHz sine wave output. Adjust the low noise oscillator amplitude vernier for a marker amplitude reading of between -2 dBV and 0 dBV.
3. Set the -hp-3561A controls as follows:

RELative MarKeR . REL MKR ON  
                                DEFINE MAG REF ..... MKR VALUE  
FREQUENCY ..... DEFINE CENTER ..... 99 kHz  
VERTical SCALE .. DEFINE FULL SCL ..... -20 dBV  
AVerage ..... DEFINE NUM  
                                AVGS ..... 20 ENTER  
                                RMS

4. Press the -hp-3561A START key to initiate a measurement.
5. When the average is complete, move the marker to 99 kHz and record the marker relative amplitude (Yr:) reading on the Performance Test Record.
6. Set the -hp-3561A controls as follows:  
AVerage ..... OFF
7. Set the low noise oscillator controls as follows:  
Frequency ..... 32 kHz
8. Set the -hp-3561A controls as follows:  
FREQUENCY ..... DEFINE CENTER... 33 kHz  
VERTICAL SCALE .. DEFINE FULL SCL ..... 0 dBV
9. Move the marker to 33 kHz. Adjust the low noise oscillator frequency vernier for a frequency of 33 kHz.
10. Repeat steps 3 through 6.
11. Set the low noise oscillator controls as follows:  
Frequency ..... 24 kHz
12. Set the -hp-3561A controls as follows:  
FREQUENCY ..... DEFINE CENTER... 24.75 kHz  
VERTICAL SCALE .. DEFINE FULL SCL ..... 0 dBV
13. Move the marker to 24.75 kHz. Adjust the low noise oscillator frequency vernier for a frequency of 24.75 kHz.
14. Repeat steps 3 through 6.
15. Set the low noise oscillator controls as follows:  
FREQUENCY ..... 19 kHz
16. Set the -hp-3561A controls as follows:  
FREQUENCY ..... DEFINE CENTER... 19.8 kHz  
VERTICAL SCALE .. DEFINE FULL SCL ..... 0 dBV
17. Move the marker to 19.8 kHz. Adjust the low noise oscillator frequency vernier for a frequency of 19.8 kHz.
18. Repeat steps 3 through 6. 19. Set the low noise oscillator as follows:  
Frequency ..... 990 Hz
20. Set the -hp-3561A as follows:  
FREQUENCY ..... DEFINE SPAN ..... 10 kHz  
                                  DEFINE START ... 0 Hz  
VERTICAL SCALE .. DEFINE FULL SCL ..... 0 dBV

21. Move the marker to 1 kHz. Adjust the low noise oscillator frequency vernier for a frequency of 1 kHz.
22. Set the -hp-3561A controls as follows:
 

```

RELative MarKeR .  REL MKR ON
                   DEFINE MAG REF .....MKR VALUE
VERTical SCALE ..  DEFINE FULL SCL .....-20 dBV
AVeraGe .....    DEFINE NUM
                   AVGS .....20 ENTER
                   RMS
      
```
23. Press the -hp-3561A START key to initiate a measurement.
24. When the average is complete, move the marker to each of the harmonic frequencies listed in Table 2-10. Record the marker relative amplitude (Yr:) reading for each harmonic on the Performance Test Record.

## 2-18 Two-Tone Intermodulation Distortion

This test measures the level of the intermodulation distortion products generated within the -hp-3561A out to the 4th order. The outputs of the frequency synthesizer and the low noise oscillator are summed together through two 1 k $\Omega$  resistors.

**Table 2-11 Intermodulation Products Measurement One**

Fundamental Frequencies		Intermodulation Distortion	
F1	F2	Order	Frequency
25 kHz	30 kHz	F2 - F1	5 kHz
25 kHz	30 kHz	2F1 - F2	20 kHz
25 kHz	30 kHz	2F2 - 2F1	10 kHz
25 kHz	30 kHz	3F1 - 2F2	15 kHz

**Table 2-12 Intermodulation Products Measurement Two**


Fundamental Frequencies		Intermodulation Distortion	
F1	F2	Order	Frequency
95 kHz	100 kHz	F2 - F1	5 kHz
95 kHz	100 kHz	2F1 - F2	90 kHz
95 kHz	100 kHz	2F2 - 2F1	10 kHz
95 kHz	100 kHz	3F1 - 2F2	85 kHz

## SPECIFICATION

The amplitude of all intermodulation products will be greater than 80 dB below the fundamental amplitude.

**REQUIRED TEST EQUIPMENT**

Frequency Synthesizer .....	-hp-3325A
Low Noise Oscillator .....	-hp-339A
(2) 50 $\Omega$ Terminations .....	-hp-11048C
(2) 1 k $\Omega$ Series Resistors .....	see Figure 1-6

**INITIAL TEST SETUP****Figure 2-13 Intermodulation Distortion Test Setup**

**PROCEDURE**

1. Connect the test instruments as shown in Figure 2-13 and set the instrument controls as follows:

## Frequency Synthesizer

Frequency ..... 30 kHz  
 Amplitude ..... 100 mVrms (-20 dBV)

## Low Noise Oscillator

Frequency ..... 24 kHz  
 Amplitude ..... 1 V

## -hp-3561A

## PRESET

RANGE ..... DEFINE RANGE ..... -19 dBV  
 FREQuency ..... DEFINE CENTER ..... 30 kHz  
                                 DEFINE SPAN ..... 5 kHz  
 FORMAT ..... SINGLE  
 INPUT ..... SINGLE CAL

2. When the calibration is complete, move the marker to 30 kHz and set the -hp-3561A as follows:

RELative MarKeR . REL MKR ON  
                                 DEFINE MAG REF ..... MKR VALUE  
 FREQuency ..... DEFINE CENTER ..... 25 kHz

3. Adjust the low noise oscillator frequency vernier for a frequency of 25 kHz. Adjust the low noise oscillator amplitude until the marker relative amplitude (Yr:) reading is 0 dB  $\pm$  .5 dB at 25 kHz.

4. Set the -hp-3561A controls as follows:

AVerage ..... RMS  
                                 DEFINE NUM  
                                 AVGS ..... 20 ENTER  
 VERTical SCALE .. DEFINE FULL SCL ..... -40 dBV

5. Set the -hp-3561A controls as follows:

FREQuency ..... DEFINE CENTER ..... 5 kHz

6. Press the -hp-3561A START key to initiate a measurement.
7. When the average is complete, move the marker to 5 kHz. Record the marker relative amplitude (Yr:) reading on the Performance Test Record.

8. Repeat steps 5 through 7 for each of the remaining intermodulation distortion frequencies listed in Table 2-11. For each frequency record the marker relative amplitude (Yr:) reading on the corresponding position of the Performance Test Record.

9. Set the frequency synthesizer controls as follows:

Frequency . . . . . 100 kHz

10. Set the low noise oscillator controls as follows:

Frequency . . . . . 94 kHz

11. Set the -hp-3561A controls as follows:

AVerAge . . . . . OFF  
 FREQuency . . . . . DEFINE CENTER . . . . . 100 kHz  
 VERTical SCALE . . . . . DEFINE FULL SCL . . . . . -19 dBV

12. Move the marker to 100 kHz and set the -hp-3561A as follows:

RELative MarKeR . . . . . REL MKR ON  
 . . . . . DEFINE MAG REF . . . . . MKR VALUE  
 FREQuency . . . . . DEFINE CENTER . . . . . 95 kHz

13. Adjust the low noise oscillator frequency vernier for a frequency of 95 kHz. Adjust the low noise oscillator amplitude until the marker amplitude offset is 0 dB  $\pm$  .5 dB at 95 kHz.

14. Set the -hp-3561A controls as follows:

VERTical SCALE . . . . . DEFINE FULL SCL . . . . . -40 dBV  
 AVerAge . . . . . RMS  
 . . . . . DEFINE NUM  
 . . . . . AVGS . . . . . 20 ENTER

15. Set the -hp-3561A controls as follows:

FREQuency . . . . . DEFINE CENTER . . . . . 5 kHz

16. Press the -hp-3561A START key to initiate a measurement.

17. When the average is complete, move the marker to 5 kHz. Record the marker relative amplitude (Yr:) reading on the Performance Test Record.

18. Repeat steps 15 through 17 for each of the remaining intermodulation distortion frequencies listed in Table 2-12. For each frequency record the marker relative amplitude (Yr:) reading on the corresponding position of the Performance Test Record.

## 2-19 Noise Source Output Impedance

This test uses the -hp-3561A input channel to measure the output level of the noise source with and without a 50  $\Omega$  termination on the source output. From these two measurements the noise source output impedance is calculated.

### SPECIFICATION


The noise source output impedance will be 50  $\Omega \pm 5 \Omega$  (10%)

### REQUIRED TEST EQUIPMENT

50  $\Omega$  Termination .....-hp-11048C

### INITIAL TEST SETUP

Figure 2-14 Noise Source Impedance Test Setup







## 2-20 Noise Source Amplitude Accuracy/Flatness †

This test uses the -hp-3561A input channel to measure the flatness of the noise source over frequency and the RMS amplitude accuracy. The noise source level accuracy is measured using the Band Power special marker. The flatness specification is then calculated by dividing the band power reading by 20 to obtain the noise per bin on the -hp-3561A display and then multiplying by the flatness specification to obtain the acceptable deviation.

**Table 2-13 Noise Source Flatness Measurement**

Noise Source	Baseband/ Zoom	Start Frequency	Frequency Span
† Periodic	Baseband	0 Hz	100 kHz
Periodic	Baseband	0 Hz	10 kHz
Periodic	Zoom	21 kHz	10 kHz
† Random	Baseband	0 Hz	100 kHz
Random	Baseband	0 Hz	20 kHz
Random	Zoom	50 kHz	50 kHz

† When performing an operational verification rather than a full performance test, complete these measurements only.

## SPECIFICATION

### RMS Amplitude Accuracy

The maximum in-band power output into a 50  $\Omega$  termination is specified in the Amplitude Accuracy column, and the Amplitude flatness over the specified frequency span is listed in the Amplitude Flatness Column.


### NOTE

*Random source flatness can only be measured with long term averaging (16000), for shorter averages, add .4 dB  $\times$  (1000/number of averages) to the Amplitude Flatness specification. This value has already been factored into the tolerances listed on the Performance Test Record.*

**Table 2-14 Noise Source Amplitude Accuracy Specification**

Noise Source Selected	Frequency Span	Baseband/ Zoom	Amplitude Accuracy	Amplitude Flatness
Periodic	100 kHz	Baseband	0.7 Vrms $\pm$ .07 Vrms	$\pm$ 0.8 dB
Periodic	$\leq$ 50 kHz	Baseband	0.7 Vrms $\pm$ .07 Vrms	$\pm$ 0.7 dB
Periodic	all	Zoom	0.5 Vrms $\pm$ .075 Vrms	$\pm$ 1.0 dB
Random	100 kHz	Baseband	0.7 Vrms $\pm$ .14 Vrms	$\pm$ 1.6 dB
Random	$\leq$ 50 kHz	Baseband	0.7 Vrms $\pm$ .07 Vrms	$\pm$ 0.7 dB
Random	all	Zoom	0.5 Vrms $\pm$ .075 Vrms	$\pm$ 2.0 dB

Figure 2-15 Noise Source Amplitude Accuracy Test Setup



Procedure

- † 1. Connect the test instruments as shown in Figure 2-15 and set the instrument controls as follows:

-hp-3561A

PRESET	
RANGE .....	DEFINE RANGE ... 3.5 Vrms
FORMAT .....	SINGLE
WINDOW .....	UNIFORM
AVeraGe .....	DEFINE NUM
	AVGS ..... 4 ENTER
	RMS
SOURCE .....	PERIODIC NOISE
	DEFINE ATTEN ... 0 dB
SPeCiaL MarKeR ..	BAND POWER ...
	DEFINE LEFT FRQ ... 0 Hz
	DEFINE RGHT FRQ ... 100 kHz
INPUT .....	SINGLE CAL



† 11. Set up the -hp-3561A controls as follows:

VERTical SCALE .	DEFINE FULL SCL .....	3.5 Vrms
	DEFINE dB/DIV ..	10 dB
FREQuency .....	0 - 100 kHz	
SOURCE .....	RANDOM	
	DEFINE ATTEN ...	0 dB
AVeraGe .....	DEFINE NUM	
	AVGS .....	1000 ENTER
	SETUP SELECT ...	FAST DISPLAY
SPeCiaL MarKeR .	BAND POWER ...	DEFINE LEFT FRQ .. 0 Hz
		DEFINE RGHT FRQ . 100 kHz

† 12. Repeat steps 2 through 6. Record the marker readings for random noise, 100 kHz baseband.

13. Set up the -hp-3561A controls as follows:

VERTical SCALE	DEFINE FULL SCL .....	3.5 Vrms
	DEFINE dB/DIV ..	10 dB
FREQuency .....	DEFINE SPAN ....	20 kHz
SPeCiaL MarKeR .	BAND POWER ...	DEFINE LEFT FRQ .. 0 Hz
		DEFINE RGHT FRQ . 20 kHz

14. Repeat steps 2 through 6, record the marker readings for random noise, 20 kHz baseband.

15. Set up the -hp-3561A controls as follows:

VERTical SCALE .	DEFINE FULL SCL .....	3.5 Vrms
	DEFINE dB/DIV ..	10 dB
FREQuency .....	DEFINE SPAN ....	50 kHz
	DEFINE START ...	50 kHz
SPeCiaL MarKeR .	BAND POWER ...	DEFINE LEFT FRQ .. 50 kHz
		DEFINE RGHT FRQ . 100 kHz

16. Repeat steps 2 through 6. Record the marker readings for random noise, 50 kHz zoom.

† 17. Calculate the maximum and minimum noise level specifications for each measurement using the equations given under the specification column of each table.

**2-21 External Sample**

This test checks the external sample rear panel to insure TTL compatibility. The frequency synthesizer is used as an external sample input, while the internal CAL signal is viewed on the display.

**SPECIFICATION**


TTL compatible.

**REQUIRED TEST EQUIPMENT**

Frequency Synthesizer .....-hp-3325A

**INITIAL TEST SETUP**

**Figure 2-16 External Sample Test**



**PROCEDURE**

1. Connect the test instruments as shown in Figure 2-16 and set the instrument controls as follows:

## Frequency Synthesizer


Frequency ..... 128 kHz  
 Amplitude ..... 5.0 Vp-p  
 dc Offset ..... 2.5 Vdc  
 Function ..... SQUARE WAVE

-hp-3561A

## PRESET

RANGE ..... DEFINE RANGE .. -12 dBV  
 INPUT ..... CAL SIG ON  
 MODE ..... EXT SAMP ON

2. Verify that the CAL signal appears on the -hp-3561 CRT screen as shown in Figure 2-17, and that the "EXTERNAL SAMPLE TO FAST" message does not appear on the screen.

**Figure 2-17 Cal Signal In External Sample Mode**

**2-22 Internal Self Test †**

This test runs three internal circuit verification routines. Each test passes if no return codes are displayed on the -hp-3561A CRT screen when the test is complete. These tests are run only for an operational verification and do not guarantee performance to specifications.

**REQUIRED TEST EQUIPMENT**

None

**PROCEDURE**

- † 1. Set the -hp-3561A controls as follows:

```
PRESET
MODE . . . . . TEST SELECT . . . . . DEFINE TEST NUM   1 ENTER
                                START SINGLE TEST
```

- † 2. When the "TEST #1 IS COMPLETE" message is displayed, set the -hp-3561A controls as follows:

```
DEFINE TEST NUM .  14 ENTER
START SINGLE TEST
```

- † 3. When the "TEST #14 IS COMPLETE" message is displayed, set the -hp-3561A controls as follows:

```
DEFINE TEST NUM .  19 ENTER
START SINGLE TEST
```

- † 4. When the "TEST #19 IS COMPLETE" message is displayed, press PRESET to exit the test mode.



**Performance Test Record  
-hp-3561A Spectrum Analyzer**

Serial Number: \_\_\_\_\_

Test Performed by: \_\_\_\_\_

Date: \_\_\_\_\_

**dc Offset †**

Range Setting	Specification	Measured Value
		Marker Y: reading
0 dBV	≤ -30 dBV	_____dBV †
-25 dBV	≤ -55 dBV	_____dBV †
-51 dBV	≤ -71 dBV	_____dBV †

**Amplitude Accuracy/Flatness †**

Signal Frequency	Range Setting	ac Calibrator Amplitude	Specification		Measured Value
			Lower Limit dBV	Upper Limit dBV	Marker Y: reading
1 kHz	8 dBV	(2.5119 Vrms)	7.85	8.15	_____dBV †
99 kHz	8 dBV	(2.5119 Vrms)	7.85	8.15	_____dBV †
1 kHz	-11 dBV	(.28184 Vrms)	-11.15	-10.85	_____dBV †
99 kHz	-11 dBV	(.28184 Vrms)	-11.15	-10.85	_____dBV †
1 kHz	-22 dBV	(79.433 mVrms)	-22.15	-21.85	_____dBV
50 kHz	-22 dBV	(79.433 mVrms)	-22.15	-21.85	_____dBV
90 kHz	-22 dBV	(79.433 mVrms)	-22.15	-21.85	_____dBV
100 kHz	-22 dBV	(79.433 mVrms)	-22.15	-21.85	_____dBV
1 kHz	-51 dBV	(2.8184 mVrms)	-51.25	-50.75	_____dBV
1 kHz	-49 dBV	(3.5481 mVrms)	-49.25	-48.75	_____dBV
1 kHz	-47 dBV	(4.4668 mVrms)	-47.25	-46.75	_____dBV
1 kHz	-45 dBV	(5.6234 mVrms)	-45.25	-44.75	_____dBV
1 kHz	-43 dBV	(7.0795 mVrms)	-43.25	-42.75	_____dBV
1 kHz	-41 dBV	(8.9125 mVrms)	-41.25	-40.75	_____dBV
1 kHz	-39 dBV	(11.220 mVrms)	-39.15	-38.85	_____dBV
1 kHz	-29 dBV	(35.481 mVrms)	-29.15	-28.85	_____dBV
1 kHz	-27 dBV	(44.668 mVrms)	-27.15	-26.85	_____dBV
1 kHz	-25 dBV	(56.234 mVrms)	-25.15	-24.85	_____dBV

**Amplitude Linearity****Signal Frequency = 1 kHz**

Amplitude		Specification		Measured Value
Vrms	(dBV)	Upper Limit	Lower Limit	Marker Y: reading
10.0 Vrms	(+ 20 dBV)	10.17 Vrms	9.827 Vrms	_____ Vrms
1.00 Vrms	(+ 0 dBV)	1.019 Vrms	981.4 mVrms	_____ Vrms
100.0 mVrms	(-20 dBV)	103.2 mVrms	96.79 mVrms	_____ Vrms
10.0 mVrms	(-40 dBV)	11.67 mVrms	8.329 mVrms	_____ Vrms
3.1623 mVrms	(-50 dBV)	4.717 mVrms	1.608 mVrms	_____ Vrms
1.00 mVrms	(-60 dBV)	2.517 mVrms	0.000 mVrms	_____ Vrms

**Signal Frequency = 99 kHz**

Amplitude		Specification		Measured Value
Vrms	(dBV)	Upper Limit	Lower Limit	Marker Y: reading
10.0 Vrms	(+ 20 dBV)	10.17 Vrms	9.827 Vrms	_____ Vrms
1.00 Vrms	(+ 0 dBV)	1.019 Vrms	981.4 mVrms	_____ Vrms
100.0 mVrms	(-20 dBV)	103.2 mVrms	96.79 mVrms	_____ Vrms
10.0 mVrms	(-40 dBV)	11.67 mVrms	8.329 mVrms	_____ Vrms
3.1623 mVrms	(-50 dBV)	4.717 mVrms	1.608 mVrms	_____ Vrms
1.00 mVrms	(-60 dBV)	2.517 mVrms	0.000 mVrms	_____ Vrms

**Noise Level/Spurious Signal Level †**

Start Frequency	Frequency Span	Window / Bandwidth	Noise Level Specification	Measured Value
				Marker Y: reading
20 Hz	2 kHz	Uniform / 2.5 Hz	≤ -131 dBV	_____ dBV
2 kHz	25 kHz	Uniform / 62.5 Hz	≤ -131 dBV	_____ dBV
25 kHz	25 kHz	Uniform / 62.5 Hz	≤ -131 dBV	_____ dBV
50 kHz	25 kHz	Uniform / 62.5 Hz	≤ -131 dBV	_____ dBV
75 kHz	25 kHz	Uniform / 62.5 Hz	≤ -131 dBV	_____ dBV
20 Hz	1 kHz	Flat Top / 9.5475 Hz	≤ -131 dBV	_____ dBV †
2 kHz	100 kHz	Flat Top / 954.75 Hz	≤ -120 dBV	_____ dBV †

**Frequency Accuracy †**

Signal Frequency	Specification		Measured Value
	Lower limit	Upper Limit	Marker X: reading
99,990 Hz	99,987 Hz	99,993 Hz	_____ Hz †

**Input Coupling Insertion Loss**

Specification	Measured Value
	Marker Yr: reading
Insertion loss $\leq$ 3 dB	_____ dB

**Anti-Alias Filter Response**

Frequency Synthesizer Frequency	Alias Frequency	Specification	Measured Value
			Marker Yr: reading
100 kHz			_____ 0.0 dB
156 kHz	100 kHz	$\leq$ -80 dB	_____ dB
185 kHz	71 kHz	$\leq$ -80 dB	_____ dB
206 kHz	50 kHz	$\leq$ -80 dB	_____ dB
267 kHz	11 kHz	$\leq$ -80 dB	_____ dB
924 kHz	100 kHz	$\leq$ -80 dB	_____ dB

**A-Weight Filter Response**

Signal Amplitude = 0 dBV

Frequency	Amplitude	Specification		Measured Value Marker Yr: reading
		Upper Limit dBV	Lower Limit dBV	
10 Hz	-70.4 dBV	-66.4	-74.4	_____ dBV
80 Hz	-22.5 dBV	-21.5	-23.5	_____ dBV
400 Hz	-4.8 dBV	-3.8	-5.8	_____ dBV
1000 Hz	0.0 dBV	1.0	-1.0	_____ dBV
2500 Hz	1.3 dBV	2.3	0.3	_____ dBV
5000 Hz	0.5 dBV	1.5	-1.5	_____ dBV
20000 Hz	-9.3 dBV	-6.3	$-\infty$	_____ dBV

## Phase Accuracy †

Frequency	Trigger Slope	Trigger Type	Specification		Measured Value Marker Y: reading
			Lower Limit	Upper Limit	
99 kHz	POS	INPUT	-100 °	-80 °	_____ ° †
99 kHz	POS	EXTERNAL	-100 °	-80 °	_____ ° †
99 kHz	NEG	INPUT	80 °	100 °	_____ °
99 kHz	NEG	EXTERNAL	80 °	100 °	_____ °
9 kHz	POS	INPUT	-92 °	-88 °	_____ °
9 kHz	POS	EXTERNAL	-92 °	-88 °	_____ °

Input Impedance  
Resistance Measurement

Range Setting	Specification		Measured Value Digital Voltmeter reading
	Lower limit	Upper Limit	
20 dBV	950 kΩ	1050 kΩ	_____ Ω (R1)
0 dBV	950 kΩ	1050 kΩ	_____ Ω (R2)
-13 dBV	950 kΩ	1050 kΩ	_____ Ω (R3)

## Capacitance Measurement

$V1 = \text{_____} V_{rms}$ $V2 = \text{_____} V_{rms}$	
$C = \left( \frac{V2}{V1} - 1 \right) 16 \text{ pf} - 1.6 \text{ pf}$	
Specification $\leq 95 \text{ pf}$	Measured Value _____ pf

## Floating Ground Capacitance

Ground Switch	Measured Value Marker Y: reading
CHASSIS FLOAT	$V1 = \text{_____} V_{rms}$ $V2 = \text{_____} V_{rms}$
$C = \left( \frac{V2}{V1 - V2} \right) .254 \mu F$	
Specification $C \leq .25 \mu F$	Measured Value $C = \text{_____} \mu F$

**Harmonic Distortion**

Signal Frequency	Harmonic Number	Harmonic Frequency	Specification	Measured Value Marker Yr: reading
49500 Hz	2nd	99 kHz	$\leq -80$ dB	_____dB
33000 Hz	3rd	99 kHz	$\leq -80$ dB	_____dB
24750 Hz	4th	99 kHz	$\leq -80$ dB	_____dB
19800 Hz	5th	99 kHz	$\leq -80$ dB	_____dB

Signal Frequency	Harmonic Number	Harmonic Frequency	Specification	Measured Value Marker Yr: reading
1 kHz	2nd	2 kHz	$\leq -80$ dB	_____dB
1 kHz	3rd	3 kHz	$\leq -80$ dB	_____dB
1 kHz	4th	4 kHz	$\leq -80$ dB	_____dB
1 kHz	5th	5 kHz	$\leq -80$ dB	_____dB
1 kHz	6th	6 kHz	$\leq -80$ dB	_____dB

**Two-Tone Intermodulation Distortion**

Fundamental Frequencies F1 F2	Intermodulation Distortion		Specification	Measured Value
	Order	Frequency		Marker Yr: reading
25 kHz 30 kHz	F2 - F1	5 kHz	$\leq -80$ dB	_____dB
25 kHz 30 kHz	2F1 - F2	20 kHz	$\leq -80$ dB	_____dB
25 kHz 30 kHz	2F2 - 2F1	10 kHz	$\leq -80$ dB	_____dB
25 kHz 30 kHz	3F1 - 2F2	15 kHz	$\leq -80$ dB	_____dB

Fundamental Frequencies F1 F2	Intermodulation Distortion		Specification	Measured Value
	Order	Frequency		Marker Yr: reading
95 kHz 100 kHz	F2 - F1	5 kHz	$\leq -80$ dB	_____dB
95 kHz 100 kHz	2F1 - F2	90 kHz	$\leq -80$ dB	_____dB
95 kHz 100 kHz	2F2 - 2F1	10 kHz	$\leq -80$ dB	_____dB
95 kHz 100 kHz	3F1 - 2F2	85 kHz	$\leq -80$ dB	_____dB

**Noise Source Output Impedance**

50 $\Omega$ Termination	Measured Value
	Marker Y: reading
Connected Disconnected	V1 = _____Vrms
	V2 = _____Vrms
Measured Resistance = 50 $\Omega$ ( $\frac{V2 - V1}{V1}$ )	
Specification	Measured Value
50 $\Omega \pm 5 \Omega$	_____ $\Omega$

**Source Amplitude Accuracy/Flatness +  
Noise Source Amplitude Accuracy**

Noise Source Selected	Frequency Span	Baseband/ Zoom	Specification Level Accuracy		Measured Value
			Upper Limit	Lower Limit	Band Power(BND): Marker Reading
Periodic	100 kHz	Baseband	770 mVrms	630 mVrms	_____mVrms†
Periodic	20 kHz	Baseband	770 mVrms	630 mVrms	_____mVrms
Periodic	10 kHz	Zoom	575 mVrms	425 mVrms	_____mVrms
Random	100 kHz	Baseband	840 mVrms	560 mVrms	_____mVrms†
Random	20 kHz	Baseband	770 mVrms	630 mVrms	_____mVrms
Random	50 kHz	Zoom	575 mVrms	425 mVrms	_____mVrms

**Noise Source Flatness: Maximum Noise Level**

The maximum noise level specification for each noise source/frequency span combination is calculated from the band power marker value as shown in the equation below. Division by 20 in this equation converts band power to power per bin.

$$\text{Specification} = \text{Band Power Value} \times (1 + \text{percent tolerance})/20$$

Noise Source Selected	Frequency Span	Baseband/ Zoom	Specification Maximum Noise Level		Measured Value Marker Y: reading
			Band Power (BND): Marker Value	Calculated Value	
Periodic	100 kHz	Baseband	_____mVrms $\times (1.096/20) =$	_____mVrms	_____mVrms†
Periodic	20 kHz	Baseband	_____mVrms $\times (1.084/20) =$	_____mVrms	_____mVrms
Periodic	10 kHz	Zoom	_____mVrms $\times (1.259/20) =$	_____mVrms	_____mVrms
Random	100 kHz	Baseband	_____mVrms $\times (1.259/20) =$	_____mVrms	_____mVrms†
Random	20 kHz	Baseband	_____mVrms $\times (1.135/20) =$	_____mVrms	_____mVrms
Random	50 kHz	Zoom	_____mVrms $\times (1.318/20) =$	_____mVrms	_____mVrms

**Noise Source Flatness: Minimum Noise Level**

The minimum noise level specification for each noise source/frequency span combination is calculated from the band power marker value as shown in the equation below. Division by 20 in this equation converts band power to power per bin.

$$\text{Specification} = \text{Band Power Value} \times (1 - \text{percent tolerance})/20$$

Noise Source Selected	Frequency Span	Baseband/ Zoom	Specification Minimum Noise Level		Measured Value  Marker Yr: reading
			Band Power(BND:) Marker Value	Calculated Value	
Periodic	100 kHz	Baseband	_____mVrms $\times (.9120/20) =$	_____mVrms	_____mVrms†
Periodic	20 kHz	Baseband	_____mVrms $\times (.9226/20) =$	_____mVrms	_____mVrms
Periodic	10 kHz	Zoom	_____mVrms $\times (.7943/20) =$	_____mVrms	_____mVrms
Random	100 kHz	Baseband	_____mVrms $\times (.7943/20) =$	_____mVrms	_____mVrms†
Random	20 kHz	Baseband	_____mVrms $\times (.8810/20) =$	_____mVrms	_____mVrms†
Random	50 kHz	Zoom	_____mVrms $\times (.7586/20) =$	_____mVrms	_____mVrms†

**SECTION III**  
**ADJUSTMENTS**

---



<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
3-1	INTRODUCTION .....	3-1
3-2	SAFETY CONSIDERATIONS .....	3-1
3-3	EQUIPMENT REQUIRED .....	3-2
3-4	ADJUSTMENT LOCATIONS .....	3-2
3-5	ADJUSTMENT SUMMARY .....	3-2
3-6	A71 POWER SUPPLY LOW LINE DETECT ADJUSTMENT PROCEDURE ....	3-3
3-7	A90 CRT DISPLAY ADJUSTMENT PROCEDURE .....	3-4
3-8	A40 REFERENCE OSCILLATOR ADJUSTMENT PROCEDURE .....	3-8
3-9	A15 DIGITIZER ASSEMBLY ADJUSTMENT PROCEDURE .....	3-10
3-10	A10 INPUT ASSEMBLY ADJUSTMENT PROCEDURE .....	3-16
3-11	A50 NOISE SOURCE ADJUSTMENT PROCEDURE .....	3-22

## SECTION III ADJUSTMENTS

---

### 3-1 INTRODUCTION

This section describes the adjustments which will return the -hp-3561A to specified operating accuracy after repairs are completed or for periodic maintenance. Before adjustments are made, the -hp-3561A must have a 15 minute warm-up and the line voltage should be  $\pm 5\%$ -10% of nominal. The adjustment procedures are listed in the order in which they should be performed. This order must be followed since certain adjustment results are measured by the -hp-3561A itself.

### 3-2 SAFETY CONSIDERATIONS

Although the -hp-3561A has been designed in accordance with international safety standards, this manual contains information, cautions, and warnings which must be followed to ensure safe operation and to keep the unit in safe condition. Service and adjustments should be performed only by qualified personnel who are aware of the hazards involved.

#### WARNING

*Any interruption of the protective (grounding) conductor inside or outside the unit, or disconnection of the protective earth terminal is likely to make the unit hazardous. Capacitors inside the -hp-3561A may still be charged even though the -hp-3561A has been removed from the mains supply.*

*Only fuses with the required rated current and specified type should be used for replacement. The use of repaired fuses and short circuiting of fuse holders is not permitted. Whenever it is likely that the protection offered by the fuse has been impaired, the -hp-3561A must be made inoperative and secured against any unintended operation.*

*Adjustments described in this section are performed with the protective covers removed and the power applied. Energy available at many points can, if contacted, result in serious personal injury.*

### 3-3 EQUIPMENT REQUIRED

The test equipment required to adjust the -hp-3561A is listed in Table 1-5, Recommended Test Equipment. The test equipment needed for the adjustment of each particular assembly is also listed at the beginning of the adjustment procedure for that assembly. If the recommended equipment is not available, a substitute which meets or exceeds the "Required Characteristics" given in Table 1-5 may be used.

### 3-4 ADJUSTMENT LOCATIONS

As an adjustment aid, locators for each assembly are given at the beginning of each of the assembly adjustment procedures. These locators are simplified illustrations of the assembly showing the location of the test points and adjustable components.

### 3-5 ADJUSTMENT SUMMARY



*The -hp-3561A contains components which may be damaged as a result of static discharge. Remove circuit assemblies only at a static protected workstation.*

The adjustments are listed in the order in which they should be performed. Any deviation from this order is not recommended. However, after an assembly repair, it is only necessary to adjust the repaired assembly.

Refer to Table 3-1 for the list of the adjustments. If any of the adjustment results are unattainable, refer to the troubleshooting section for that assembly.

**Table 3-1 -hp-3561A List of Adjustments**

Paragraph Number	Test Name
3-6	A71 Power Supply Low Line Detect Adjustment
3-7	A90 CRT Display Adjustment
3-8	A40 Reference Oscillator Adjustment
3-9	A15 Digitizer Assembly Adjustment
3-10	A10 Input Assembly Adjustment
3-11	A50 Local Oscillator/Noise Source Adjustment

### 3-6 A71 Power Supply Low Line Detect Adjustment Procedure

This adjustment sets the Low-Line sense trip point.


#### EQUIPMENT NEEDED

Variable ac Source

#### SETUP PROCEDURE

1. With the power removed, remove the top cover of the -hp-3561A.
2. Remove PC cover plate (cover plate behind the CRT) over the power supply assemblies by removing the four screws in the plate's corners.
3. Set the -hp-3561A input voltage selection switches located on the bottom side of the motherboard to the 100V position as shown in Figure 3-1.

Figure 3-1 100V Input Voltage Selection Switch Setting




#### ADJUSTMENT PROCEDURE

1. Set the variable ac source to  $100V \pm 4V$  and turn on the -hp-3561A.
2. Adjust A71R1 fully CCW. (See Figure 3-2)
3. Adjust the variable ac source down to  $82V \pm 1V$ .
4. Adjust A71R1 slowly CW just to the point where the -hp-3561A goes into its power-up reset routine.
5. Turn the power off and reset the -hp-3561A line voltage switches to the proper position.

This completes the A71 Power Supply adjustment.

Figure 3-2 A71R1 Adjustment Location




3-7 A90 CRT Display Adjustment Procedure

EQUIPMENT NEEDED

- Digital Voltmeter .....-hp-3455A
- High Voltage Probe .....-hp-10014A (10M $\Omega$  impedance 10:1)
- Plastic 0.1in hex .....-hp- 8710-1388
- Adjustment Tool

Figure 3-3 A90 Adjustment and TP locations



**ADJUSTMENT PROCEDURE****NOTE**


Refer to Figure 3-3 for adjustment and test point locations.

**WARNING**

*The following adjustments expose hazardous voltages!*


1. With the power cord removed from the instrument, remove the top cover of the -hp-3561A by turning the four screws on the top cover one-quarter turn CCW. Also remove the long aluminum PC cover located on the right side of the instrument opposite the CRT.
2. Apply power to the -hp-3561A and move the A60J100 jumper from the Normal position to the FB (Full Bright) position as shown in the diagram in Figure 3-4. The CRT should now display a bright checkerboard pattern.

**Figure 3-4 A60J100 Jumper Position**



3. Adjust A90R200 "G1" until the CRT pattern is no longer visible.
4. Connect the HV Probe ground clip to A90 TP "GND" located directly above A90U1.
5. Using the HV Probe, measure the voltage at TP300 (or J300(10)). Adjust A90R300 "BRIGHT" for a reading of 400Vdc  $\pm$  10V.
6. Readjust A90R200 "G1" fully CW and then CCW until the background raster just disappears. The checkerboard pattern should now be at its brightest level without "blooming" or fuzz at the edges.
7. Adjust A90R201 "FOCUS" for the best overall screen focus.
8. Move the A60J100 jumper back to the normal position (see Figure 3-4) and then press the front panel PRESET key.
9. Adjust A99L101 "VERTICAL SIZE" to align the soft key separator lines as shown in Figure 3-5. (Note: A99L101 is located on the A99 Assembly next to the flyback transformer.)

**Figure 3-5 A99L101 Adjustment Reference (soft key separator alignment)**




10. Place the -hp-3561A in test mode 50 by pressing the following keys:

MODE ..... TEST SELECT ..... 50 ENTER  
 START SNGL TST

The CRT should now show the display alignment pattern shown in Figure 3-6.

11. Adjust A90R2 "WIDTH" until the width of the alignment pattern is approximately 3.8 inches (97mm). Refer to Figure 3-6 for the alignment example.

**Figure 3-6 Display Alignment Pattern**



12. Adjust A90R1 "LEFT EDGE" to center the alignment pattern in the CRTK display. Refer to Figure 3-6 for the alignment example.
13. Press the soft key STOP TEST.
14. Press the front panel PRESET key.
15. Adjust A90R100 "HALF BRIGHT" for a comfortable viewing contrast between half bright and full bright characters on the display.
16. Readjust A90R201 "FOCUS" if necessary.
17. Repeat steps 7 through 16 to "fine tune" the display alignment.  
 This completes the adjustments for the CRT display.





### 3-8 A40 Reference Oscillator Adjustment Procedure

This adjustment sets the frequency of the -hp-3561A's reference oscillator.

## EQUIPMENT NEEDED

Frequency Synthesizer .....-hp-3325A

### Figure 3-7 A40 Adjustment Locator




**ADJUSTMENT PROCEDURE**

1. Set the frequency synthesizer to 99 kHz at an amplitude of 1Vrms.
2. Connect the output of the frequency synthesizer to the front panel input of the -hp-3561A.
3. Press the following -hp-3561A front panel keys:  


```

FORMAT ..... SINGLE
FREQUENCY ..... DEFINE CENTER... 99 kHz
                        DEFINE SPAN ..... 5 kHz
WINDOW ..... UNIFORM

```
4. A measurement will be made and displayed on the CRT.
5. Adjust A40C201 for minimum skirt width as shown in Figure 3-8.

**Figure 3-8 Correctly and Incorrectly Adjusted A40C201**


A40C201  
Correctly Adjusted  
for a minimum  
width skirt



A40C201  
Incorrectly  
Adjusted

### 3-9 A15 Digitizer Assembly Adjustment Procedure


Figure 3-9 Digitizer Adjustment Setup



The A15 adjustment procedure assumes all the -hp-3561A assemblies are installed and functional. To perform the adjustments, the top cover of the -hp-3561A must be removed. The long cover plate over the PC assemblies in the right side of the instrument (opposite the CRT) must also be removed by unscrewing the four pan-head screws (two on each end of the plate).

**EQUIPMENT NEEDED**

Oscilloscope .....	-hp-1980A
Frequency Synthesizer .....	-hp-3325A
50Ω Feedthrough .....	-hp-11048C

**Figure 3-10 A15 Adjustment Locator**

**SECOND GAIN ADJUSTMENT**

Refer to the test setup shown in Figure 3-9 and follow the directions below.

1. Connect the "SYNC OUT" of the frequency synthesizer to the "MAIN TRIG IN" input of the oscilloscope and set the oscilloscope to the External Trigger mode.
2. Remove the coax cable (W15) from A15J1.
3. Connect the SIGNAL output of the frequency synthesizer to A15J1 using the adapter cable -hp- PN 03585-61616 and a 50 $\Omega$  load.
4. Set the frequency synthesizer output waveform to triangle with a frequency of 200 Hz and an amplitude of 10mVrms.
5. Program the -hp-3561A for an input RANGE of 0 dBV and the AUTO-RANGE function to OFF.
6. Place the -hp-3561A into test mode 114 by pressing the following keys in the following order:


```
MODE ..... TEST SELECT.....114 ENTER
                        START SNGL TST
```

The display of the -hp-3561A should indicate that test 114 is complete. At this time, the -hp-3561A is programmed properly and the rest of the adjustment may be performed. If the display does not indicate that test 114 is complete, repeat step 6.


7. Set the oscilloscope sensitivity to 5.0mV/Div. and the time base to 1.0mS/Div.
8. Connect the oscilloscope probe to A15 TP "2ND GAIN" which is located next to resistor R105. Connect the probe ground clip to the A15 "I GND" TP which is located in the upper-right corner of the A15 assembly next to regulator U201. Refer to Figure 3-10 for TP and adjustment locations.
9. Adjust A15R115 2ND GAIN for a flat waveform on the oscilloscope as seen in the left photo of Figure 3-11.

**Figure 3-11 Correctly and Incorrectly Adjusted R115**

Correctly adjusted R115



Incorrectly adjusted R115



Probe: 10:1  
 Ch1: Connection - A15 TP "2ND GAIN"  
 Coupling - dc  
 Ground - Center Graticule

Trigger: Internal - Ch1  
 Slope - Positive

Bandwidth Limit: OFF

### FIRST PASS ADJUSTMENT PROCEDURE


Use the test equipment interconnect setup as shown in Figure 3-9 and follow steps 1 and 2 of the Second Gain Adjustment procedure when connecting the equipment.

1. Set the frequency synthesizer output waveform to triangle with a frequency of 200 Hz and an amplitude of 200mVrms.
2. Connect the oscilloscope probe to A15 TP"ADC IN" located below IC U204. Connect the ground clip to the A15 "I GND" TP located in the upper-right corner of the A15 assembly near regulator U201.
3. Program the -hp-3561A for an input RANGE of 0dBV with the Auto-Range function to OFF.
4. Program the -hp-3561A for the INPUT AUTO-CAL off.
5. Place the 3561A into Test Mode 111 by pressing the following keys in the following order:

MODE ..... TEST SELECT ..... 111 ENTER  
 START SNGL TST


6. Set the oscilloscope sensitivity to 10mV/Div and the time base to 1.0mS/Div.
7. Adjust R201 "REF" for a flat response as shown in the left photo of Figure 3-12.

**Figure 3-12 Correctly and Incorrectly Adjusted R201 "REF"**



8. Adjust R200 "FP ZERO" to center the flat response waveform within the triangle wave as shown in the left photo of Figure 3-13.

**Figure 3-13 Correctly and Incorrectly Adjusted R200**




## DC OFFSET ADJUSTMENT

The DC Offset Adjustment does not require the use of any test equipment. Adjustment is made using the -hp-3561A CRT in the PRESET state.

1. Remove the coax cable (W15) from A15J1.  
Short A15J1 using a test lead or shorting connector.
2. Press the PRESET key on the front panel of the -hp-3561A.
3. Press the following keys on the -hp-3561A front panel:  
  
FORMAT ..... SINGLE
4. Adjust A15 R202 for a minimum peak at the dc (left-most) point of the -hp-3561A CRT display. Refer to the left waveform in Figure 3-14 for the properly adjusted response.
5. Remove the short from A15J1 and replace the coax cable coming from the A10 Assembly.


**Figure 3-14 A15 R202 DC Offset Adjustment**

Correctly adjusted R202



Minimum DC response

Incorrectly adjusted R202



DC response out of adjustment





### 3-10 A10 Input Assembly Adjustment Procedure

There are five adjustments on the A10 Input Assembly: Zero, Amplitude, 20dB Attenuator flatness, 40dB Attenuator flatness and A-Weight Filter.

#### EQUIPMENT NEEDED

AC Calibrator .....	Fluke 5200A
Frequency Synthesizer .....	-hp- 3325A
Extender Board .....	-hp- 03561-66595
Adjustment Tool 0.1in hex .....	-hp- 8710-1388
BNC to J cable adapter .....	-hp- 03585-61616

Figure 3-15 A10 Assembly Adjustment Locations




**SETUP PROCEDURE**

1. With the power cord removed from the instrument, remove the top and bottom covers from the -hp-3561A by turning the four screws of each cover CCW.
2. Carefully remove the input cable coming in at the lower left of the A10 Input Assembly by pulling it straight out toward the front of the instrument.
3. Remove the A10 assembly and reinsert into the instrument on an extender board.
4. Connect the BNC to J cable to A10J300 (located in the lower-left corner of the A10 assembly).

**ZERO ADJUSTMENT PROCEDURE**

This adjustment does not require the use of external equipment.

1. Disconnect any signal going into the A10 assembly.
2. Move the A10W100 jumper from the N (normal) position to the T (test) position. This jumper is located in the top center of the A10 assembly. (Refer to Figure 3-15)
3. Press the -hp-3561A PRESET key. The CRT will show both a MAG and TIME display. The 0Hz (dc) portion of the MAG display should be greater than 35dB down from full scale as shown in the left diagram of Figure 3-16.
4. Adjust A10R9 "ZERO" for the minimum response at 0 Hz (dc).
5. Move the Jumper A10W100 back to the N position.

**Figure 3-16 Response Of A10 ZERO Adjustment****AMPLITUDE ADJUSTMENT PROCEDURE**

1. Connect the frequency synthesizer signal output to the Fluke 5200A PHASE LOCK (located on the rear panel).
2. Connect the Fluke 5200A front panel output to the BNC adapter cable going to A10J300.
3. Set the output of the synthesizer to 1 kHz at 2.0Vrms.
4. Set the Fluke 5200A AC Calibrator front panel controls as follows:

VOLTAGE RANGE .....1.0V  
 VOLTAGE ERROR .....OFF  
 FREQUENCY RANGE .....10k  
 VOLTAGE .....200mV  
 FREQUENCY .....1.000kHz  
 CONTROL .....LOCAL  
 PHASE LOCK .....ON  
 SENSE .....INT  
 MODE .....OPERate

- Press the following front panel keys:

```

PRESET
MODE ..... TEST SELECT.....52 ENTER
                START CONT TST

```

The CRT will display the instructions to input a sinewave signal of 1 kHz at 200mVrms.

- Input the 1 kHz signal to the A10 assembly and press the menu key "CONTINUE".  
The CRT will display "Calibration deviation = value" where value is the numerical amount of error in the amplitude adjustment.
- Adjust A10R500 "CAL" until the value of the error is equal to  $0.00 \pm .05$ .  
When the adjustment is finished, press the menu key STOP TEST.

### 20dB ATTENUATOR FLATNESS ADJUSTMENT PROCEDURE

This adjustment does not require the use of external equipment.

- Press the following keys on the -hp-3561A front panel:

```

PRESET
MODE ..... TEST SELECT.....53 ENTER
                START CONT TST

```

The -hp-3561A CRT should display "TEST # 53 IN PROGRESS" and "Calibration deviation = value" where value is the numerical amount of error in the adjustment of the 20dB attenuator circuit.

- Adjust A10C303 until the value of the error is equal to  $0.00 \pm .05$ .  
When the adjustment is finished, press the menu key STOP TEST.

### 40dB ATTENUATOR FLATNESS ADJUSTMENT PROCEDURE

This adjustment procedure does not require the use of external equipment.

- Press the following keys on the -hp-3561A front panel:

```

PRESET
MODE ..... TEST SELECT.....54 ENTER
                START CONT TST

```

The -hp-3561A CRT should display "TEST # 54 IN PROGRESS" and "Calibration deviation = value" where value is the numerical amount of error in the adjustment of the 40dB attenuator circuit.

2. Adjust A10C300 until the value of the error is equal to  $0.00 \pm .05$ .  
When the adjustment is finished, press the menu key STOP TEST.

## A-WEIGHT FILTER ADJUSTMENT PROCEDURE

### EQUIPMENT NEEDED

Frequency Synthesizer .....-hp-3325A

### ADJUSTMENT PROCEDURE

1. Press the following keys on the -hp-3561A front panel:

```
PRESET
INPUT.....  A WT FLT
                ON OFF
```

This should turn the A-Weight Filter on.

2. Connect a  $50\Omega$  load to the A10 input cable and adjust A10R201 for a minimum 0Hz response as shown in the left diagram of Figure 3-16.
3. Connect the frequency synthesizer to the input cable of the A10 Assembly and set as follows:


```
FREQUENCY .....2.5 kHz
FUNCTION.....SINE
AMPLITUDE .....1.0Vrms
```

4. Press the following keys on the -hp-3561A front panel:

```
PRESET
MKR .....  DEFINE MKR POS .....2.5 kHz
INPUT.....  A WT FLT
                ON OFF
```

The -hp-3561A should now be making baseband measurements of the 2.5 kHz input signal with the Y-MARKER and the A-Weight Filter turned on.

5. Adjust A10R202 "GAIN" for a Y-MARKER reading of  $+1.3\text{dBV} \pm .02\text{dB}$  as indicated by the left diagram in Figure 3-17.

**Figure 3-17 Response Of A10 A-Weight Filter Adjustment**


Y-MARKER properly  
adjusted to +1.30 dBV

### 3-11 A50 Local Oscillator/Noise Source Adjustment Procedure

This adjustment does not require the use of external equipment.

#### SETUP PROCEDURE

Connect the -hp-3561A rear panel noise source output to the front panel input BNC using a 50 $\Omega$  load.



**ADJUSTMENT PROCEDURE**

1. Press the following -hp-3561A front panel keys:

PRESET

WINDOW ..... UNIFORM


FREQuency ..... DEFINE SPAN ..... 25 kHz

MarKeR ..... DEFINE MKR POS ..... 12.5 kHz

SOURCE ..... PERIODIC NOISE  
 DEFINE ATTN .... 0 dB

2. Adjust A50R400 until the Y-MARKER reads -28.9dBV  $\pm$  .04dBV as shown in Figure 3-19.

**Figure 3-19 A50R400 Adjustment Reference**



Y-MARKER properly  
 adjusted to -28.90 dBV



**SECTION IV**  
**REPLACEABLE PARTS**

---

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
4-1	INTRODUCTION .....	4-1
4-2	STANDARD ABBREVIATIONS .....	4-1
4-3	ORDERING INFORMATION .....	4-2
4-4	MANUFACTURER'S CODE LIST .....	4-2
4-5	REPLACEABLE PARTS LIST .....	4-2
4-6	DIRECT MAIL ORDER SYSTEM .....	4-4

## SECTION IV REPLACEABLE PARTS

### 4-1 INTRODUCTION

This section of the manual contains information for ordering replaceable parts for the -hp-3561A. Table 4-1 lists standard abbreviations used in the parts list. Table 4-2 is a listing of all the replaceable parts in order of reference designator. Table 4-3 lists the names and addresses which correspond to the manufacturer's code numbers.

### 4-2 STANDARD ABBREVIATIONS

The standard abbreviations used in the parts list and throughout the manual are listed in Table 4-1. In some cases, two forms of an abbreviation are used, one in all CAPITAL letters and one in partial or no capital letters. Abbreviations in the parts list are given in all capital letters, on the schematics and in other parts of the manual abbreviations may be given in either lower case or capital letters.

**Table 4-1 Reference Designations and Abbreviations**

ABBREVIATIONS			
Ag	silver	Hz	hertz (cycle(s) per second)
Al	aluminum		
A	ampere(s)	IO	inside diameter
Au	gold	imp	impregnated
		incd	incandescent
C	capacitor	ins	insulation(s)
cer	ceramic		
coef	coefficient	kΩ	kiloohm(s) = 10 <sup>3</sup> ohms
com	common	kHz	kiloherzt = 10 <sup>3</sup> hertz
comp	composition		
conn	connection	L	inductor
		lin	linear taper
dap	deposited	log	logarithmic taper
OPDT	double-pole double throw	mA	milliampere(s) = 10 <sup>-3</sup> ampere(s)
OPST	double-pole single throw	MHz	megahertz = 10 <sup>6</sup> hertz
elect	electrolytic	MΩ	megaohm(s) = 10 <sup>6</sup> ohms
encap	encapsulated	mat film	metal film
		mfr	manufacturer
F	farad(s)	ms	millisecond
FET	field effect transistor	mtg	mounting
fxd	fixed	mV	millivolt(s) = 10 <sup>-3</sup> volts
		μF	microfarad(s)
GaAs	gallium arsenide	μs	microsecond(s)
GHz	gigahertz = 10 <sup>9</sup> hertz	μV	microvolt(s) = 10 <sup>-6</sup> volts
gd	guarded	my	Mylar®
Ge	germanium		
gnd	grounded	nA	nanoampere(s) = 10 <sup>-9</sup> ampere(s)
H	henry(ies)	NC	normally closed
		Ne	neon
Hg	mercury	NO	normally open
		NPO	negative positive zero (zero temperature coefficient)
		ns	nanosecond(s) = 10 <sup>-9</sup> seconds
		nsr	not separately replaceable
		Ω	ohm(s)
		obd	order by description
		OD	outside diameter
		p	peak
		pA	picoampere(s)
		pc	printed circuit
		pF	picofarad(s) 10 <sup>-12</sup> farads
		prv	peak inverse voltage
		p/o	part of
		pos	positron(s)
		poly	polystyrene
		pot	potentiometer
		p p	peak-to-peak
		ppm	parts per million
		prec	precision (temperature coefficient, long term stability and/or tolerance)
		R	resistor
		Rh	rhodium
		rms	root-mean-square
		rot	rotary
		Sa	selenium
		sect	sectorial
		Sr	silicon
		sl	slide
		SPOT	single-pole double-throw
		SPST	single-pole single-throw
		Ta	tantalum
		TC	temperature coefficient
		TiO <sub>2</sub>	titanium dioxide
		tog	toggle
		tol	tolerance
		trim	trimmer
		TSTR	transistor
		V	volt(s)
		vacw	alternating current working voltage
		var	variable
		wdcw	direct current working voltage
		W	watt(s)
		w/.	with
		wiv	working inverse voltage
		w/o	without
		ww	wirewound
		*	optimum value selected at factory.
		**	average value shown (part may be omitted)
			no standard type number assigned
			selected or special type
			® Dupont de Nemours
DESIGNATORS			
A	assembly	FL	filter
B	motor	HR	heater
BT	battery	IC	integrated circuit
C	capacitor	J	jack
CR	diode or thyristor	K	relay
DL	delay line	L	inductor
DS	lamp	M	meter
E	misc electronic part	MP	mechanical part
F	fuse	P	plug
		Q	transistor
		QCR	transistor-diode
		R(p)	resistor(pack)
		RT	thermistor
		S	switch
		T	transformer
		TB	terminal board
		TC	thermocouple
		TP	test point
		TS	terminal strip
		U	microcircuit
		V	vacuum tube, neon bulb, photocell, etc.
		W	wire
		X	socket
		XDS	terminal board
		XF	fuseholder
		Y	crystal
		Z	network

### 4-3 ORDERING INFORMATION

To order a part listed in Table 4-3, quote the Hewlett-Packard part number (with the check digit) and indicate the quantity required. To order a part not listed in Table 4-3, include the instrument Model Number (-hp-3561A), the instrument serial number, a description and function of the part, and the quantity of the part required. Address the order to the nearest Hewlett-Packard office (office locations are listed at the back of this manual).

### 4-4 MANUFACTURER'S CODE LIST

The information given in the parts list includes the manufacturer's code and part number. Table 4-2 contains the names and addresses which correspond with the manufacturer's code number.

**Table 4-2 Manufacturer's Code List**

Mfr No.	Manufacturer Name	Address
01121	Allen-Bradley Co	Milwaukee WI 53204
01295	Texas Instr Inc Semicond Cmpnt Div	Dallas TX 75222
01928	RCA Corp Solid State Div	Somerville NJ 08876
03888	KDI Pyrofilm Corp	Whippany NJ 07981
04713	Motorola Semiconductor Products	Phoenix AZ 85062
07263	Fairchild Semiconductor Div	Mountain View CA 94042
13606	Sprague Elect Co Semiconductor Div	Concord NH 03301
17856	Siliconix Inc	Santa Clara CA 95054
18324	Signetics Corp	Sunnyvale CA 94086
19701	Mepco/Electra Corp	Mineral Wells TX 76067
20932	Emcon Div Itw	San Diego CA 92129
24546	Corning Glass Works (Bradford)	Bradford PA 16701
27014	National Semiconductor Corp	Santa Clara CA 95051
28480	Hewlett-Packard Co Corporate Hq	Palo Alto CA 94304
51642	Centre Engineering Inc	State College PA 16801
56289	Sprague Electric Co	North Adams MA 02147
72136	Electro Motive Corp Sub IEC	Willimantic CT 06226
80103	Lambda Electronics Corp	Melville NY 11746

### 4-5 REPLACEABLE PARTS LIST

Table 4-3 is the list of replaceable parts in the -hp-3561A and is organized as follows:

- Electrical assemblies and their components are listed in numerical order.
- Chassis-mounted parts are listed in order of their reference designation.
- Miscellaneous parts.

The parts list contains seven columns. The descriptions for these columns are given below:

**Column 1: Reference Designation**

This is the reference designation of the part. It is a two part number. The first part identifies the assembly on which the component is located. The second part identifies the component type and location as it is mounted on the PC assembly. For example: component A10R101 is on the A10 Assembly, it is a resistor, and it is the upper-left resistor located in quadrant 100.

**Column 2: HP Part Number**

This is the Hewlett-Packard part number for the component.

**Column 3: CD**

This is the Check Digit for the Hewlett-Packard part number. It is an internal number used by Hewlett-Packard to verify the validity of the part number.

**Column 4: Qty**

This is the total quantity of that part used on the assembly. The total quantity for each part is given only once per assembly at the first appearance of the part number in the assembly parts list.

**Column 5: Description**

This is a description of the part sometimes including color, power rating, value, etc.

**Column 6: Mfr Code**

This is a Hewlett-Packard internal code number assigned to the various manufacturing vendors. Table 4-3 lists the name and address of the manufacturers along with their Mfr. Code number.

**Column 7: Mfr Part Number**

This is the part number assigned to the part by the manufacturer.

**4-6 DIRECT MAIL ORDER SYSTEM**

Within the USA, Hewlett-Packard can supply parts through a direct mail order system. Advantages of using the system are:

- a. Direct ordering and shipment from the HP Parts Center in Mountain View, California.
- b. No maximum or minimum on any mail order (there is a minimum order amount for parts ordered through a local HP office when the order requires billing and invoicing).
- c. Prepaid transportation (there is a small handling charge for each order).
- d. No invoices — to provide these advantages, a check or money order must accompany each order.

Mail order forms and specific ordering information are available through your local HP office. The addresses and phone numbers of the offices are located at the back of this manual.

Table 4-3 Replaceable Parts

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A10	03561-66510	5	1	INPUT AMPLIFIER ASSEMBLY (REVISION B)	20480	03561-66510
A10C002	0160-4571	8	21	CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C004	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C005	0160-4532	1	1	CAPACITOR-FXD 1000PF +-20% 50VDC CER	28480	0160-4532
A10C006	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C007	0160-4792			CAPACITOR-FXD 8.2pf	28480	0160-4792
A10C008	0160-4811			CAPACITOR-FXD 270pf	28480	0160-4811
A10C100	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C101	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C103	0160-4571	0		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C104	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C106	0160-4571	8	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C107	0160-4953	0		CAPACITOR-FXD .027UF +-5% 50VDC CER	28480	0160-4953
A10C108	0160-4009	3	1	CAPACITOR-FXD 2200PF +-1% 500VDC MICA	28480	0160-4009
A10C109	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C110	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C111	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C112	0160-4801	7	2	CAPACITOR-FXD 100PF +-5% 100VDC CER	28480	0160-4801
A10C200	0170-0042	1	3	CAPACITOR-FXD .33UF +-5% 100VDC POLYE	99515	E1-3340
A10C201	0170-0042	1		CAPACITOR-FXD .33UF +-5% 100VDC POLYE	99515	E1-3340
A10C202	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C203	0160-4801	7		CAPACITOR-FXD 100PF +-5% 100VDC CER	28480	0160-4801
A10C204	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C205	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C300	0121-0536	5	2	CAPACITOR-V TRMR-PS1N 1-5.5PF 250V	28480	0121-0536
A10C301	0160-2207	3	1	CAPACITOR-FXD 300PF +-5% 300VDC MICA	28480	0160-2207
A10C302	0160-4796	9	2	CAPACITOR-FXD 3.9PF +--.25PF 100VDC CER	28480	0160-4796
A10C303	0121-0536	5		CAPACITOR-V TRMR-PS1N 1-5.5PF 250V	28480	0121-0536
A10C304	0160-4796	9		CAPACITOR-FXD 3.9PF +--.25PF 100VDC CER	28480	0160-4796
A10C305	0160-4790	1	1	CAPACITOR-FXD 2.7PF +--.25PF 100VDC CER	28480	0160-4798
A10C306	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C307	0170-0042	1		CAPACITOR-FXD .33UF +-5% 100VDC POLYE	99515	E1-3340
A10C308	0160-0116	1	1	CAPACITOR-FXD 6.8UF+-10% 35VDC TA	56209	150D685X9035B2
A10C400	0160-3847	9	12	CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C401	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C402	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C404	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C405	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C406	0160-4811	9	4	CAPACITOR-FXD 270PF +-5% 100VDC CER	28480	0160-4811
A10C407	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C408	0160-4811	9		CAPACITOR-FXD 270PF +-5% 100VDC CER	28480	0160-4811
A10C409	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C410	0160-4811	9		CAPACITOR-FXD 270PF +-5% 100VDC CER	28480	0160-4811
A10C411	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
A10C412	0160-4811	9		CAPACITOR-FXD 270PF +-5% 100VDC CER	28480	0160-4811
A10C413	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C414	0160-0228	6	1	CAPACITOR-FXD 22UF+-10% 15VDC TA	56209	150D226X9015B2
A10C415	0160-1794	3	2	CAPACITOR-FXD 22UF+-10% 35VDC TA	56289	150D226X9035B2
A10C416	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C417	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C418	0160-1794	3		CAPACITOR-FXD 22UF+-10% 35VDC TA	56209	150D226X9035B2
A10C500	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C501	0160-0127	2	3	CAPACITOR-FXD 1UF +-20% 25VDC CER	28480	0160-0127
A10C503	0160-0127	2		CAPACITOR-FXD 1UF +-20% 25VDC CER	28480	0160-0127
A10C505	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C506	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C507	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C508	0160-0127	2		CAPACITOR-FXD 1UF +-20% 25VDC CER	28480	0160-0127
A10C509	0160-2208	6	1	CAPACITOR-FXD 220UF+-10% 10VDC TA	56289	150D227X9010B2
A10C510	0160-0128	3	1	CAPACITOR-FXD 2.2UF +-20% 50VDC CER	28480	0160-0128
A10C511	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C512	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10C513	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A10CR001	1901-0579	1	2	DIODE-SWITCHING 40V 20MA 300NS DO-7	28480	1901-0579
A10CR002	1901-0579	1		DIODE-SWITCHING 40V 20MA 300NS DO-7	28480	1901-0579
A10CR003	1901-0040	1	2	DIODE-SWITCHING 30V 50MA 2NS DO-35	28480	1901-0040
A10CR004	1902-0049	2	4	DIODE-ZNR 6.19V 5% DO-35 PD=.4W	28480	1902-0049
A10CR005	1902-0049	2		DIODE-ZNR 6.19V 5% DO-35 PD=.4W	28480	1902-0049
A10CR006	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	28480	1901-0040
A10CR007	1902-0049	2		DIODE-ZNR 6.19V 5% DO-35 PD=.4W	28480	1902-0049
A10CR008	1902-0049	2		DIODE-ZNR 6.19V 5% DO-35 PD=.4W	28480	1902-0049
A10CR100	1902-0686	3	3	DIODE-ZNR 6.2V 2% DO-7 PD=.4W TC=+.002%	04713	1N825
A10CR101	1990-0486	6	2	LED-LAMP LUM-INT=1MCD IF=20MA-MAX FVR=5V	28480	5082-4684
A10CR200	1902-0686	3		DIODE-ZNR 6.2V 2% DO-7 PD=.4W TC=+.002%	04713	1N825
A10CR300	1902-0627	2	1	DIODE-CUR RGLTR 1N5312 100V DO-7	04713	1N5312
A10CR301	1901-0743	1	1	DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A10CR400	1990-0486	6		LED-LAMP LUM-INT=1MCD IF=20MA-MAX FVR=5V	28480	5082-4684
A10CR401	1901-0050	3	2	DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A10CR500	1902-0686	3		DIODE-ZNR 6.2V 2% DO-7 PD=.4W TC=+0.02Z	04713	1N025
A10CR501	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20400	1901-0050
A10K001	0490-1403	8	14	RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K002	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K100	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K101	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K200	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K300	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K301	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K302	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K303	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K304	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K305	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K306	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10K307	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	28480	0490-1403
A10K308	0490-1403	8		RELAY-REED 1A 500MA 200VDC 5VDC-COIL	20400	0490-1403
A10L300	9140-0740	0	2	INDUCTOR 250UH 25% .25DX.5LG 0=3	20480	9140-0740
A10L400	9140-0740	0		INDUCTOR 250UH 25% .25DX.5LG 0=3	28480	9140-0740
A10L401	9140-0029	0	2	INDUCTOR RF-CH-MLD 100UH 10% .25DX.313LG	28480	9140-0029
A10L402	9140-0029	0		INDUCTOR RF-CH-MLD 100UH 10% .25DX.313LG	20480	9140-0029
A10L403	03561-60305	0		INDUCTOR 2 mH	28480	03561-60305
A10Q001	1055-0460	0	1	TRANSISTOR J-FET N-CHAN	28480	1055-0460
A10Q500	1054-0215	1	3	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A10Q501	1054-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A10Q502	1054-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A10R001	0698-6634	1	2	RESISTOR 1.05K 1% .125W F TC=0+-25	28480	0698-6634
A10R002	0698-6624	5	5	RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6634
A10R003	0757-0416	7	1	RESISTOR 511 1% .125W F TC=0+-100	24546	C4-1/8-T0-511R-F
A10R004	0698-6362	0	1	RESISTOR 3K 1% .125W F TC=0+-25	28480	0698-6362
A10R005	0698-6362	0	2	RESISTOR 1K 1% .125W F TC=0+-25	28480	0698-6362
A10R006	0757-0280	3	3	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A10R007	0698-3178	8	1	RESISTOR 467 1% .125W F TC=0+-100	24546	C4-1/8-T0-467R-F
A10R008	0698-6699	4	1	RESISTOR 127 .25% .125W F TC=0+-50	28480	0698-6699
A10R009	2100-3874	8	1	RESISTOR-TRMR 5K 10% C TOP-ADJ 17-TRN	28480	2100-3874
A10R010	0757-0457	6	2	RESISTOR 47.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4750-F
A10R011	0757-0457	6		RESISTOR 47.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4750-F
A10R012	0757-0427	0	3	RESISTOR 1.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1501-F
A10R013	0757-0279	0	4	RESISTOR 3.16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3161-F
A10R014	0698-6362	8		RESISTOR 1K 1% .125W F TC=0+-25	28480	0698-6362
A10R015	0757-0273	4	2	RESISTOR 3.01K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3011-F
A10R016	0757-0273	4		RESISTOR 3.01K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3011-F
A10R017	0757-0427	0		RESISTOR 1.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1501-F
A10R018	0757-0279	0		RESISTOR 3.16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3161-F
A10R019	0698-6624	5		RESISTOR 2K 1% .125W F TC=0+-25	28480	0698-6624
A10R020	0698-7332	4	1	RESISTOR 1M 1% .125W F TC=0+-100	28480	0698-7332
A10R021	0757-0033	2	1	RESISTOR 5.11K 1% .5W F TC=0+-100	28480	0757-0033
A10R100	0698-6362	8		RESISTOR 1K 1% .125W F TC=0+-25	28480	0698-6362
A10R101	0698-6362	8		RESISTOR 1K 1% .125W F TC=0+-25	28480	0698-6362
A10R102	0698-6624	5		RESISTOR 2K 1% .125W F TC=0+-25	28480	0698-6624
A10R103	0698-6624	5		RESISTOR 2K 1% .125W F TC=0+-25	28480	0698-6624
A10R104	0757-0426	9	1	RESISTOR 1.3K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1301-F
A10R105	0490-4479	4	1	RESISTOR 14K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1402-F
A10R106	0698-6616	5	1	RESISTOR 750 1% .125W F TC=0+-25	28480	0698-6616
A10R107	0698-8611	4	1	RESISTOR 254.34 1% .125W F TC=0+-25	28480	0698-8611
A10R108	0698-8058	1	1	RESISTOR 12.4K 1% .125W F TC=0+-25	20480	0698-8058
A10R109	0757-0427	0		RESISTOR 1.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1501-F
A10R110	0757-0280	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A10R111	0757-0290	5	2	RESISTOR 6.19K 1% .125W F TC=0+-100	19701	MF4C1/8-T0-6191-F
A10R112	0757-0290	5		RESISTOR 6.19K 1% .125W F TC=0+-100	19701	MF4C1/8-T0-6191-F
A10R113	0698-4508	0	1	RESISTOR 70.7K 1% .125W F TC=0+-100	24546	C4-1/8-T0-7072-F
A10R114	0698-4440	9	1	RESISTOR 3.4K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3401-F
A10R115	0757-0401	6	5	RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A10R116	0683-5125	8	6	RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CR5125
A10R117	0683-5125	8		RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CR5125
A10R118	0683-1025	9	4	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CR1025
A10R119	0683-5125	8		RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CR5125
A10R200	0683-1525	4	2	RESISTOR 1.5K 5% .25W FC TC=-400/+700	01121	CR1525
A10R201	2100-0558	9	1	RESISTOR-TRMR 20K 10% C TOP-ADJ 1-TRN	28480	2100-0558
A10R202	2100-0567	0	1	RESISTOR-TRMR 2K 10% C TOP-ADJ 1-TRN	28480	2100-0567
A10R203	0698-7343	7	1	RESISTOR 78.7K .5% .125W F TC=0+-50	19701	MF4C1/8-T0-7872-F
A10R204	0698-6519	7	1	RESISTOR 26.7K 1% .125W F TC=0+-25	28480	0698-6519
A10R205	0757-0279	0		RESISTOR 3.16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3161-F
A10R206	0757-0279	0		RESISTOR 3.16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3161-F
A10R207	0698-3226	7	1	RESISTOR 6.49K 1% .125W F TC=0+-100	24546	C4-1/8-T0-6491-F
A10R208	0683-1525	4		RESISTOR 1.5K 5% .25W FC TC=-400/+700	01121	CR1525

See introduction to this section for ordering information  
 \*Indicates factory selected value



Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A10R300	0698-6306	0	1	RESISTOR 990K 1% .25W F TC=0+-25	28480	0698-6306
A10R301	0698-6975	9	1	RESISTOR 10.1K 1% .125W F TC=0+-25	28480	0698-6975
A10R302	0698-6979	3	1	RESISTOR 111.1K 1% .125W F TC=0+-25	28480	0698-6979
A10R303	0698-6305	9	1	RESISTOR 900K 1% .25W F TC=0+-25	28480	0698-6305
A10R304	0757-0401	0		RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A10R400	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A10R401	0698-4456	7	1	RESISTOR 549 1% .125W F TC=0+-100	24546	C4-1/8-T0-549R-F
A10R402	0698-3510	2	1	RESISTOR 453 1% .125W F TC=0+-100	24546	C4-1/8-T0-453R-F
A10R403	0698-6362	0		RESISTOR 1K 1% .125W F TC=0+-25	28480	0698-6362
A10R404	0698-6624	5		RESISTOR 2K 1% .125W F TC=0+-25	28480	0698-6624
A10R405	0698-4123	5	4	RESISTOR 499 1% .125W F TC=0+-100	24546	C4-1/8-T0-499R-F
A10R406	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A10R407	0698-4123	5		RESISTOR 499 1% .125W F TC=0+-100	24546	C4-1/8-T0-499R-F
A10R408	0698-4123	5		RESISTOR 499 1% .125W F TC=0+-100	24546	C4-1/8-T0-499R-F
A10R409	0698-4123	5		RESISTOR 499 1% .125W F TC=0+-100	24546	C4-1/8-T0-499R-F
A10R410	0698-4376	0	1	RESISTOR 32.4 1% .125W F TC=0+-100	24546	C4-1/8-T0-32R4-F
A10R500	2100-3020	6	1	RESISTOR-TRMR 10 20% C TOP ADJ 12-TRN	32997	32920-1-100
A10R501	0698-7161	7	1	RESISTOR 139.19 1% .125W F TC=0+-25	28480	0698-7161
A10R502	0683-4705	8	2	RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A10R503	0683-5125	8		RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CB5125
A10R504	0698-3404	9	1	RESISTOR 6.65K 1% .125W F TC=0+-100	24546	C4-1/8-T0-6651-F
A10R505	0683-5125	8		RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CB5125
A10R506	0757-0442	9	2	RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-100P-F
A10R507	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A10R508	0698-6625	6	2	RESISTOR 6K 1% .125W F TC=0+-25	28480	0698-6625
A10R509	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A10R510	0757-0401	0		RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A10R511	0757-0442	9		RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-100P-F
A10R512	0698-4438	5	1	RESISTOR 3.09K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3091-F
A10R513	0757-0401	0		RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A10R514	0757-0200	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A10R515	0698-6625	6		RESISTOR 6K 1% .125W F TC=0+-25	28480	0698-6625
A10R516	0698-6377	5	1	RESISTOR 200 1% .125W F TC=0+-25	28480	0698-6377
A10R517	0757-0401	0		RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A10R518	0757-0462	3	2	RESISTOR 75K 1% .125W F TC=0+-100	24546	C4-1/8-T0-750R-F
A10R519	0757-0462	3		RESISTOR 75K 1% .125W F TC=0+-100	24546	C4-1/8-T0-750R-F
A10R520	0698-4492	1	1	RESISTOR 32.4K 1% .125W F TC=0+-100	24546	C4-1/8-T0-324P-F
A10RP001	1810-0523	2	2	NETWORK-RES 14-DIP MULTI VALUE	28480	1810-0523
A10RP100	1810-0523	2		NETWORK-RES 14-DIP MULTI VALUE	28480	1810-0523
A10RP101	1810-0231	9	2	NETWORK-RES 8-SIP2.2K OHM X 7	01121	20RA222
A10RP400	1010-0231	9		NETWORK-RES 8-SIP2.2K OHM X 7	01121	20RA222
A10T400	9100-0468	7	1	TRANSFORMER-PULSE PRI OCL: 30UH; TURNS	28480	9100-0468
A10U001	1826-0501	5	3	IC SWITCH ANLG 16-DIP-C PKG	27014	LF13508D
A10U002	1826-0715	7	5	IC OP AMP LOW-NOISE 8-DIP-P PKG	18324	NE5534AN
A10U003	1826-0715	7		IC OP AMP LOW-NOISE 8-DIP-P PKG	18324	NE5534AN
A10U100	1826-0501	5		IC SWITCH ANLG 16-DIP-C PKG	27014	LF13508D
A10U101	1826-0715	7		IC OP AMP LOW-NOISE 8-DIP-P PKG	18324	NE5534AN
A10U102	1826-0715	7		IC OP AMP LOW-NOISE 8-DIP-P PKG	18324	NE5534AN
A10U103	1826-0501	5		IC SWITCH ANLG 16-DIP-C PKG	27014	LF13508D
A10U104	1820-1934	2	2	IC CONV 8-B-D/A 16-DIP-C PKG	06665	DAC-08EQ
A10U105	1820-1662	3	4	IC SHF-RGTR CMOS SERIAL-IN PRL-OUT 8-BIT	3L585	CD4094BE
A10U106	1850-0047	5	2	TRANSISTOR ARRAY 16-PIN PLSTC DIP	13606	ULN-2003A
A10U107	1820-1662	3		IC SHF-RGTR CMOS SERIAL-IN PRL-OUT 8-BIT	3L585	CD4094BE
A10U200	1826-0319	7	1	IC OP AMP LOW-BIAS-H-IMPD TO-99 PKG	04713	LF356G
A10U201	1820-1662	3		IC SHF-RGTR CMOS SERIAL-IN PRL-OUT 8-BIT	3L585	CD4094BE
A10U202	1820-1934	2		IC CONV 8-B-D/A 16-DIP-C PKG	06665	DAC-08EQ
A10U400	1820-1273	2	1	IC BFR TTL LS NOR QUAD 2-INP	01295	SN74LS20N
A10U401	1820-1662	3		IC SHF-RGTR CMOS SERIAL-IN PRL-OUT 8-BIT	3L585	CD4094BE
A10U402	1820-1440	5	1	IC LCH TTL LS QUAD	01295	SN74LS279N
A10U403	1850-0047	5		TRANSISTOR ARRAY 16-PIN PLSTC DIP	13606	ULN-2003A
A10U404	1820-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A10U405	1820-1074	1	1	IC DRV TTL NOR QUAD 2-INP	01295	SN74120N
A10U500	1820-2408	3	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A10U501	1826-0715	7		IC OP AMP LOW-NOISE 8-DIP-P PKG	18324	NE5534AN
A10U502	1826-0043	4	1	IC OP AMP GP TO-99 PKG	3L585	CA307T
				A10 MISCELLANEOUS PARTS		
	03561-23702	7	1	SHIELD, COMP SIDE	28480	03561-23702
	03561-01227	5	1	CVR, SHLD CAN	28480	03561-01227
	03577-20601	7	1	SHLD-CIRC SIDE	28480	03577-20601
	1250-1339	2	1	CONNECTOR-RF 5M-SLD M PC 50-OHM	28480	1250-1339
	1250-1512	3	1	CONNECTOR-RF 5M-SLD M PC 50-OHM	28480	1250-1512
	1251-5033	3	1	CONNECTOR 3-PIN M PUST TYPE	28480	1251-5033
	5040-6843	2	1	BOARD EXTRACTOR	28480	5040-6843
	5000-9043	6	1	BOARD EXTRACTOR PIN	28480	5000-9043
	0515-0158	2	6	SCREW-MACH M3 X 0.5 20MM-LG	00000	ORDER BY DESCRIPTION

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A15	03561-66515	0	1	DIGITIZER ASSEMBLY (REVISION B)	20400	03561-66515
A15C001	0160-5862	2	1	CAPACITOR-FXD 240PF +-1% 100VDC CER	20400	0160-5862
A15C002	0160-5872	4	1	CAPACITOR-FXD 750PF +-1% 100VDC CER	20400	0160-5872
A15C003	0160-5861	1	1	CAPACITOR-FXD 100PF +-1% 100VDC CER	20400	0160-5861
A15C004	0160-5874	6	2	CAPACITOR-FXD 2000PF +-1% 50VDC CER	20400	0160-5874
A15C005	0160-5870	2	1	CAPACITOR-FXD 430PF +-1% 100VDC CER	20400	0160-5870
A15C006	0160-5874	6		CAPACITOR-FXD 2000PF +-1% 50VDC CER	20400	0160-5874
A15C007	0160-5871	3	1	CAPACITOR-FXD 510PF +-1% 100VDC CER	20400	0160-5871
A15C008	0160-5880	4	1	CAPACITOR-FXD 3200PF +-1% 50VDC CER	20400	0160-5880
A15C009	0160-5873	5	1	CAPACITOR-FXD 1500PF +-1% 50VDC CER	20400	0160-5873
A15C010	0180-0271	3	2	CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C011	0160-4571	0	33	CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C012	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C013	0180-1794	3	2	CAPACITOR-FXD 22UF+-10% 35VDC TA	56209	150D226X9035R2
A15C014	0180-1794	3		CAPACITOR-FXD 22UF+-10% 35VDC TA	56209	150D226X9035R2
A15C015	0160-4801	7	5	CAPACITOR-FXD 100PF +-5% 100VDC CER	20400	0160-4801
A15C016	0160-4708	9	1	CAPACITOR-FXD 10PF +-5% 100VDC CER 0+-30	20400	0160-4708
A15C017	0160-4801	7		CAPACITOR-FXD 100PF +-5% 100VDC CER	20400	0160-4801
A15C018	0160-4007	3	1	CAPACITOR-FXD 33PF +-5% 100VDC CER 0+-30	20400	0160-4007
A15C019	0160-5865	5	1	CAPACITOR-FXD 36PF +-5% 200VDC CER 0+-30	20400	0160-5865
A15C020	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C101	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C102	0160-5863	3	1	CAPACITOR-FXD 330PF +-1% 100VDC CER	20400	0160-5863
A15C103	0160-4793	6	3	CAPACITOR-FXD 6.8PF +-5% 100VDC CER	20400	0160-4793
A15C104	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C105	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C106	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56209	150D105X9035A2
A15C107	0160-4447	7	2	CAPACITOR-FXD 220PF +-10% 50VDC POLYP	20400	0160-4447
A15C108	0160-4447	7		CAPACITOR-FXD 220PF +-10% 50VDC POLYP	20400	0160-4447
A15C109	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C110	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C111	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C112	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56209	150D105X9035A2
A15C113	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C114	0160-4793	6		CAPACITOR-FXD 6.8PF +-5% 100VDC CER	20400	0160-4793
A15C115	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C116	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C117	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C118	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C119	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C120	0160-4793	6		CAPACITOR-FXD 6.8PF +-5% 100VDC CER	20400	0160-4793
A15C121	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C122	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56209	150D105X9035A2
A15C123	0180-0309	4	3	CAPACITOR-FXD 4.7UF+-20% 10VDC TA	56207	150D475X010A2
A15C124	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C200	0160-4789	0	3	CAPACITOR-FXD 15PF +-5% 100VDC CER 0+-30	20400	0160-4789
A15C201	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C202	0160-4787	0	1	CAPACITOR-FXD 22PF +-5% 100VDC CER 0+-30	20400	0160-4787
A15C203	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C204	0180-0291	3		CAPACITOR-FXD 10UF+-10% 35VDC TA	56207	150D105X9035A2
A15C205	0180-0309	4		CAPACITOR-FXD 4.7UF+-20% 10VDC TA	56207	150D475X010A2
A15C206	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C207	0160-4825	5	1	CAPACITOR-FXD 560PF +-5% 100VDC CER	20400	0160-4825
A15C208	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C209	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C210	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C211	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C212	0180-0197	0	1	CAPACITOR-FXD 2.2UF+-10% 20VDC TA	56207	150D225X9020A2
A15C213	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C300	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C301	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C302	0160-4822	2	1	CAPACITOR-FXD 1000PF +-5% 100VDC CER	20400	0160-4822
A15C303	0160-4801	7		CAPACITOR-FXD 100PF +-5% 100VDC CER	20400	0160-4801
A15C304	0160-4789	0		CAPACITOR-FXD 15PF +-5% 100VDC CER 0+-30	20400	0160-4789
A15C305	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C306	0160-4814	0		CAPACITOR-FXD 150PF +-5% 10VDC CER 0+-30	20400	0160-4814
A15C307	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C308	0180-0220	6	1	CAPACITOR-FXD 22UF+-10% 15VDC TA	56207	150D226X9015B2
A15C309	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C400	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571
A15C401	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	20400	0160-4571

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A15C402	0160-4801	7	2	CAPACITOR-FXD 100PF +-5% 100VDC CER	20480	0160-4801
A15C403	0160-4801	7		CAPACITOR-FXD 100PF +-5% 100VDC CER	20480	0160-4801
A15C404	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3847
A15C405	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-4571
A15C406	0180-0309	4		CAPACITOR-FXD 4.7UF+-20% 10VDC TA	56289	1500475X0010A2
A15C407	0160-4571	8	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-4571
A15C500	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-4571
A15C501	0160-4808	7		CAPACITOR-FXD 470PF	20480	0160-4808
A15C502	0160-4794	7		CAPACITOR-FXD 5.6PF +- .5PF 100VDC CER	20480	0160-4794
A15C503	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-4571
A15C504	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3847
A15C505	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-4571
A15CR100	1901-0040	1	12	DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR101	1902-0952	6	1	DIODE-ZNR 5.6V 5% DO-35 PD=.4W TC=-.046%	20480	1902-0952
A15CR102	1901-0510	8	2	DIODE-5M SIG SCHOTTKY	20480	1901-0510
A15CR103	1901-0510	8		DIODE-5M SIG SCHOTTKY	20480	1901-0510
A15CR104	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR105	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR200	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR201	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR300	1901-0376	6	2	DIODE-GEN PRP 35V 50MA DO-35	20480	1901-0376
A15CR301	1901-0376	6		DIODE-GEN PRP 35V 50MA DO-35	20480	1901-0376
A15CR400	1902-0948	0	2	DIODE-ZNR 3.9V 5% DO-35 PD=.4W TC=-.012%	20480	1902-0948
A15CR401	1902-0945	7	2	DIODE-ZNR 3V 5% DO-35 PD=.4W TC=-.043%	20480	1902-0945
A15CR402	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR403	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR500	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR501	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR502	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR503	1902-0945	7		DIODE-ZNR 3V 5% DO-35 PD=.4W TC=-.043%	20480	1902-0945
A15CR504	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR505	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A15CR506	1902-0948	0		DIODE-ZNR 3.9V 5% DO-35 PD=.4W TC=-.012%	20480	1902-0948
A15J001	1250-1339	2	1	CONNECTOR-RF 5M-SLD M PC 50-OHM	20480	1250-1339
A15J100	1251-4822	6	1	CONNECTOR 3-PIN M POST TYPE	20480	1251-4822
A15J300	1251-4778	1	1	CONNECTOR 10-PIN M POST TYPE	22526	65547-110
A15L001	03561-60302	1	1	L-2304UH 1%	20480	03561-60302
A15L002	03561-60303	2	1	L-1034UH 1%	20480	03561-60303
A15L003	03561-60301	0	2	L-2035UH 1%	20480	03561-60301
A15L004	03561-60301	0		L-2035UH 1%	20480	03561-60301
A15L500	9100-2265	6	1	INDUCTOR RF-CH-MLO 10UH 10% .105DX.261G	20480	9100-2265
A15L501	9140-0748	0	3	INDUCTOR 250UH 25% .25DX.5LG Q=3	20480	9140-0748
A15L502	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	20480	9140-0748
A15L503	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	20480	9140-0748
A15P100	1250-0141	8	1	JUMPER-REM	20480	1250-0141
A15Q100	1055-0269	7	1	TRANSISTOR MOSFET N-CHAN E MODE TO-72 5T	10324	5D214
A15R001	0698-7847	6	1	RESISTOR 1.111K 1% .125W F TC=0+-25	19701	MF4C1/R-T9-1111R-B
A15R002	0698-6360	6	1	RESISTOR 10K 1% .125W F TC=0+-25	20480	0698-6360
A15R003	8150-3375	5	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	8150-3375
A15R004	0698-4509	2	1	RESISTOR 57.6K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5767-F
A15R005	0698-8629	4	1	RESISTOR 1.69K 1% .125W F TC=0+-25	20480	0698-8629
A15R006	0698-6362	8	4	RESISTOR 1K 1% .125W F TC=0+-25	20480	0698-6362
A15R007	0698-6624	5	5	RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6624
A15R008	0698-3454	3	2	RESISTOR 215K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2153-F
A15R009	0757-0200	3	9	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R010	0698-4471	6	1	RESISTOR 7.15K 1% .125W F TC=0+-100	24546	C4-1/8-T0-7151-F
A15R011	0698-4429	4	1	RESISTOR 1.07K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1071-F
A15R012	0757-0482	7	1	RESISTOR 511K 1% .125W F TC=0+-100	20480	0757-0482
A15R013	0757-0280	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R014	0757-0280	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R015	0757-0280	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R016	0757-0280	3		RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R100	0698-6362	8		RESISTOR 1K 1% .125W F TC=0+-25	20480	0698-6362
A15R101	0698-6624	5		RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6624
A15R102	0698-6362	8		RESISTOR 1K 1% .125W F TC=0+-25	20480	0698-6362
A15R103	0757-0274	5	3	RESISTOR 1.21K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1211-F
A15R104	0698-6320	8	1	RESISTOR 5K 1% .125W F TC=0+-25	03088	PM155-1/R-T9 5001-D
A15R105	0698-6627	0	1	RESISTOR 25K 1% .125W F TC=0+-25	20480	0698-6627
A15R106	0757-0346	2	8	RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10R0-F
A15R107	0757-0346	2		RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10R0-F
A15R108	0698-4412	5	1	RESISTOR 143 1% .125W F TC=0+-100	24546	C4-1/8-T0-143R-F
A15R109	0698-3161	7	2	RESISTOR 30.3K 1% .125W F TC=0+-100	24546	C4-1/8-T0-303R-F
A15R110	0757-0346	2		RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10R0-F
A15R111	0757-0346	2		RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10R0-F
A15R112	0757-0403	2	1	RESISTOR 121 1% .125W F TC=0+-100	24546	C4-1/8-T0-121R-F
A15R113	0757-0457	8	1	RESISTOR 56.2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5622-F

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A15R114	0698-3156	2	1	RESISTOR 14.7K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1472-F
A15R115	2100-3296	8	1	RESISTOR-TRMR 1K 10% C TOP-ADJ 17-TRN	20480	2100-3296
A15R116	0757-0346	2	1	RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10K0-F
A15R117	0757-0346	2	1	RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10K0-F
A15R118	0757-0346	2	1	RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10K0-F
A15R119	0757-0346	2	1	RESISTOR 10 1% .125W F TC=0+-100	24546	C4-1/8-T0-10K0-F
A15R120	0757-1094	9	2	RESISTOR 1.47K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1471-F
A15R121	0698-3161	9	1	RESISTOR 39.3K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3932-F
A15R122	0757-0472	5	1	RESISTOR 200K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2003-F
A15R123	0698-6347	9	1	RESISTOR 1.5K 1% .125W F TC=0+-25	20480	0698-6347
A15R124	0757-0274	5	1	RESISTOR 1.21K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1211-F
A15R125	0683-0475	1	1	RESISTOR 4.7 5% .25W FC TC=400+-500	01121	CR4705
A15R200	2100-3354	9	1	RESISTOR-TRMR 50K 10% C SIDE-ADJ 1-TRN	20480	2100-3354
A15R201	2100-3207	1	1	RESISTOR-TRMR 5K 10% C SIDE-ADJ 1-TRN	20480	2100-3207
A15R202	2100-3354	6	1	RESISTOR-TRMR 50K 10% C SIDE-ADJ 17-TRN	02111	43P593
A15R203	0698-6624	5	1	RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6624
A15R204	0698-3162	0	1	RESISTOR 46.4K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4642-F
A15R205	0757-1094	9	1	RESISTOR 1.47K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1471-F
A15R206	0698-6624	5	1	RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6624
A15R207	0757-0467	0	1	RESISTOR 121K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1213-F
A15R208	0757-0442	9	1	RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1002-F
A15R209	0698-3445	2	1	RESISTOR 340 1% .125W F TC=0+-100	24546	C4-1/8-T0-340R-F
A15R210	0698-6361	7	3	RESISTOR 0K 1% .125W F TC=0+-25	20480	0698-6361
A15R211	0698-6361	7	1	RESISTOR 0K 1% .125W F TC=0+-25	20480	0698-6361
A15R212	0757-0290	5	1	RESISTOR 6.19K 1% .125W F TC=0+-100	19791	MF4C1/8-T0-6191-F
A15R213	0698-3444	1	1	RESISTOR 316 1% .125W F TC=0+-100	24546	C4-1/8-T0-316R-F
A15R214	0698-6503	5	1	RESISTOR 66.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-6652-F
A15R215	0699-0690	5	1	RESISTOR 302 1% .125W F TC=0+-25	20480	0699-0690
A15R216	0757-0420	1	1	RESISTOR 1.62K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1621-F
A15R217	0698-6624	5	1	RESISTOR 2K 1% .125W F TC=0+-25	20480	0698-6624
A15R218	0757-0462	3	1	RESISTOR 75K 1% .125W F TC=0+-100	24546	C4-1/8-T0-7502-F
A15R219	0699-0842	9	1	RESISTOR 6.19K 1% .125W F TC=0+-25	20480	0699-0842
A15R220	0757-0401	0	1	RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A15R221	0757-0200	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R222	0698-7394	8	1	RESISTOR 698 1% .125W F TC=0+-25	19791	MF4C1/8-T0-698R-F
A15R223	0898-8381	7	1	RESISTOR 8K 1% .125W F TC=0+-25	20480	0898-8381
A15R224	0898-8366	2	1	RESISTOR 800 1% .125W F TC=0+-25	20480	0898-8366
A15R225	0898-8377	5	1	RESISTOR 200 1% .125W F TC=0+-25	20480	0898-8377
A15R226	0757-0484	3	1	RESISTOR 619K 1% .125W	20480	0757-0484
A15R300	0898-3454	3	1	RESISTOR 215K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2153-F
A15R301	0898-3202	9	1	RESISTOR 1.74K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1741-F
A15R302	0757-0200	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R303	0698-3266	5	1	RESISTOR 237K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2373-F
A15R304	0757-0200	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R305	0757-0439	4	1	RESISTOR 6.81K 1% .125W F TC=0+-100	24546	C4-1/8-T0-6811-F
A15R306	0698-0085	0	1	RESISTOR 2.61K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2611-F
A15R307	0698-4439	6	1	RESISTOR 3.24K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3241-F
A15R308	0757-0416	7	1	RESISTOR 511 1% .125W F TC=0+-100	24546	C4-1/8-T0-511R-F
A15R309	0698-6362	8	1	RESISTOR 1K 1% .125W F TC=0+-25	20480	0698-6362
A15R310	0698-6348	0	1	RESISTOR 3K 1% .125W F TC=0+-25	20480	0698-6348
A15R311	0698-4211	2	1	RESISTOR 150K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1503-F
A15R400	0698-3402	1	1	RESISTOR 316 1% .5W F TC=0+-100	20480	0698-3402
A15R401	0757-0280	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A15R402	0698-0084	9	1	RESISTOR 2.15K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2151-F
A15R403	0757-1060	9	1	RESISTOR 196 1% .5W F TC=0+-100	20480	0757-1060
A15R500	0698-3439	4	1	RESISTOR 170 1% .125W F TC=0+-100	24546	C4-1/8-T0-170R-F
A15R501	0757-0274	5	1	RESISTOR 1.21K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1211-F
A15R502	0757-0418	9	1	RESISTOR 619 1% .125W F TC=0+-100	24546	C4-1/8-T0-619R-F
A15R503	0757-0443	3	1	RESISTOR 11K 1% .125W	20480	0757-0443
A15R504	1010-0037	3	2	NETWORK-RES 16-DIP1.0K OHM X 8	11236	761-3-R1K
A15R505	1010-0037	3	2	NETWORK-RES 16-DIP1.0K OHM X 0	11236	761-3-R1K
A15T001	9100-2616	1	1	TRANSFORMER-PULSE BIFILAR WOUND; 10.0 MM	20480	9100-2616
A15T400	2100-4336	6	2	PE0304	20480	2100-4336
A15T500	2100-4336	6	2	PE0304	20480	2100-4336
A15U001	1026-0175	7	2	IC OP AMP LOW-NOISE 8-DIP-P PKG	10324	NE5534AN
A15U002	1026-0175	3	3	IC COMPARATOR GP DUAL 14-DIP-P PKG	27014	LM319N
A15U010	1026-0175	7	1	IC OP AMP LOW-NOISE 8-DIP-P PKG	10324	NE5534AN
A15U011	1026-0109	3	3	IC OP AMP WB TO-99 PKG	34371	HA2-2625-B0593
A15U012	1026-1110	8	1	D/A 16-BIT 24-DIP-C BPLR	20480	1026-1110
A15U200	1026-0109	3	1	IC OP AMP WB TO-99 PKG	34371	HA2-2625-B0593
A15U201	1026-0445	0	1	IC 7935 V REGTR TO-220	07263	UA7905UC
A15U202	1026-1127	7	1	IC PREN DUAL 8-T0-99 PKG	20480	1026-1127
A15U203	1026-0528	0	1	IC OP AMP LOW-BIAS-H-IMPD TO-99 PKG	27014	LF356BH
A15U204	1026-0501	9	1	IC MULTIPLEX 2-CHAN-ANLC TRIPLE 16-DIP-P	04713	MC14053BCP
A15U205	1026-0109	3	1	IC OP AMP WB TO-99 PKG	34371	HA2-2625-B0593
A15U206	1026-1112	0	1	A/D 8-1/2-BIT 10-DIP-C BPLR	20480	1026-1112
A15U300	1026-0175	3	1	IC COMPARATOR GP DUAL 14-DIP-P PKG	27014	LM319N
A15U301	1026-0408	1	1	IC OP AMP WB TO-99 PKG	27014	LM210H
A15U302	1026-0175	3	1	IC COMPARATOR GP DUAL 14-DIP-P PKG	27014	LM319N

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A15U303	1020-1922	8	1	IC SHF-RGTR TTL LS PRL-IN SERIAL-OUT	01295	SN74LS166N
A15U304	1020-2634	1	2	IC INV TTL ALS HEX	01295	SN74ALS04N
A15U305	1020-1440	5	1	IC LCH TTL LS QUAD	01295	SN74LS279N
A15U306	1020-2656	7	2	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A15U400	1020-1195	7	1	IC FF TTL LS D-TYPE POS-EDGE-TRIG CDM	01295	SN74LS175N
A15U401	1020-1492	7	1	IC BFR TTL LS INV HEX 1-INP	01295	SN74LS368AN
A15U402	1020-3441	0	1	IC GATE-ARY CMOS	20400	1020-3441
A15U403	1020-1662	3	1	IC SHF-RGTR CMOS SERIAL-IN PRL-OUT 8-BIT	31585	CD4094BC
A15U404	1020-0471	0	2	IC INV TTL HEX 1-INP	01295	SN7406N
A15U405	1020-0693	8	1	IC FF TTL S D-TYPE POS-EDGE-TRIG	01295	SN74C74N
A15U406	1020-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A15U500	1020-2634	1		IC INV TTL ALS HEX	01295	SN74ALS04N
A15U501	1020-0471	0		IC INV TTL HEX 1-INP	01295	SN7406N
A15 MISCELLANEOUS PARTS						
	0340-0564	3	1	INSULATOR-XSTR THRM-CONDCT	20400	0340-0564
	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-PSC-SZ SQ	20400	1251-0600
	1400-0116	0	1	PIN GRV .052-IN DIA .25-IN-LG STL	20400	1400-0116
	2190-0004	9	1	WASHER-LK INTL T NO. 4 .115-IN-ID	20400	2190-0004
	2200-0105	4	1	SCREW-MACH 4-40 .312-IN-LG PAN-RO-POZI	00000	ORDER BY DESCRIPTION
	2260-0001	5	1	NUT-HEX-DBL-CHAM 4-40-THD .094-IN-THK	20400	2260-0001
	3050-0440	2	1	WASHER SHLDR NO. 4 .115-IN-ID .2-IN-OD	20400	3050-0440
	3050-0063	3	3	WASHER-FL NM 9/32 IN .295-IN ID	20400	3050-0063
	4040-0711	0	1	EXTR-PC BD BRN POLYC .07-BD-THKNS	20400	4040-0711
	4040-0753	0	1	EXTR-PC BD GRN POLYC .062-BD-THKNS	20400	4040-0753

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A29	03561-66520	7	1	DIGITAL FILTER ASSEMBLY (REVISION B)	28480	03561-66520
A29C001	0160-4571	8	36	CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C002	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C003	0180-0374	3	5	CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A29C004	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C005	0180-0374	3		CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A29C006	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C007	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C008	0160-4810	8	2	CAPACITOR-FXD 330PF +-5% 100VDC CER	28480	0160-4810
A29C009	0160-4810	8		CAPACITOR-FXD 330PF +-5% 100VDC CER	28480	0160-4810
A29C010	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C011	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C010	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C011	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C012	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C020	0160-4571	8		CAPACITOR-FXD .10UF +00-20% 50VDC CER	28480	0160-4571
A29C201	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C202	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C300	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C301	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C302	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C303	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C400	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C401	0180-0374	3		CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A29C402	0180-0374	3		CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A29C403	0180-1974	1	1	CAPACITOR-FXD 10UF+-10% 35VDC TA	56209	150D106X9035R2
A29C404	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C405	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C406	0100-0374	3		CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A29C407	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C408	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C500	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C501	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C502	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C503	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C600	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C601	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C602	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C603	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C604	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C700	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C701	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C702	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C703	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29C704	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A29J100	1251-5202	8	2	CONNECTOR 5-PIN M POST TYPE	28480	1251-5202
A29J200	1251-5202	8		CONNECTOR 5-PIN M POST TYPE	28480	1251-5202
A29R001	0683-3375	5	2	RESISTOR ZERO OHMS 22 AWG LEAD DIA	28480	0683-3375
A29R002	0683-1005	5	4	RESISTOR 10 5% .25W FC TC=-400/+500	01121	CB1005
A29R003	0683-1005	5		RESISTOR 10 5% .25W FC TC=-400/+500	01121	CB1005
A29R004	0603-2415	3	2	RESISTOR 240 5% .25W FC TC=-400/+600	01121	CB2415
A29R005	0683-1025	9	11	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R006	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R007	0683-3375	5		RESISTOR ZERO OHMS 22 AWG LEAD DIA	28480	0683-3375
A29R008	0683-1005	5		RESISTOR 10 5% .25W FC TC=-400/+500	01121	CB1005
A29R009	0683-1005	5		RESISTOR 10 5% .25W FC TC=-400/+500	01121	CB1005
A29R010	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R011	0683-2415	3		RESISTOR 240 5% .25W FC TC=-400/+600	01121	CB2415
A29R012	0603-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R013	0683-4715	0	2	RESISTOR 470 5% .25W FC TC=-400/+600	01121	CB4715
A29R014	0683-4715	0		RESISTOR 470 5% .25W FC TC=-400/+600	01121	CB4715
A29R015	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R016	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R100	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R200	0683-4725	2	2	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A29R300	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R400	0683-6015	5	1	RESISTOR 680 5% .25W FC TC=-400/+600	01121	CB6815
A29R401	0757-0430	5	1	RESISTOR 2.21K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2211-F
A29R402	3757-0442	9	1	RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1002-F
A29R500	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A29R501	0603-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A29R700	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A20R701	9603-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1925
A20RP200	1010-0200	8	3	NETWORK-RES 10-SIP10.0K OHM X 9	01121	216A103
A20RP400	1010-0200	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	216A103
A20RP500	1010-0200	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	216A103
A20TP001	1251-0600	0	16	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP100	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP131	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP200	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP201	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP300	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP301	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP302	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP501	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP502	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP700	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP701	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP702	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20TP703	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28400	1251-0600
A20U001	15C3-0033	5	2	DECIMATION FLTR	28400	15C3-0033
A20U002	1020-2103	9	2	IC DRVR TTL CLOCK DRVR DUAL	27014	DS0056CJ-8
A20U003	1020-2103	9		IC DRVR TTL CLOCK DRVR DUAL	27014	DS0056CJ-8
A20U004	15C4-0034	8	1	FLTR CONTROLLER	28400	15C4-0034
A20U005	1020-2656	7	1	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A20U100	1020-0681	4	1	IC GATE TTL S NAND QUAD 2-INP	01295	SN74LS00N
A20U101	1020-2634	1	2	IC INV TTL ALS HEX	01295	SN74ALS04N
A20U102	1020-0629	0	1	IC FF TTL S J-K NEG-EDGE-TRIG	01295	SN74LS112N
A20U103	1020-1205	0	2	IC GATE TTL LS AND DUAL 4-INP	01295	SN74LS21N
A20U104	1020-1196	8	1	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS174N
A20U105	1020-1433	6	2	IC SHF-RCTR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A20U106	1020-2635	2	2	IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS08N
A20U107	1020-3239	4	5	IC DRVR TTL ALS BUS OCTL	28400	1020-3239
A20U100	1020-1205	0		IC GATE TTL LS AND DUAL 4-INP	01295	SN74LS21N
A20U107	1020-1281	2	1	IC DCVR TTL LS 2-TO-4-LINE DUAL 2-INP	01295	SN74LS139N
A20U110	1020-2046	9	2	IC MUXR/DATA-SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS353N
A20U111	1020-2046	9		IC MUXR/DATA-SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS353N
A20U200	1020-2691	0	6	IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U201	1020-2691	0		IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U202	1020-2705	7	1	IC 8-BIT/16-BIT SYSTEM TIMING CONTROLLER	20400	1020-2705
A20U203	1020-2691	9		IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U300	1020-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS08N
A20U301	1020-2691	0		IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U302	1020-2691	0		IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U303	1020-2691	0		IC FF TTL F D-TYPE POS-EDGE-TRIG	07263	74F74PC
A20U304	1020-2772	0	1	IC FF TTL ALS J-K NEG-EDGE-TRIG	01295	SN74ALS112N
A20U305	1020-2400	3	2	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A20U306	1020-3100	8	2	IC DCVR TTL ALS BIN 3-TO-8-LINE 3-INP	28400	1020-3100
A20U307	1020-3100	8		IC DCVR TTL ALS BIN 3-TO-8-LINE 3-INP	28400	1020-3100
A20U300	1020-1211	8	2	IC GATE TTL LS EXCL-OR QUAD 2-INP	01295	SN74LS86N
A20U309	1020-1211	8		IC GATE TTL LS EXCL-OR QUAD 2-INP	01295	SN74LS86N
A20U400	1020-3239	3	3	IC TRANSCEIVER TTL ALS BUS OCTL	28400	1020-3239
A20U401	15C3-0033	5		DECIMATION FLTR	28400	15C3-0033
A20U402	1020-3239	3		IC TRANSCEIVER TTL ALS BUS OCTL	28400	1020-3239
A20U500	1020-1730	6	3	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A20U501	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A20U502	1020-1195	7	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS175N
A20U503	1020-2773	9	2	IC GATE TTL ALS NAND 8-INP	01295	SN74ALS30N
A20U504	1020-2739	7	1	IC GATE TTL ALS NOR QUAD 2-INP	01295	SN74ALS02N
A20U505	1020-1244	7	2	IC MUXR/DATA-SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS153N
A20U506	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A20U507	1020-1244	7		IC MUXR/DATA-SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS153N
A20U500	1020-1430	3	1	IC CNTR TTL LS BIN SYNCHRO POS-EDGE-TRIG	01295	SN74LS161AN
A20U509	1020-1195	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS175N
A20U510	1020-1977	7	6	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A20U600	1020-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	28400	1020-3238
A20U601	1020-3239	4		IC DRVR TTL ALS BUS OCTL	28400	1020-3239
A20U602	1020-1977	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A20U603	1020-1977	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A20U604	1020-3239	4		IC DRVR TTL ALS BUS OCTL	28400	1020-3239
A20U605	1020-3239	4		IC DRVR TTL ALS BUS OCTL	28400	1020-3239
A20U606	1020-1977	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A20U607	1020-1977	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A20U700	1020-2096	9	3	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A20U701	1020-2657	8	1	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A20U702	1820-0603	6	1	IC INV TTL S HEX 1-INP	01295	SN74S04N
A20U703	1820-2634	1		IC INV TTL ALS HEX	01295	SN74ALS04N
A20U704	1820-2773	9		IC GATE TTL ALS NAND 8-INP	01295	SN74ALS30N
A20U705	1820-2096	9		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A20U706	1820-2096	9		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A20U707	1820-3239	4		IC DRVR TTL ALS BUS OCTL	28480	1820-3239
A20U708	1820-2400	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A20U709	1820-1991	7	1	IC	01295	SN74LS390PC
A20U710	1820-1433	6		IC SHF-RETR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A20X708	1200-0638	7	1	SOCKET-IC 14-CONT DIP DIP-SLDR	28480	1200-0638
A20X709	1200-0607	8	1	SOCKET-IC 16-CONT DIP DIP-SLDR	28480	1200-0607
				A20 MISCELLANEOUS PARTS		
	03561-41101	8	3	HEAT SINK	28480	03561-41101
	0380-0411	3	12	SPACER-RND .5-IN-LG .114-IN-ID	28480	0380-0411
	0515-0064	9	12	SCREW-MACH M3 X 0.5 16MM-LG PAN-HD	28480	0515-0064
	0590-1095	6	1	THREADED INSERT-NUT M3 X 0.5 .059-IN-LG	28480	0590-1095
	1200-1011	2	1	SOCKET-IC 64-CONT SQUARE DIP-SLDR	28480	1200-1011
	1260-0989	7	2	SEMICONDUCTOR PKG PART CERAMIC PLUG-IN	28480	1260-0989
	1460-1007	2	12	SPRING-CPRSN .24-IN-OD .375-IN-OD-LG MUW	28480	1460-1007
	1480-0116	8	1	PIN-CRV .062-IN-DIA .25-IN-LG STL	28480	1480-0116
	3980-0621	2	2	LID-ALKNA .6-WD .6-LG .071-THK	28480	3980-0621
	4040-0740	3	1	EXTR-PC BD BLK POLYC .062-BD-THKNS	28480	4040-0740
	4040-0750	7	1	EXTR-PC BD RED POLYC .062-BD-THKNS	28480	4040-0750

See introduction to this section for ordering information  
 \*Indicates factory selected value



Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A30	03561-66530	9	1	FFT/RAM ASSEMBLY (REVISION B)	20400	03561-66530
A30C001	0160-4571	8	55	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A30C002	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C003	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C004	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C005	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C006	0160-4571	8	2	CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C100	0160-4791	4		CAPACITOR-FXD 101F +-5% 100VDC CER 0+-30	20400	0160-4791
A30C101	0160-4791	4		CAPACITOR-FXD 101F +-5% 100VDC CER 0+-30	20400	0160-4791
A30C102	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C103	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C104	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C105	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C200	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C201	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C202	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C203	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C204	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C205	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C206	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C207	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C208	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C209	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C210	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C211	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C300	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C301	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C302	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C303	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C304	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C305	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C306	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C307	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C308	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C309	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C310	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C400	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C500	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C501	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C502	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C503	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C504	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C505	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C600	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C601	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C602	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C603	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C604	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C605	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C606	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C607	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C700	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C701	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C702	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C703	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C704	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C705	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30C706	0160-4571	8		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20400	0160-4571
A30CR001	1990-0485	5	1	LED-LAMP LUM-INT=000UCD 1F=30MA-MAX	20400	5302-4704
A30J001	1251-5202	0	2	CONNECTOR 5-PIN M POST TYPE	20400	1251-5202
A30J200	1251-5202	0		CONNECTOR 5-PIN M POST TYPE	20400	1251-5202
A30R001	0683-2715	6	1	RESISTOR 270 5% .25W FC TC=-400/+600	01121	C07715
A30R002	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	C01025
A30R003	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	C01025
A30R004	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	C01025
A30R300	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	C04705
A30R301	0683-4705	8	4	RESISTOR 47 5% .25W FC TC=-400/+500	01121	C04705
A30R302	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	C04705
A30R401	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	C01025
A30R403	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20400	0150-3375
A30R406	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	C01025

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A30R437	8150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	8150-3375
A30R409	8150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	8150-3375
A30R411	8150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	8150-3375
A30R500	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A30R501	0603-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A30R600	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A30R700	0603-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A30RP200	1810-0533	4	1	NETWORK-RES 16-DIP33.0 OHM X 8	20480	1810-0533
A30RP500	1010-0280	0	5	NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A30RP501	1810-0200	0		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A30RP600	1010-0280	0		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A30RP601	1810-0200	0		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A30RP700	1010-0280	0		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A30TP001	1251-0600	0	10	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP002	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP003	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP004	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP100	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP101	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP200	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP300	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30TP301	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A30U001	1820-2488	3	3	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A30U002	1820-2001	0	1	IC-SN74ALS27	20480	1820-2001
A30U003	1820-0683	6	1	IC INV TTL S HEX 1-INP	01295	SN74S04N
A30U004	1020-2565	7	2	IC BFR TTL S LINE DRVR OCTL	34335	AM74S244N
A30U005	1820-2488	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A30U006	1820-2635	2	3	IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A30U007	1820-2565	7		IC BFR TTL S LINE DRVR OCTL	34335	AM74S244N
A30U100	T-55272	0	1	TMS320	20480	T-55272
A30U101	1820-1997	7	8	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U102	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U103	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U104	1820-1997	7		IC FE TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U105	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U106	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U200	1820-1428	9	2	IC MUXR/DATA-SEL TTL LS 2-TO-1-LINE QUAD	01295	SN74LS150N
A30U201	1818-3006	8	16	IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U202	1818-3006	0		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U203	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U204	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U205	1820-1428	9		IC MUXR/DATA-SEL TTL LS 2-TO-1-LINE QUAD	01295	SN74LS150N
A30U206	1820-3239	4	3	IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A30U207	1810-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1810-3006
A30U208	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U209	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U210	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U300	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U301	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U302	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U303	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U304	1820-2775	1	3	IC GATE TTL ALS NAND TPL 3-INP	01295	SN74ALS10N
A30U305	1820-2635	7	3	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A30U306	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U307	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U308	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U309	1818-3006	8		IC NMOS 65536 (64K) DYN RAM 200-NS 3-S	20480	1818-3006
A30U310	1820-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A30U311	1820-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A30U400	03561-60315	6	1	PROGRAMMED PROM	20480	03561-60315
A30U401	1820-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A30U402	03561-60316	7	1	PROGRAMMED PROM	20480	03561-60316
A30U501	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U502	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A30U503	1820-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A30U506	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A30U600	1820-1195	7	1	IC FE TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS175N
A30U601	1820-2096	9	1	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A30U602	1820-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A30U604	1820-3238	3	2	IC TRANSCEIVER TTL ALS BUS OCTL	20480	1820-3230
A30U605	1820-2657	8	1	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A30U606	1820-3100	0	1	IC CDCR TTL ALS BIN 3-TO-6-LINE 3-INP	20480	1820-3100

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A30U607	1020-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A30U608	1020-2488	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A30U609	1020-2775	1		IC GATE TTL ALS NAND TPL 3-INP	01295	SN74ALS10N
A30U700	1020-3230	3		IC TRANSCEIVER TTL ALS BUS OCTL	20480	1020-3230
A30U701	1020-1730	6	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A30U702	1020-2739	7	1	IC GATE TTL ALS NOR QUAD 2-INP	01295	SN74ALS02N
A30U703	1020-0629	0	3	IC FF TTL S J-K NEG-EDGE-TRIG	01295	SN74S112N
A30U704	1020-0629	0		IC FF TTL S J-K NEG-EDGE-TRIG	01295	SN74S112N
A30U705	1020-2775	1		IC GATE TTL ALS NAND TPL 3-INP	01295	SN74ALS10N
A30U706	1020-1729	3	1	IC LCH TTL LS COM CLEAR 8-DIT	01295	SN74LS259N
A30U707	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A30U708	1020-1051	2	1	IC ENCDR TTL LS	01295	SN74LS140N
A30U709	1020-0629	0		IC FF TTL S J-K NEG-EDGE-TRIG	01295	SN74S112N
A30W100	1251-5205	7	1	CONNECTOR 2-PIN M POST TYPE	20480	1251-5205
A30W101	T-55274	2	2	0X2 JUMPER	20480	T-55274
A30W102	T-55274	2		0X2 JUMPER	20480	T-55274
A30Y001	0410-1501	9	1	CRYSTAL-QUARTZ 20 MHZ HC-18/U-HLDR	20480	0410-1501
				A30 MISCELLANEOUS PARTS		
	1251-5376	7	1	CONNECTOR 8-PIN M POST TYPE	20480	1251-5376
	1480-0116	8	1	PIN-GRV .062-IN-DIA .25-IN-LG STL	20480	1480-0116
	4040-0748	3	1	EXTR-PC BD BLK POLYC .062-BD-THKNS	20480	4040-0748
	4040-0751	8	1	EXTR-PC BD DRN POLYC .062-BD-THKNS	20480	4040-0751

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A40	03561-66540	1	1	PROCESSOR/ROM ASSEMBLY (REVISION 8)	28480	03561-66540
A40C001	0160-4571	0	60	CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C002	0160-3847	9	3	CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A40C003	0180-0229	7	1	CAPACITOR-FXD 330UF+-10% 10VDC TA	56289	150D336X9010R2
A40C004	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C005	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C006	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C007	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C008	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C009	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C010	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C011	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C100	0180-0228	6	1	CAPACITOR-FXD 220UF+-10% 15VDC TA	56289	150D226X901502
A40C101	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C102	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C103	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C104	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C105	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C106	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C107	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C108	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C109	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C110	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A40C200	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C201	0121-9432	0	1	CAPACITOR-V TRMR AIR 2.1-13.3PF 350V	74970	189-8505-125
A40C202	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C203	0160-4021	1	1	CAPACITOR-FXD 1200PF +-5% 100VDC CER	28480	0160-4021
A40C204	0180-0374	3	1	CAPACITOR-FXD 100UF+-10% 20VDC TA	56289	150D106X9020R2
A40C205	0160-4790	3	1	CAPACITOR-FXD 12PF +-5% 100VDC CER 9+-30	28480	0160-4790
A40C206	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A40C207	0180-0116	1	1	CAPACITOR-FXD 6.8UF+-10% 35VDC TA	56289	150D635X9035R2
A40C208	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C209	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C210	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C211	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C212	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C213	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C214	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C215	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C216	0160-2328	9	1	CAPACITOR-FXD 200PF +-1% 300VDC MICA	28480	0160-2328
A40C300	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C301	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C302	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C303	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C304	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C305	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C306	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C307	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C308	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C309	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C310	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C400	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C401	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C402	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C403	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C404	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C405	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C406	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C407	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C408	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C409	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C500	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C501	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C502	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C503	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C504	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C600	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C601	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C602	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C700	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A40C701	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A40G782	1160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28489	0160-4571
A40LR001	1990-0485	5	1	LED-LAMP LUM-INT=800UCD IF=30MA-MAX	28480	5882-4994
A40CR002	1990-0486	6	1	LED-LAMP LUM-INT=1MCD IF=20MA-MAX DVR=5V	28480	5882-4684
A40CR003	1902-0943	5	1	DIODE-ZNR 2.4V 5% DO-35 PD=.4W TC=-.037%	28480	1902-0943
A40CR200	1901-0025	2	1	DIODE-GEN PRP 100V 200MA DO-7	28480	1901-0025
A40J100	1251-5202	0	1	CONNECTOR 5-PIN M POST TYPE	28480	1251-5202
A40L100	9140-0748	0	1	INDUCTOR 250UH 25% .25DX.5LG Q=3	28480	9140-0748
A40L101	9100-3313	7	1	INDUCTOR RF-CH-MLD 22UH 5% .166DX.385LG	28400	9100-3313
A40L201	9140-0253	2	1	INDUCTOR RF-CH-MLD 300NH 1% .166DX.385LG	20489	9140-0253
A40Q100	1854-0019	3	1	TRANSISTOR NPN SI TO-18 PD=360MW	28480	1854-0019
A40Q200	1054-0215	1	2	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A40Q201	1854-0215	1	1	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A40R001	0757-0415	6	3	RESISTOR 475 1% .125W F TC=0+-100	24546	C4-1/8-T0-475R-F
A40R002	0683-2215	1	1	RESISTOR 220 5% .25W FC TC=-400/+600	01121	CB2215
A40R003	0698-3279	0	6	RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R004	0683-1015	7	1	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A40R005	0683-1135	8	1	RESISTOR 91K 5% .25W FC TC=-400/+800	01121	CB9135
A40R006	0683-1035	1	3	RESISTOR 10K 5% .25W FC TC=-400/+700	01121	CB1035
A40R007	0683-1035	1		RESISTOR 10K 5% .25W FC TC=-400/+700	01121	CB1035
A40R008	0683-1535	6	1	RESISTOR 15K 5% .25W FC TC=-400/+800	01121	CB1535
A40R009	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R100	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R101	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A40R102	0683-2715	6	2	RESISTOR 270 5% .25W FC TC=-400/+600	01121	CB2715
A40R103	0683-2715	6		RESISTOR 270 5% .25W FC TC=-400/+600	01121	CB2715
A40R104	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A40R105	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A40R200	0683-4705	8	4	RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A40R201	0683-5115	6	1	RESISTOR 510 5% .25W FC TC=-400/+600	01121	CB5115
A40R203	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R204	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A40R205	0757-0415	6		RESISTOR 475 1% .125W F TC=0+-100	24546	C4-1/8-T0-475R-F
A40R206	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A40R207	0683-1035	1		RESISTOR 10K 5% .25W FC TC=-400/+700	01121	CB1035
A40R208	0757-0415	6		RESISTOR 475 1% .125W F TC=0+-100	24546	C4-1/8-T0-475R-F
A40R209	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R210	0683-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A40R400	0683-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A40R401	0683-3305	2	1	RESISTOR 33 5% .25W FC TC=-400/+500	01121	CB3305
A40R402	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A40R503	0150-3375	5	8	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R504	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R505	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R600	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R601	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R603	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R604	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40R609	0150-3375	5		RESISTOR-ZERO OHMS 22 AWG LEAD DIA	28480	0150-3375
A40RP001	1810-0280	8	6	NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP100	1810-0280	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP101	1810-0280	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP102	1810-0280	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP103	1810-0280	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP104	1810-0280	8		NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
A40RP109	1810-0279	5	1	NETWORK-RES 10-SIP4.7K OHM X 9	01121	210A472
A40TP001	1251-0600	0	21	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP002	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP003	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP004	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP100	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP101	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP200	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP201	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP202	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP300	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP400	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP401	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP402	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP403	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP404	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP405	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP501	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600
A40TP502	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	28480	1251-0600

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A401P600	1251-0600	0		CONNECTOR-SCL CNT PIN 1.14-MM BSC-SZ SQ	20480	1251-0600
A40U001	1626-0138	8	1	IC COMPARATOR GP QUAD 14-DIP-P P&G	01295	LM339N
A40U002	1813-0130	3	1	IC OSC HYBRID	34344	K1140A-16.0MHZ
A40U003	1820-2408	3	2	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A40U004	1820-2096	9	1	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A40U005	1820-0668	7	1	IC BFR TTL NON-INV HEX 1-INP	01295	SN7407N
A40U006	1820-2505	5	1	IC	20480	1820-2505
A40U007	1820-2772	8	1	IC FF TTL ALS J-K NEG-EDGE-TRIG	01295	SN74ALS112N
A40U008	1820-1433	6	1	IC SHIF-REGR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A40U009	1820-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A40U010	1820-3239	4	6	IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U100	1820-3230	3	4	IC TRANSCEIVER TTL ALS BUS OCTL	20480	1820-3230
A40U101	1820-1997	7	3	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A40U102	1820-3230	3		IC TRANSCEIVER TTL ALS BUS OCTL	20480	1820-3230
A40U103	1820-1492	7	1	IC BFR TTL LS INV HEX 1-INP	01295	SN74LS368AN
A40U104	1820-3230	3		IC TRANSCEIVER TTL ALS BUS OCTL	20480	1820-3230
A40U105	1820-3230	3		IC TRANSCEIVER TTL ALS BUS OCTL	20480	1820-3230
A40U106	03561-60320			IC PROGRAMMED PROM	20480	03561-60320
A40U200	03561-60321			IC PROGRAMMED PROM	20480	03561-60321
A40U201	03561-60322			IC PROGRAMMED PROM	20480	03561-60322
A40U202	03561-60323			IC PROGRAMMED PROM	20480	03561-60323
A40U203	03561-60324			IC PROGRAMMED PROM	20480	03561-60324
A40U300	03561-60325			IC PROGRAMMED PROM	20480	03561-60325
A40U301	03561-60326			IC PROGRAMMED PROM	20480	03561-60326
A40U302	03561-60327			IC PROGRAMMED PROM	20480	03561-60327
A40U303	03561-60326			IC PROGRAMMED PROM	20480	03561-60326
A40U304	03561-60329			IC PROGRAMMED PROM	20480	03561-60329
A40U305	03561-60330			IC PROGRAMMED PROM	20480	03561-60330
A40U306	03561-60331			IC PROGRAMMED PROM	20480	03561-60331
A40U400	1820-2408	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A40U401	1820-2657	0	2	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A40U402	1820-2774	0	1	IC GATE TTL ALS NAND DUAL 4 INP	01295	SN74ALS00N
A40U403	1820-2656	7	1	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A40U404	1820-1217	4	2	IC MUXR/DATA-SEL TTL LS 0-TO-1-LINE	01295	SN74LS151N
A40U405	1820-1217	4		IC MUXR/DATA-SEL TTL LS 0-TO-1-LINE	01295	SN74LS151N
A40U406	1820-2739	7	1	IC GATE TTL ALS NOR QUAD 2-INP	01295	SN74ALS02N
A40U407	1820-2657	8		IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A40U408	1820-1851	2	1	IC ENCDR TTL LS	01295	SN74LS148N
A40U409	1820-2635	2	1	IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS08N
A40U500	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U501	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U502	03561-60332			IC PROGRAMMED PROM	20480	03561-60332
A40U503	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U504	1820-3100	8	3	IC DCDR TTL ALS BIN 3-TO-0 LINE 3 INP	20480	1820-3100
A40U505	1820-1991			IC TTL LS	01295	SN74LS390PC
A40U600	03561-60333			IC PROGRAMMED PROM	20480	03561-60333
A40U601	03561-60334			IC PROGRAMMED PROM	20480	03561-60334
A40U602	03561-60335			IC PROGRAMMED PROM	20480	03561-60335
A40U603	03561-60336			IC PROGRAMMED PROM	20480	03561-60336
A40U604	1820-1991			IC TTL LS	01295	SN74LS390PC
A40U605	1820-3100	8		IC DCDR TTL ALS BIN 3-TO-0-LINE 3-INP	20480	1820-3100
A40U606	1820-3100	0		IC DCDR TTL ALS BIN 3-TO-0-LINE 3-INP	20480	1820-3100
A40U700	03561-60337			IC PROGRAMMED PROM	20480	03561-60337
A40U701	03561-60336			IC PROGRAMMED PROM	20480	03561-60336
A40U702	03561-60339			IC PROGRAMMED PROM	20480	03561-60339
A40U703	03561-60340			IC PROGRAMMED PROM	20480	03561-60340
A40U704	03561-60341			IC PROGRAMMED PROM	20480	03561-60341
A40U705	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U706	1820-3239	4		IC DRVR TTL ALS BUS OCTL	20480	1820-3239
A40U707	03561-60342			IC PROGRAMMED PROM	20480	03561-60342
A40U708	03561-60343			IC PROGRAMMED PROM	20480	03561-60343
A40W001	1251-4700	9	3	CONNECTOR 3-PIN M POST TYPE	20480	1251-4700
A40W002	1251-4700	9		CONNECTOR 3-PIN M POST TYPE	20480	1251-4700
A40W003	1251-4700	9		CONNECTOR 3-PIN M POST TYPE	20480	1251-4700
A40X003	1200-0638	7	1	SOCKET-IC 14-CNT DIP DIP SLDR	20480	1200-0638
A40Y200	0410-1503	1	1	CRYSTAL-QUARTZ 20.48 MHZ HC-18/U-HLDR	20480	0410-1503
				A40 MISCELLANEOUS PARTS		
	0340-0944	3	1	INSULATOR-IC NYLON BLACK	20480	0340-0944
	1250-0141	8	1	JUMPER-REM	20480	1250-0141
	1400-0116	8	1	PIN-CRV .062-IN-DIA .25-IN-LG STL	20480	1400-0116
	4040-0748	3	1	EXTR-PC BD BLK POLYC .062-BD-THKNS	20480	4040-0748
	4040-0752	9	1	EXTR-PC BD YEL POLYC .062-BD-THKNS	20480	4040-0752

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A50	03561-66550	3	1	LOCAL OSCILLATOR/NOISE SOURCE ASSEMBLY (REV B)	20400	03561-66550
A50C001	0160-3847	9	47	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C002	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C003	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C004	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C100	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C101	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C102	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C103	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C104	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C105	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C106	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C200	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C203	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C204	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C205	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C206	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C207	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C208	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C300	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C301	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C302	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C303	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C304	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C305	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C306	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C307	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C308	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C309	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C310	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C400	0160-4786	7	1	CAPACITOR-FXD 27PF +-.5% 100VDC CER	20400	0160-4786
A50C401	0160-4786	0	1	CAPACITOR-FXD 27PF +-.5% 100VDC CER	20400	0160-4786
A50C402	0160-5870	0	1	CAPACITOR-FXD 3600PF +-1% 50VDC CER	20400	0160-5870
A50C403	0160-5876	0	1	CAPACITOR-FXD 1300PF +-1% 50VDC CER	20400	0160-5876
A50C404	0160-4571	8	3	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A50C405	0160-5890	6	1	CAPACITOR-FXD 9100PF +-1% 50VDC CER	20400	0160-5890
A50C406	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A50C407	0160-5877	9	1	CAPACITOR-FXD 2400PF +-1% 50VDC CER	20400	0160-5877
A50C408	0160-5889	3	1	CAPACITOR-FXD 5600PF +-1% 50VDC CER	20400	0160-5889
A50C409	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A50C410	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C411	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C412	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C413	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C414	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C415	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C416	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C417	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C418	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C500	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C501	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C502	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C503	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C504	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C600	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C601	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C602	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C603	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C700	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C800	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C801	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C802	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C803	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C804	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C805	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C906	0160-3847	7	3	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C807	0180-2249	5		CAPACITOR-FXD 47UF+-10% 20VDC TA	56209	150D476X9020R2
A50C908	0160-3847	7		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A50C909	0180-2249	5		CAPACITOR-FXD 47UF+-10% 20VDC TA	56209	150D476X9020R2
A50C900	0180-2249	5		CAPACITOR-FXD 47UF+-10% 20VDC TA	56209	150D476X9020R2
A50C901	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C902	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C903	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C904	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C905	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C906	0160-4801			CAPACITOR-FXD 100 PF	20400	0160-4801
A50C907	0160-4791			CAPACITOR-FXD 1D PF	20400	0160-4791
A50C908	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571
A50C909	0160-4571			CAPACITOR-FXD .1 UF	20400	0160-4571

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A50C990	0160-5439	9	1	CAPACITOR-FXD 510PF +-5% 100VDC CER	20480	0160-5439
A50C991	0160-5405	9	1	CAPACITOR-FXD 130PF +-5% 100VDC CER	20480	0160-5405
A50C992	0160-5404	8	1	CAPACITOR-FXD 360PF +-5% 100VDC CER	20480	0160-5404
A50C993	0160-4011	9	1	CAPACITOR-FXD 270PF +-5% 100VDC CER	20480	0160-4011
A50CR400	1902-0951	5	1	DIODE-ZNR 5.1V 5% DO-35 PD=.4W TC=+.035%	20480	1902-0951
A50CR401	1902-0777	3	1	DIODE-ZNR 1N825 6.2V 5% DO 7 PD=.4W	04713	1N825
A50CR900	1901-0040	1	2	DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A50CR901	1901-0040	1		DIODE-SWITCHING 30V 50MA 2NS DO-35	20480	1901-0040
A50J001	1251-5205	7	1	CONNECTOR 2-PIN M POST TYPE	20480	1251-5205
A50J100	1251-5202	8	2	CONNECTOR 5-PIN M POST TYPE	20480	1251-5202
A50J200	1251-5202	8		CONNECTOR 5-PIN M POST TYPE	20480	1251-5202

See introduction to this section for ordering information  
 \*Indicates factory selected value



Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A50L400	03561-60304	3	1	FILTER IND 1	20400	03561-60304
A50L401	03561-60300	9	1	FILTER IND 2	20400	03561-60300
A50L402	9140-0748	0	4	INDUCTOR 250UH 25% .25DX.5LG Q=3	20400	9140-0748
A50L800	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	20400	9140-0748
A50L900	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	20400	9140-0748
A50L902	9100-3551			INDUCTOR 1μH	20400	9100-3551
A50L901	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	20400	9140-0748
A50R001	0683-4725	2	10	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R002	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R003	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R001	0698-6362	8	2	RESISTOR 1K .1% .125W F TC=0+-25	20400	0698-6362
A50R000	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R301	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R400	2100-3123	0	1	RESISTOR-TRMR 500 10% C SIDE ADJ 17-1RN	02111	43P501
A50R401	0757-0280	4	1	RESISTOR 825 1% .125W F TC=0+-100	24546	C4-1/B-T0-025R-F
A50R402	0698-6377	5	1	RESISTOR 230 1% .125W F TC=0+-25	20400	0698-6377
A50R403	0683-6015	5	1	RESISTOR 680 5% .25W FC TC=-400/+600	01121	CR6015
A50R404	0698-6360	6	1	RESISTOR 10K .1% .125W F TC=0+-25	20400	0698-6360
A50R405	0698-6320	8	1	RESISTOR 5K .1% .125W F TC=0+-25	03088	PHE55-1/R-T2 5001-B
A50R406	0757-0280	6	1	RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/B-T0-2001-F
A50R407	0698-6624	5	1	RESISTOR 2K .1% .125W F TC=0+-25	20400	0698-6624
A50R408	0698-6362	8		RESISTOR 1K .1% .125W F TC=0+-25	20400	0698-6362
A50R409	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R410	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R411	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R412	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R413	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R414	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R600	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R700	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R800	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R801	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R802	0683-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A50R900	0011-3657	0	2	RESISTOR 5.94K .1% .25W PWV TC=0+-10	20400	0011-3657
A50R901	0699-0123	9	1	RESISTOR 6.75K .1% .125W F TC=0+-25	20400	0699-0123
A50R902	0757-0280			RESISTOR 1K 1% .125W F TC=0+-25+-100	20400	0757-0280 0-101-F
A50R903	0011-3657	0		RESISTOR 5.94K .1% .25W PWV TC=0+-10	20400	0011-3657
A50R904	0757-0346			RESISTOR-10Ω	18480	0747-0346
A50R905	0757-0401			RESISTOR-FXD 100Ω	20400	0757-0401
A50R906	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50R907	0698-4381			RESISTOR-FXD 48.7Ω	20400	0698-4381
A50RP400	1010-0279	5	1	NETWORK-RES 10-SIP4.7K DIM X 9	01121	210A472
A50TP001	1251-0600	0	16	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP002	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP003	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP004	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP005	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP006	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP007	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP008	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP009	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP010	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP011	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP012	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP013	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP014	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP015	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50TP016	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A50U001	1020-1196	8	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS174N
A50U002	1020-1230	9	3	IC MUXR/DATA-SGL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS253N
A50U003	1020-2720	6	1	IC ADDR TTL LS QUAD	01295	SN74LS385N
A50U004	1020-1445	0	1	IC LCH TTL LS 4-BIT	01295	SN74LS375N
A50U005	1020-1441	6	6	IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U006	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U007	1020-2231	8	2	IC SHF REGR TTL LS COM CLEAR SERIAL-OUT	01295	SN74LS322AN
A50U008	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U009	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U010	1020-1470	1	2	IC MUXR/DATA-SGL TTL LS 2-TO-1-LINE QUAD	01295	SN74LS157N
A50U011	1020-2120	0	2	IC MULTR TTL LS 0-BIT	34335	AM25LS14DC
A50U012	1020-1730	6	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A50U013	03561-60310	1	1	PROGRAMMED PROM	20400	03561-60310
A50U014	1020-2657	8		IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A50U015	1020-1196	8		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS174N
A50U016	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U017	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A50U018	1020-2657	8	2	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A50U200	1020-2313	3	1	IC SHF-RCR TTL LS SERIAL-IN SERIAL-OUT	01295	SN74LS673N
A50U201	1020-2201	8		IC SHF-RCR TTL LS COM CLEAR SERIAL-OUT	01295	SN74LS322AN
A50U202	1020-1433	6	4	IC SHF-RCR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A50U203	1020-1433	6		IC SHF-RCR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A50U204	1020-1432	5	3	IC CNTR TTL LS BIN SYNCHRO POS-EDGE-TRIG	01295	SN74LS163AN
A50U205	1020-1432	5		IC CNTR TTL LS BIN SYNCHRO POS-EDGE-TRIG	01295	SN74LS163AN
A50U206	1020-1432	5		IC CNTR TTL LS BIN SYNCHRO POS-EDGE-TRIG	01295	SN74LS163AN
A50U207	1020-2635	2	2	IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS08N
A50U300	1020-1433	6		IC SHF-RCR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A50U301	1020-1470	1		IC MUXR/DATA-SEL TTL LS 2-TO-1-LINE QUAD	01295	SN74LS157N
A50U302	1020-1211	8	1	IC GATE TTL LS EXCL-OR QUAD 2-INP	01295	SN74LS06N
A50U303	1020-1997	7	8	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U304	1020-1230	9		IC MUXR/DATA SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS253N
A50U305	1020-2480	3	4	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A50U306	1020-1433	6		IC SHF-RCR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A50U307	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U308	1020-3230	3	2	IC TRANSCEIVER TTL ALS BUS OCTL	20400	1020-3230
A50U400	1026-1111	9	1	D/A 6-BIT 14-DIP-C CMOS	20400	1026-1111
A50U401	1026-1125	5	4	IC OP AMP PRON 0-TO-99 PKG	20400	1026-1125
A50U402	1020-1934	2	1	IC CONV 8-B-D/A 16-DIP-C PKG	06665	DAC-08EQ
A50U403	1026-1125	5		IC OP AMP PRON 0-TO-99 PKG	20400	1026-1125
A50U404	1026-1125	5		IC OP AMP PRON 0-TO-99 PKG	20400	1026-1125
A50U500	1020-2408	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A50U501	1020-3100	8	1	IC DCDR TTL ALS BIN 3-TO-0-LINE 3-INP	20400	1020-3100
A50U502	1020-1922	0	2	IC SHF-RCR TTL LS PRL-IN SERIAL-OUT	01295	SN74LS166N
A50U503	1020-1922	8		IC SHF-RCR TTL LS PRL-IN SERIAL-OUT	01295	SN74LS166N
A50U504	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U505	1020-0601	4	1	IC GATE TTL S NAND QUAD 2-INP	01295	SN74S00N
A50U506	03561-60312	3	1	PROGRAMMED PROM	20400	03561-60312
A50U507	03561-60311	2	1	PROGRAMMED PROM	20400	03561-60311
A50U600	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U601	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U602	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U603	1020-2405	4	3	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	34335	AM25LS2520DC
A50U604	1020-2405	4		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	34335	AM25LS2520DC
A50U605	1020-2405	4		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	34335	AM25LS2520DC
A50U606	T-55200	0	1	IC-PAL168BA	20400	T-55200
A50U700	03561-60313	4	1	PROGRAMMED PROM	20400	03561-60313
A50U701	03561-60314	5	1	PROGRAMMED PROM	20400	03561-60314
A50U702	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A50U703	1020-1431	4	1	IC CNTR TTL LS DECD SYNCHRO	01295	SN74LS162AN
A50U704	1020-2126	0		IC MULTR TTL LS 8-BIT	34335	AM25LS140C
A50U705	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U706	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A50U800	1020-2480	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A50U801	1020-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A50U802	1020-2408	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A50U803	1020-0697	2	1	IC DRV R TTL S NAND LINE DUAL 4-INP	01295	SN74ALS140N
A50U804	1020-3230	3		IC TRANSCEIVER TTL ALS BUS OCTL	20400	1020-3230
A50U805	1020-2540	6	1	IC-TMS 9914	20400	1020-2540
A50U806	1020-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A50U807	1020-1416	5	1	IC SCHMITT-TRIG TTL LS INV HEX 1-INP	01295	SN74LS14N
A50U808	1020-1230	9		IC MUXR/DATA-SEL TTL LS 4-TO-1-LINE DUAL	01295	SN74LS253N
A50U900	1020-2405	0	1	IC RCVR TTL LS BUS OCTL	01295	SN75160N
A50U901	1020-0224	1	1	IC OP AMP SPCL TO-99 PKG	27014	LH0002CH
A50U902	1026-1125	5		IC OP AMP PRON 0-TO-99 PKG	20400	1026-1125
A50U903	1020-2403	0	1	IC RCVR TTL LS BUS OCTL	01295	SN75161N
A50X001	4040-0740	3	1	EXTR-PC BD BLK POLYC .062-BD-THKNS	20400	4040-0740
A50X002	4040-0753	0	1	EXTR-PC BD GRN POLYC .062-BD-THKNS	20400	4040-0753
A50X002	1200-0638	7	1	SOCKET-IC 14-COMT DIP DIP-SLDR	20400	1200-0638
A50 MISCELLANEOUS PARTS						
	0515-0055	8	4	SCREW-MACH M3 X 0.5 6MM-LG PAN-HD	20400	0515-0055
	0590-1230	1	1	THREADED INCERT-STDF M3 X 0.5 12-MM-LG	20400	0590-1230
	1205-0011	0	1	HEAT SINK TO-S/ID-39-CS	20400	1205-0011
	2190-0004	9	4	WASHER-LK INTL T NO. 4 .115-IN-ID	20400	2190-0004
	03561-01226	4	1	SHLD, 50 BD SRCE	20400	03561-01226
	1400-0116	8	2	PIN-GRV .062-IN-DIA .25-IN-LG STL	20400	1400-0116

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A60	03561-66560	5	1	DIGITAL DISPLAY DRIVER ASSEMBLY (REVISION B)	20400	03561-66560
A60C001	0160-4571	8	56	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C002	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C003	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C004	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C005	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C006	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C007	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C008	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C009	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C010	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C011	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C012	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C100	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C101	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C102	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C103	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C200	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C201	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C202	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C203	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C204	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C300	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C301	0160-3847	9	5	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A60C302	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C303	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C304	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C400	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C401	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A60C402	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C406	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C407	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C500	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C501	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C502	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C503	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C504	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C505	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C506	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C507	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C508	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C509	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C510	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C511	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C600	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C601	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C602	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C603	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C700	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C701	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C702	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C703	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C800	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C801	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C802	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C903	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C901	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C903	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C906	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-4571
A60C907	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A60C908	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A60C709	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	20400	0160-3847
A60C710	0160-0291	3	1	CAPACITOR-FXD 1UF+-10% 35VDC TA	56209	150D105X903E A2
A60C711	0160-0309	4	1	CAPACITOR-FXD 4.7UF+-20% 10VDC TA	56209	150D475X0010A2
A60C712	0160-0374	3	1	CAPACITOR-FXD 10UF+-10% 20VDC TA	56209	150D106X9020B2
A60CR800	1901-0025	2	1	DIODE-GEN PRP 100V 200MA DO-7	20400	1901-0025
A60J100	1251-5286	0	1	CONNECTOR 4-PIN M POST TYPE	20400	1251-5286
A60J300	1251-4700	0	1	CONNECTOR 3-PIN M POST TYPE	20400	1251-4700
A60R001	0603-4725	2	2	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	0603-4725
A60R002	0603-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	0603-4725
A60R300	0603-1025	9	2	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	0603-1025
A60R500	0603-4705	8	3	RESISTOR 47 5% .25W FC TC=-400/+500	01121	0603-4705
A60R501	0603-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	0603-4705

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A60R532	0603-4705	8		RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A60R900	0603-1025	9		RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A60R901	0603-0225	5	1	RESISTOR 0.2K 5% .25W FC TC=-400/+700	01121	CB0225
A60R902	0603-2435	7	1	RESISTOR 24K 5% .25W FC TC=-400/+800	01121	CB2435
A60R993	0603-1535	6	1	RESISTOR 15K 5% .25W FC TC=-400/+800	01121	CB1535
A60RP001	1010-0450	4	1	NETWORK-RES 14-DIP47.0 OHM X 7	11236	760-3-R47
A60U001	1020-2656	7	4	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A60U002	1010-1775	4	16	IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U003	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U004	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U005	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U006	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U007	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U008	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U009	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U100	1020-1794	2	5	IC BFR TTL LS NON-INV OCTL	27014	DM01LS95N
A60U101	1020-2096	9	3	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A60U102	1020-1794	9		IC BFR TTL LS NON-INV OCTL	27014	DM01LS95N
A60U103	1020-2096	2		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A60U104	1020-1794	2		IC BFR TTL LS NON-INV OCTL	27014	DM01LS95N
A60U105	1020-1730	6	5	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A60U106	1020-1794	2		IC BFR TTL LS NON-INV OCTL	27014	DM01LS95N
A60U107	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A60U200	1020-2096	9		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN74LS393N
A60U201	1020-2400	3	4	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A60U202	1020-2400	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A60U203	1020-2400	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A60U204	1020-2775	1	1	IC GATE TTL ALS NAND TPL 3-INP	01295	SN74ALS10N
A60U205	1020-2739	7	1	IC GATE TTL ALS NOR QUAD 2-INP	01295	SN74ALS02N
A60U206	1020-1441	6	4	IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A60U207	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A60U208	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A60U209	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A60U300	1020-1211	8	1	IC GATE TTL LS EXCL-BR QUAD 2-INP	01295	SN74LS06N
A60U301	1020-1416	5	1	IC SCHMITT-TRIG TTL LS INV HEX 1-INP	01295	SN74LS14N
A60U302	1020-2400	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A60U303	1020-2635	2	4	IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A60U304	1020-2657	8	2	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A60U305	1020-0693	8	1	IC FF TTL S D-TYPE POS-EDGE-TRIG	01295	SN74S74N
A60U400	1020-2777	3	1	IC CNTR TTL ALS BIN SYNCHRO	01295	SN74ALS161N
A60U401	1020-2506	6	1	IC INV TTL F HEX	07263	74F04PC
A60U500	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U501	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U502	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U503	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U504	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U505	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U506	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U507	1010-1775	4		IC NMOS 16384 (16K) DYN RAM 120-NS 3-S	S4013	HM4816AP-4 (SELECTED)
A60U600	1020-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A60U601	1020-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A60U602	1020-1922	8	2	IC SHF-RCR TTL LS PRL-IN SERIAL-OUT	01295	SN74LS166N
A60U603	1020-1997	7	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A60U604	1020-1922	8		IC SHF-RCR TTL LS PRL-IN SERIAL-OUT	01295	SN74LS166N
A60U605	1020-1997	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
A60U606	1020-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A60U607	1020-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A60U700	1020-1441	6		IC ADDR TTL LS BIN FULL ADDR 4-BIT	01295	SN74LS283N
A60U701	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A60U702	1020-3100	8	2	IC DCDR TTL ALS BIN 3-TO-8-LINE 3-INP	20400	1020-3100
A60U703	1020-3375	9	3	IC CNTR TTL ALS BIN UP/DOWN SYNCHRO	20400	1020-3375
A60U704	1020-1217	4	2	IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN74LS151N
A60U705	1020-3375	9		IC CNTR TTL ALS BIN UP/DOWN SYNCHRO	20400	1020-3375
A60U706	1020-1794	2		IC BFR TTL LS NON-INV OCTL	27014	DM01LS95N
A60U707	1020-1975	1	1	IC SHF-RCR TTL LS NEG-EDGE-TRIG PRL-IN	01295	SN74LS165N
A60U800	1020-1730	6		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN74LS273N
A60U801	1020-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N
A60U802	1020-3375	9		IC CNTR TTL ALS BIN UP/DOWN SYNCHRO	20400	1020-3375
A60U803	1020-1433	6	1	IC SHF-RCR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN74LS164N
A60U804	1020-1217	4		IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN74LS151N
A60U805	1020-2657	8		IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A60U806	1020-3100	8		IC DCDR TTL ALS BIN 3-TO-8-LINE 3-INP	20400	1020-3100
A60U807	1020-2635	2		IC GATE TTL ALS AND QUAD 2-INP	01295	SN74ALS00N
A60U900	1020-2772	8	1	IC FF TTL ALS J-K NEG-EDGE-TRIG	01295	SN74ALS112N
A60U901	1020-2689	8	1	IC GATE TTL ALS AND TPL 3-INP	20400	1020-2689
A60U902	1020-2656	7		IC GATE TTL ALS NAND QUAD 2-INP	01295	SN74ALS00N

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A600903	1026-0205	0	1	IC TIMER TTL	10324	NE555A
A60Y400	1013-0393	0	1	XTAL-CLK-OSC	28406	1813 0393

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A65	03561-66565	0	1	CMOS/BUBBLE MEMORY ASSEMBLY (REVISION B) OPT 001	20480	03561-66565
A65BT100	1420-0278	7	1	BATTERY 3V .72A-HR LI/S-DJ8X W-FLEX	20480	1420-0278
A65C001	0100-2765	0	6	CAPACITOR-FXD 15UF+-20% 20VDC TA	20480	0100-2765
A65C002	0100-2765	0	0	CAPACITOR-FXD 15UF+-20% 20VDC TA	20400	0100-2765
A65C003	0160-3443	1	7	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C004	0160-3443	1	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C005	0160-2205	1	2	CAPACITOR-FXD 120PF +-5% 300VDC MICA	20480	0160-2205
A65C006	0160-2205	1	1	CAPACITOR-FXD 120PF +-5% 300VDC MICA	20480	0160-2205
A65C007	0160-3443	1	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C008	0100-2765	0	0	CAPACITOR-FXD 15UF+-20% 20VDC TA	20400	0100-2765
A65C009	0160-3443	1	0	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C100	0100-2765	0	1	CAPACITOR-FXD 15UF+-20% 20VDC TA	20480	0100-2765
A65C101	0160-3443	1	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C102	0160-3443	1	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20400	0160-3443
A65C103	0100-0197	0	1	CAPACITOR-FXD 2.2UF+-10% 20VDC TA	56269	150D25X9029A2
A65C104	0160-3047	9	10	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C105	0100-0499	3	1	CAPACITOR-FXD 10UF+-20% 20VDC TA	20480	0100-0499
A65C200	0100-2765	0	0	CAPACITOR-FXD 15UF+-20% 20VDC TA	20480	0100-2765
A65C201	0160-3443	1	1	CAPACITOR-FXD .1UF +80-20% 50VDC CER	20480	0160-3443
A65C202	0100-2249	5	2	CAPACITOR-FXD 47UF+-10% 20VDC TA	56209	150D47X9020R2
A65C203	0100-2249	5	0	CAPACITOR-FXD 47UF+-10% 20VDC TA	56209	150D47X9020R2
A65C204	0100-2765	0	0	CAPACITOR-FXD 15UF+-20% 20VDC TA	20480	0100-2765
A65C205	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C206	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C300	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C301	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C302	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C303	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C304	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C305	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65C306	0160-3047	9	9	CAPACITOR-FXD .01UF +100-0% 50VDC CER	20480	0160-3047
A65CR100	1901-0539	3	1	DIODE-SM SIG SCHOTTKY	20480	1901-0539
A65CR101	1902-3059	0	1	DIODE-ZNR 3.83V 5% DO-35 PD=.4W	20480	1902-3059
A65CR102	1901-0050	3	2	DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A65CR300	1901-0050	3	3	DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A65Q100	1853-0201	9	1	TRANSISTOR PNP 2N2907A SI TO-18 PD=400MW	04713	2N2907A
A65Q101	1854-0215	1	1	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A65Q102	1855-0269	7	2	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	18324	SD214
A65Q300	1855-0423	5	1	TRANSISTOR MOSFET N-CHAN E-MODE	17856	VN18KM
A65Q301	1855-0269	7	2	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	18324	SD214
A65R003	0698-7521	3	2	RESISTOR 5.1 5% .25W F TC=0+-100	11502	TF07-1/4-T0-5R1-J
A65R004	0698-7521	3	3	RESISTOR 5.1 5% .25W F TC=0+-100	11502	TF07-1/4-T0-5R1-J
A65R005	0757-0438	3	4	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A65R100	0683-4725	2	3	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A65R102	0698-5652	9	1	RESISTOR 500 1% .125W F TC=0+-100	24546	C4-1/8-T0-500R-F
A65R103	0698-3155	1	2	RESISTOR 4.64K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4641-F
A65R104	0683-4705	0	1	RESISTOR 47 5% .25W FC TC=-400/+500	01121	CB4705
A65R105	0757-0397	3	1	RESISTOR 60.1 1% .125W F TC=0+-100	24546	C4-1/8-T0-60R1-F
A65R106	0757-0417	0	1	RESISTOR 562 1% .125W F TC=0+-100	24546	C4-1/8-T0-562R-F
A65R107	0683-3335	0	1	RESISTOR 33K 5% .25W FC TC=-400/+800	01121	CB3335
A65R108	0683-5625	3	1	RESISTOR 5.6K 5% .25W FC TC=-400/+700	01121	CB5625
A65R109	0683-3925	2	1	RESISTOR 3.9K 5% .25W FC TC=-400/+700	01121	CB3925
A65R200	0757-0430	3	3	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A65R201	0683-1005	5	1	RESISTOR 10 5% .25W FC TC=-400/+500	01121	CR1005
A65R202	0757-0430	3	3	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A65R203	0757-0438	3	3	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A65R204	0683-1025	9	3	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CR1025
A65R205	0683-4725	2	1	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A65R300	0683-1025	9	1	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CR1025
A65R301	0698-3152	8	1	RESISTOR 3.40K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3401-F
A65R302	0698-3155	1	1	RESISTOR 4.64K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4641-F
A65R303	0683-4725	2	1	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A65R304	0683-1025	9	1	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CR1025
A65RP001	0810-0374	1	1	NETWORK-RES 0-SIP1.0K DIM X 4	01121	208B102
A65U001	1050-0001	7	2	TRANSISTOR ARRAY 14-PIN CER DIP	20480	1050-0001
A65U002	1020-2016	1	1	IC MISC CMOS	20400	1020-2016
A65U003	1020-2017	0	1	IC-INS 8039LN-11	20480	1020-2017
A65U004	1020-2007	0	1	IC BUBMEM 1048576 BRL-MEM	20480	1020-2007
A65U100	1050-0001	7	2	TRANSISTOR ARRAY 14-PIN CER DIP	20480	1050-0001

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A65U102	1020-2010	3	1	IC MISC TTL S	20480	1020-2010
A65U103	1010-3103	2	1	ICM 6264L155 C28	20400	1010-3103
A65U200	1020-2006	9	1	IC-BUBBLE MEMORY CONTROLLER	20480	1020-2006
A65U201	1020-2657	8	2	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A65U202	1020-3230	3	1	IC TRANSCEIVER TTL ALS BUS CCTL	20480	1020-3230
A65U203	1020-2757	9	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG OCTL	01295	SN74ALS74N
A65U300	1020-2520	4	1	IC DRVR TTL DUAL	01295	SN75463N
A65U301	1020-2657	0	1	IC GATE TTL ALS OR QUAD 2-INP	01295	SN74ALS32N
A65U302	1020-1246	9	1	IC GATE TTL LS AND QUAD 2-INP	01295	SN74LS09N
A65U303	1020-2634	1	1	IC INV TTL ALS HEX	01295	SN74ALS04N
A65U304	1020-2408	3	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN74ALS74N
A65U305	1020-1641	8	2	IC DRVR TTL LS BUS DRVR HEX 1-INP	01295	SN74LS365AN
A65U306	1020-1641	8	1	IC DRVR TTL LS BUS DRVR HEX 1-INP	01295	SN74LS365AN
A65X004	1200-1106	6	1	BUBBLE SOCKET	20480	1200-1106
A65X102	1200-1096	3	1	22 PIN DIP	20480	1200-1096
A65 MISCELLANEOUS PARTS						
	1480-0116	0	1	PTN-GRV .062-IN DIA .25-IN-LG STL	20480	1480-0116
	4040-0753	0	1	EXTR-PC BD GRN POLYC .062-BD-THKNS	20400	4040-0753
	4040-0754	1	1	EXTR-PC BD BLU POLYC .062-BD-THKNS	20480	4040-0754

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A66	03561-66566	1	1	CMOS MEMORY ASSEMBLY (REVISION B)	28480	03561-66566
A66BT100	1420-0278	7	1	BATTERY 3V .72A-HR LI/S-DIOX W-FLEX	28480	1420-0278
A66C104	0160-3847	9	3	CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A66C202	0180-2249	5	1	CAPACITOR-FXD 47UF+10% 26VDC TA	56287	150D476X901082
A66C205	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A66C206	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	28480	0160-3847
A66CR100	1901-0539	3	1	DIODE-SM SIG SCHOTTKY	28480	1901-0539
A66CR101	1902-3059	0	1	DIODE-ZNR 3.83V 5% DO-35 PD=.4W	28480	1902-3059
A66Q100	1053-0281	2	1	TRANSISTOR PNP 2N2907A SI TO-18 PD=400MW	04713	2N2907A
A66Q101	1054-0215	1	1	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A66Q102	1055-0269	7	2	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	10324	SD214
A66Q301	1055-0269	7		TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	10324	SD214
A66R100	0603-4725	2	2	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A66R102	0698-5052	9	1	RESISTOR 500 1% .125W F TC=0/+100	24546	C4 1/8-T0-500R-F
A66R103	0698-3155	1	2	RESISTOR 4.64K 1% .125W F TC=0/+100	24546	C4 1/8-T0-4641-F
A66R105	0757-0397	3	1	RESISTOR 68.1 1% .125W F TC=0/+100	24546	C4 1/8-T0-68R1-F
A66R106	0757-0417	0	1	RESISTOR 562 1% .125W F TC=0/+100	24546	C4 1/8-T0-562R-F
A66R302	0698-3155	1		RESISTOR 4.64K 1% .125W F TC=0/+100	24546	C4 1/8-T0-4641-F
A66R303	0603-4725	2		RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CB4725
A66U100	1020-1201	2	1	IC DCDR TTL LS 2-TO-4-LINE DUAL 2-INP	01295	SN74LS139N
A66U101	1020-3239	4	1	IC DRVR TTL ALS BUS OCTL	28480	1020-3239
A66U103	1018-3103	2	1	ICM 6264L155 C28	28480	1018-3103
A66U202	1020-3238	3	1	IC TRANSCEIVER TTL ALS BUS OCTL	28480	1020-3238
A66U203	1020-2757	9	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG OCTL	01295	SN74ALS574N
A66 MISCELLANEOUS PARTS						
	1400-0116	0	1	PIN-GRV .062-IN-DIA .25-IN-LG STL	28480	1400-0116
	4040-0753	0	1	EXTR-PC BD GRN POLYC .062-BD-THKNS	28480	4040-0753
	4040-0754	1	1	EXTR-PC BD BLU POLYC .062-PD-THKNS	28480	4040-0754

See introduction to this section for ordering information  
 \*Indicates factory selected value



Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A70	03561-66570	7	1	POWER SUPPLY PWM ASSEMBLY (REVISION B)	20480	03561-66570
A70C001	0160-4791	4	3	CAPACITOR-FXD 10PF +-5% 100VDC CER 0+-30	20480	0160-4791
A70C002	0160-2220	8	2	CAPACITOR-FXD 2700PF +-5% 300VDC MICA	20480	0160-2220
A70C003	0160-4602	2	1	CAPACITOR-FXD 1000PF +-2.5% 160VDC POLYP	20480	0160-4602
A70C004	0160-2220	8		CAPACITOR-FXD 2700PF +-5% 300VDC MICA	20480	0160-2220
A70C005	0160-0159	0	1	CAPACITOR-FXD 6000PF +-10% 200VDC POLYE	20480	0160-0159
A70C006	0160-4012	0	1	CAPACITOR-FXD 220PF +-5% 100VDC CER	20480	0160-4012
A70C007	0160-0127	2	1	CAPACITOR-FXD 1UF +-20% 25VDC CER	20480	0160-0127
A70C101	0160-4571	0	0	CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C102	0100-0100	3	1	CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56207	1500475X03502
A70C103	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C104	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C200	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C201	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C400	0160-0194	3	2	CAPACITOR-FXD .015UF +-10% 200VDC POLYE	20480	0160-0194
A70C401	0160-0194	3		CAPACITOR-FXD .015UF +-10% 200VDC POLYE	20480	0160-0194
A70C402	0160-4535	4	1	CAPACITOR-FXD 1UF +-10% 50VDC CER	20480	0160-4535
A70C500	0160-4791	4		CAPACITOR-FXD 10PF +-5% 100VDC CER 0+-30	20480	0160-4791
A70C501	0160-4791	4		CAPACITOR-FXD 10PF +-5% 100VDC CER 0+-30	20480	0160-4791
A70C502	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C503	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C504	0160-4571	0		CAPACITOR-FXD .1UF +00-20% 50VDC CER	20480	0160-4571
A70C600	0160-0200	0	2	CAPACITOR-FXD 390PF +-5% 300VDC MICA	72136	DM15F391J03000V1CR
A70C601	0160-0200	0		CAPACITOR-FXD 390PF +-5% 300VDC MICA	72136	DM15F391J03000V1CR
A70C602	0160-4281	7	1	CAPACITOR-FXD 2200PF +-20% 250VAC(RMS)	C0633	PME271Y428
A70C700	0160-4702	7	2	CAPACITOR-FXD 1UF +-10% 400VDC MET-POLYP	20480	0160-4702
A70C701	0160-4702	7		CAPACITOR-FXD 1UF +-10% 400VDC MET-POLYP	20480	0160-4702
A70CR001	1990-0486	6	4	LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5082-4604
A70CR002	1990-0486	6		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5082-4604
A70CR003	1990-0486	6		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5082-4604
A70CR004	1990-0486	6		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5082-4604
A70CR005	1901-0050	3	22	DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR006	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR100	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR101	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR103	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR201	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR202	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR203	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR204	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR206	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR207	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR208	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR209	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR400	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR401	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR402	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR403	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR404	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR405	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR406	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR500	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70CR501	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	20480	1901-0050
A70J300	1251-5347	2	1	CONNECTOR 5-PIN M POST TYPE	20480	1251-5347
A70J700	1251-4348	1	1	CONNECTOR 6-PIN M POST TYPE	20480	1251-4348
A70L100	9140-0740	0	1	INDUCTOR 250UH 25% .25DX.5LG Q=3	20480	9140-0740
A70Q001	1053-0036	2	6	TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q002	1053-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q003	1053-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q101	1053-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q102	1054-0215	1	3	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A70Q300	1055-0536	1	2	TRANSISTOR	20480	1055-0536
A70Q400	1053-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q500	1054-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A70Q501	1053-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	20480	1053-0036
A70Q502	1054-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A70Q700	1055-0536	1		TRANSISTOR	20480	1055-0536
A70R001	0603-1225	1	4	RESISTOR 1.2K 5% .25W FC TC=-400/+700	01121	CR1225
A70R002	0603-1225	1		RESISTOR 1.2K 5% .25W FC TC=-400/+700	01121	CR1225
A70R003	0603-1225	1		RESISTOR 1.2K 5% .25W FC TC=-400/+700	01121	CR1225
A70R004	0603-1225	1		RESISTOR 1.2K 5% .25W FC TC=-400/+700	01121	CR1225
A70R005	0603-1045	3	3	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CR1045

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A70R006	0698-3279	0	2	RESISTOR 4.59K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A70R007	0698-4501	3	1	RESISTOR 57K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5982-F
A70R008	0698-3161	9	1	RESISTOR 38.3K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3832-F
A70R009	0757-0445	2	1	RESISTOR 13K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1302-F
A70R010	0698-4477	2	1	RESISTOR 10.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1052-F
A70R011	0698-4488	5	1	RESISTOR 26.7K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2672-F
A70R012	0698-3515	7	1	RESISTOR 5.9K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5901-F
A70R013	0150-3375	5	3	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	0150-3375
A70R014	0683-5625	3	3	RESISTOR 5.6K 5% .25W FC TC=-400/+700	01121	0683-5625
A70R015	0757-0401	0	3	RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A70R016	0757-0433	6	2	RESISTOR 3.32K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3321-F
A70R017	0757-0442	9	3	RESISTOR 16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1602-F
A70R018	0683-1045	3	1	RESISTOR 100K 5% .25W FC TC=-400/+600	01121	0683-1045
A70R019	0683-1035	0	1	RESISTOR 51K 5% .25W FC TC=-400/+600	01121	0683-1035
A70R020	0757-0439	3	6	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R103	0757-0290	5	2	RESISTOR 6.19K 1% .125W F TC=0+-100	19701	MF4C1/8-T0-6191-F
A70R104	0757-0453	2	1	RESISTOR 30.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3012-F
A70R105	0757-0200	7	2	RESISTOR 5.62K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5621-F
A70R106	0683-2035	3	1	RESISTOR 20K 5% .25W FC TC=-400/+600	01121	0683-2035
A70R107	0757-0444	1	1	RESISTOR 12.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1212-F
A70R108	0757-0442	9	1	RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1002-F
A70R109	0683-3325	6	1	RESISTOR 3.3K 5% .25W FC TC=-400/+700	01121	0683-3325
A70R110	0683-1045	3	1	RESISTOR 100K 5% .25W FC TC=-400/+600	01121	0683-1045
A70R111	0683-1035	1	2	RESISTOR 10K 5% .25W FC TC=-400/+700	01121	0683-1035
A70R112	0683-1025	9	3	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	0683-1025
A70R113	0150-3375	5	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	0150-3375
A70R114	0698-3157	3	2	RESISTOR 19.6K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1962-F
A70R115	0757-0280	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A70R116	0698-3279	0	1	RESISTOR 4.59K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4991-F
A70R117	0683-1035	1	1	RESISTOR 10K 5% .25W FC TC=-400/+700	01121	0683-1035
A70R118	0698-4467	0	1	RESISTOR 1.05K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1051-F
A70R200	0699-1167	3	2	RESISTOR	20480	0699-1167
A70R201	0699-1168	4	2	RESISTOR	20480	0699-1168
A70R202	0699-1167	3	1	RESISTOR	20480	0699-1167
A70R203	0699-1168	4	1	RESISTOR	20480	0699-1168
A70R400	0683-5625	3	1	RESISTOR 5.6K 5% .25W FC TC=-400/+700	01121	0683-5625
A70R401	0757-0450	7	2	RESISTOR 51.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5112-F
A70R402	0150-3375	5	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20480	0150-3375
A70R403	0757-0290	5	1	RESISTOR 6.19K 1% .125W F TC=0+-100	19701	MF4C1/8-T0-6191-F
A70R404	0757-0442	9	1	RESISTOR 10K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1002-F
A70R405	0757-0200	7	1	RESISTOR 5.62K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5621-F
A70R406	0683-5125	8	3	RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	0683-5125
A70R407	0757-0451	0	1	RESISTOR 24.3K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2432-F
A70R408	0698-0002	7	2	RESISTOR 464 1% .125W F TC=0+-100	24546	C4-1/8-T0-4640-F
A70R409	0757-0440	7	1	RESISTOR 7.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-7501-F
A70R410	0757-0401	0	1	RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A70R411	0698-3572	6	1	RESISTOR 60.4K 1% .125W F TC=0+-100	24546	C4-1/8-T0-6042-F
A70R412	0757-0401	0	1	RESISTOR 100 1% .125W F TC=0+-100	24546	C4-1/8-T0-101-F
A70R413	0698-3271	2	1	RESISTOR 115K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1153-F
A70R414	0698-0082	7	1	RESISTOR 464 1% .125W F TC=0+-100	24546	C4-1/8-T0-4640-F
A70R415	0757-0450	7	1	RESISTOR 51.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5112-F
A70R416	0683-1025	9	1	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	0683-1025
A70R417	0683-1025	9	1	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	0683-1025
A70R418	0683-5645	7	1	RESISTOR 560K 5% .25W FC TC=-800/+900	01121	0683-5645
A70R419	0757-0438	3	1	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R420	0757-0439	3	1	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R421	0757-0471	4	1	RESISTOR 182K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1823-F
A70R422	0698-3558	8	1	RESISTOR 4.02K 1% .125W F TC=0+-100	24546	C4-1/8-T0-4021-F
A70R423	0757-0283	6	6	RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R424	0698-3157	3	1	RESISTOR 19.6K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1962-F
A70R425	0757-0279	0	1	RESISTOR 3.16K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3161-F
A70R426	0698-4431	8	2	RESISTOR 2.05K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2051-F
A70R427	0698-3519	1	1	RESISTOR 12.4K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1242-F
A70R428	0698-0004	9	1	RESISTOR 2.15K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2151-F
A70R429	0698-4431	0	1	RESISTOR 2.05K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2051-F
A70R430	0757-0438	3	1	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R431	0698-4493	2	1	RESISTOR 34K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3402-F
A70R432	0683-2725	8	1	RESISTOR 2.7K 5% .25W FC TC=-400/+700	01121	0683-2725
A70R433	0757-0438	3	1	RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R500	0683-5125	8	1	RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	0683-5125
A70R501	0757-0403	2	1	RESISTOR 121 1% .125W F TC=0+-100	24546	C4-1/8-T0-1211-F
A70R502	0757-0433	8	1	RESISTOR 3.32K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3321-F
A70R503	0698-4445	4	1	RESISTOR 5.76K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5761-F
A70R504	0683-5625	3	1	RESISTOR 5.6K 5% .25W FC TC=-400/+700	01121	0683-5625
A70R505	0698-4510	4	1	RESISTOR 84.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-8452-F

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A70R506	0698-4202	1	2	RESISTOR 0.07K 1% .125W F TC=0+-100	24546	C4-1/8-T0-0871-F
A70R507	0757-0203	6		RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R508	0698-0063	4	1	RESISTOR 5.23K 1% .125W F TC=0+-100	91637	CMF-1/8-T1-5231-F
A70R509	0757-0203	6		RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R510	0757-0203	6		RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R511	0698-4202	1		RESISTOR 8.87K 1% .125W F TC=0+-100	24546	C4-1/8-T0-0871-F
A70R512	0757-0430	3		RESISTOR 5.11K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5111-F
A70R513	0757-0454	3	1	RESISTOR 33.2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3321-F
A70R514	0757-0203	6		RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R515	0698-4432	9	1	RESISTOR 2.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2101-F
A70R516	0757-0203	6		RESISTOR 2K 1% .125W F TC=0+-100	24546	C4-1/8-T0-2001-F
A70R517	0698-5125	8		RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CB5125
A70R600	0698-3613	6	2	RESISTOR 39 5% 2W MO TC=0+-200	27167	FP42-2-T00-39R0-J
A70R601	0698-3613	6		RESISTOR 39 5% 2W MO TC=0+-200	27167	FP42-2-T00-39R0-J
A70T200	9140-0820	7	1	GATE DRIVE TMR	20480	9140-0820
A70T600	9100-4348	0	1	CURR. SENSE INDC	20480	9100-4348
A70TP100	1251-0600	0	9	CONNECTOR-SGL CONT PIN 1.14-MM BSC-SZ SQ	20480	1251-0600
A70TP101	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A70TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP103	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP104	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP400	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP401	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70TP501	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20480	1251-0600
A70U001	1026-1040	3	1	IC V RCLTR-SWG 4.85/5.15V 10-DIP-C PKG	20480	1026-1040
A70U002	1026-0340	4	2	IC OP AMP LOW-BIAS-H-IMPD TO-99 PKG	20480	1026-0340
A70U003	1026-0340	4		IC OP AMP LOW-BIAS-H-IMPD TO-99 PKG	20480	1026-0340
A70U100	1020-1200	9	1	IC DRVR TTL CLOCK DRVR TTL-TO-MOS 1-INP	04713	MMH0026CL
A70U101	1026-0065	0	1	IC COMPARATOR PRCN 8-DIP-P PKG	56545	UPC311C
A70U102	1026-0138	8	3	IC COMPARATOR GP QUAD 14-DIP-P PKG	01295	LM339N
A70U400	1020-1145	7	1	IC BFR CMOS INV HEX 1-INP	3L585	CD4049UBC
A70U401	1026-0601	0	1	IC OP AMP PRCN TO-99 PKG	06665	OP-16FJ
A70U402	1026-0138	8		IC COMPARATOR GP QUAD 14-DIP-P PKG	01295	LM339N
A70U500	1020-2228	9	1	IC LCH CMOS HAND R-S QUAD	04713	KC14044BCP
A70U501	1058-0054	4	1	TRANSISTOR APRAY 16-PIN PLSTC DIP	20480	1058-0054
A70U502	1026-0138	8		IC COMPARATOR GP QUAD 14-DIP-P PKG	01295	LM339N
A70U503	1990-0545	8	1	OPTO-ISOLATOR LED-PDIO/XSTR IF=40MA-MAX	20480	5082-4371
				A70 MISCELLANEOUS PARTS		
				NUT-HEX DIL-CHAM M3 X 0.5 2.4MM-THK	00000	ORDER BY DESCRIPTION
				THREADED INSERT-STDF 4-40 .25-IN-LG SST	20480	0590-0075
				WASHER-LK INTL T NO. 4 .115-IN-ID	20480	2190-0004
				WASHER-LK EXT T NO. 6 .141-IN-ID	20480	2190-0000
				SCREW-MACH 4-40 .375-IN-LG RDC-HD-SLT	00000	ORDER BY DESCRIPTION
				WASHER-SHLDR NO. 4 .12-IN-ID .312-IN-OD	20480	3050-0004
				WASHER-FL MTLG NO. 6 .166-IN-ID	20480	3050-0054
				EXTR-PC BD BLK POLYC .062-OD-THKNS	20480	4040-0740
				EXTR-PC BD V10 POLYC .062-OD-THKNS	20480	4040-0755
				HEAT SINK SGL TO-3-CS	20480	1205-0495
				PIN-GRV	20480	1480-0116

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A71	03561-66571	8	1	POWER SUPPLY TRANSFORMER ASSEMBLY (REVISION B)	20400	03561-66571
A71C001	0160-4571	0	2	CAPACITOR-FXD .10UF +0-20% 50VDC CER	20400	0160-4571
A71C002	0100-2003	7	2	CAPACITOR-FXD 100UF+50-10% 50VDC AL	20400	0100-2003
A71C003	0160-0576	5	2	CAPACITOR-FXD .10UF +-20% 50VDC CER	20400	0160-0576
A71C004	0160-4571	0	8	CAPACITOR-FXD .10UF +0-20% 50VDC CER	20400	0160-4571
A71C005	0160-4325	0	1	CAPACITOR-FXD .33UF +-5% 50VDC MET-POLYC	20400	0160-4325
A71C006	0160-4032	4	6	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C007	0100-1046	6	2	CAPACITOR-FXD 2.2UF+-10% 35VDC TA	56289	150D225X9035D2
A71C008	0100-2003	7	2	CAPACITOR-FXD 100UF+50-10% 50VDC AL	20400	0100-2003
A71C009	0160-0576	5	2	CAPACITOR-FXD .10UF +-20% 50VDC CER	20400	0160-0576
A71C010	0100-2351	0	1	CAPACITOR-FXD 2000UF+75-10% 50VDC AL	20400	0100-2351
A71C200	0160-4032	4	4	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C201	0100-1046	6	2	CAPACITOR-FXD 2.2UF+-10% 35VDC TA	56289	150D225X9035D2
A71C202	0160-3455	5	2	CAPACITOR-FXD 470PF +-10% 1KVDC CER	20400	0160-3455
A71C203	0160-4032	4	4	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C204	0160-4032	4	4	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C205	0160-4032	4	4	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C300	0160-4032	4	4	CAPACITOR-FXD .01UF +-10% 100VDC CER	20400	0160-4032
A71C301	0160-3455	5	2	CAPACITOR-FXD 470PF +-10% 1KVDC CER	20400	0160-3455
A71CR001	1901-0743	1	2	DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A71CR002	1901-0364	2	1	DIODE-PWR RECT 200V 1A	20400	1901-0364
A71CR003	1901-0743	1	1	DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A71CR100	1906-0278	7	1	DIODES	20400	1906-0278
A71CR200	0037-0193	7	1	SUPPRESSOR-VOLTAGE AXIAL LEAD; PEAK	20400	0037-0193
A71CR201	1901-0050	3	3	DIODE-SWITCHING 80V 200MA 2WS DO-35	20400	1901-0050
A71CR202	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR203	1901-0050	3	3	DIODE-SWITCHING 80V 200MA 2WS DO-35	20400	1901-0050
A71CR204	1901-1108	4	2	DIODE-SWITCHING 300V 3A 50NS	20400	1901-1108
A71CR205	1901-0050	3	3	DIODE-SWITCHING 80V 200MA 2WS DO-35	20400	1901-0050
A71CR206	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR207	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR208	1901-1108	4	4	DIODE-SWITCHING 300V 3A 50NS	20400	1901-1108
A71CR209	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR300	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR301	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR302	1901-1111	2	2	DIODE-PWR RECT 150V 6A 30NS	20400	1901-1111
A71CR303	1901-1109	5	2	DIODE-SWITCHING 400V 3A 50NS	20400	1901-1109
A71CR304	1901-1111	2	2	DIODE-PWR RECT 150V 6A 30NS	20400	1901-1111
A71CR305	1901-1109	5	2	DIODE-SWITCHING 400V 3A 50NS	20400	1901-1109
A71CR306	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71CR307	1901-1110	0	8	DIODE-SWITCHING 300V 1A 50NS	20400	1901-1110
A71L001	9140-0029	0	1	40UH TOROID	20400	9140-0029
A71L00A	9170-0847	3	3	CORE-SHIELDING BEAD	02114	56-590-65/30 PARYLENE COATED
A71L001	9170-0847	3	3	CORE-SHIELDING BEAD	02114	56-590-65/30 PARYLENE COATED
A71L001	9170-0847	3	3	CORE-SHIELDING BEAD	02114	56-590-65/30 PARYLENE COATED
A71L001A	9170-0847	3	4	CORE-SHIELDING BEAD	02114	56-590-65/30 PARYLENE COATED
A71Q001	1053-0036	2	1	TRANSISTOR PNP SI PD=310MW FT=250MHZ	20400	1053-0036
A71R001	2100-3273	1	1	RESISTOR-TMR 2K 10% C SIDE-ADJ 1-TRN	20400	2100-3273
A71R002	0757-0270	5	1	RESISTOR 6.19K 1% .125W F TC=0+-100	19701	MF401/8-T0-6191-F
A71R003	0698-4408	9	2	RESISTOR 124 1% .125W F TC=0+-100	24546	C4-1/8-T0-124R-F
A71R004	0698-4400	9	2	RESISTOR 124 1% .125W F TC=0+-100	24546	C4-1/8-T0-124R-F
A71R005	0698-4196	2	2	RESISTOR 1.07K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1071-F
A71R006	0757-0420	3	1	RESISTOR 750 1% .125W F TC=0+-100	24546	C4-1/8-T0-751-F
A71R007	0698-3156	2	1	RESISTOR 14.7K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1472-F
A71R008	0603-4725	2	1	RESISTOR 4.7K 5% .25W FC TC=-400/+700	01121	CR4725
A71R009	0698-4472	2	1	RESISTOR 10.5K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1052-F
A71R010	0603-4705	0	1	RESISTOR 47 5% .25W FC TC=-400/+500	01121	CR4705
A71R011	0757-0458	7	1	RESISTOR 51.1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-5112-F
A71R100	0698-4196	2	2	RESISTOR 1.07K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1071-F
A71R101	0150-3375	5	2	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20400	0150-3375
A71R200	63312-00001	4	1	R/F .005	20400	63312-00001
A71R201	0757-0289	2	1	RESISTOR 13.3K 1% .125W F TC=0+-100	19701	MF401/8-T0-1332-F
A71R202	0757-0273	0	1	RESISTOR 3.01K 1% .125W F TC=0+-100	24546	C4-1/8-T0-3011-F
A71R203	0698-3609	4	1	RESISTOR 22 5% 2W MO TC=0+-200	27167	FP42-2-T00-22R0-J
A71R204	0603-4735	4	2	RESISTOR 47K 5% .25W FC TC=-400/+800	01121	CR4735
A71R205	0757-0286	3	1	RESISTOR 1K 1% .125W F TC=0+-100	24546	C4-1/8-T0-1001-F
A71R206	0603-4735	4	2	RESISTOR 47K 5% .25W FC TC=-400/+800	01121	CR4735
A71R207	0150-3375	5	2	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20400	0150-3375
A71R208	0698-3631	0	2	RESISTOR 330 5% 2W MO TC=0+-200	20400	0698-3631
A71R300	0698-3631	0	8	RESISTOR 330 5% 2W MO TC=0+-200	20400	0698-3631

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A71S100	3103-0114	0	1	SWITCH-THRM FXD +26C 3A CL-CN-RISE	28480	3103-0114
A71T300	9100-4340	2	1	TRANSFORMER-PWR (MISC ITEM)	28480	9100-4340
A71U031	1026-0393	7	1	IC V RGLTR TO-220	27314	LM317T
A71U100	1026-0527	9	1	IC 337 V RGLTR TO-220	27014	LM357C
A71U200	1026-0130	8	1	IC COMPARATOR GP QUAD 14-DIP-P PKG	01295	LM339N
A71W071	03561-61604	8	1	CABLE ASSY 70/71	28480	03561-61604
				A71 MISCELLANEOUS PARTS		
	0515-0055	8	2	SCREW-MACH M3 X 0.5 6MM-LG PAN-HD	28480	0515-0055
	0535-0004	9	4	NUT-HEX DEL CHAM M3 X 0.5 2.4MM-THK	00000	ORDER BY DESCRIPTION
	1205-0560	4	1	HEAT-SINK	28480	1205-0560
	1480-0116	0	1	PIN-GRV .062-IN-DIA .25-IN-LG STL	28480	1480-0116
	2190-0004	9	5	WASHER-LK INTL T NO. 4 .115-IN-ID	28480	2190-0004
	2190-0005	0	1	WASHER-LK EXT T NO. 4 .116-IN-ID	28480	2190-0005
	2190-0008	3	1	WASHER-LK EXT T NO. 6 .141-IN-ID	28480	2190-0008
	2420-0003	7	1	NUT-HEX-DEL-CHAM 6-32-THD .094-IN-THK	28480	2420-0003
	4040-0749	4	1	EXTR-PC BD BPN POLYC .062-BD-THKNS	28480	4040-0749
	4040-0755	2	1	EXTR-PC BD VIO POLYC .062-BD-THKNS	28480	4040-0755
	1205-0495	4	1	HEAT SINK	28480	1205-0495

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A72	03561-66572	9	1	POWER SUPPLY FILTER ASSEMBLY (REVISION A)	28480	03561-66572
A72C025	0100-3382	9	8	CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C026	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C027	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C028	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C029	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C030	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C031	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72C032	0100-3382	9		CAPACITOR-FXD 440UF+100-10% 50VDC AL	28480	0100-3382
A72CR040	1902-0679	4	2	DIODE-ZNR 17.4V 5% DO-15 PD=1W TC=+.068%	28480	1902-0679
A72CR041	1902-0679	4		DIODE-ZNR 17.4V 5% DO-15 PD=1W TC=+.068%	28480	1902-0679
A72CR043	1902-0555	5	1	DIODE-ZNR 13V 5% PD=1W IR=5UA	28480	1902-0555
A72CR045	1902-0654	5	1	DIODE-ZNR 33V 5% PD=1W IR=5UA	28480	1902-0654
A72CR047	1902-0556	6	2	DIODE-ZNR 20V 5% PD=1W IR=5UA	28480	1902-0556
A72CR049	1902-0556	6		DIODE-ZNR 20V 5% PD=1W IR=5UA	28480	1902-0556
A72CR051	1902-0652	3	1	DIODE-ZNR 11V 5% PD=1W IR=5UA	28480	1902-0652
A72L003	9140-0830	1	3	1040UH -12	28480	9140-0830
A72L004	9140-0830	1		1040UH -12	28480	9140-0830
A72L005	9140-0832	3	1	765UH +8	28480	9140-0832
A72L006	9140-0831	2	1	4240UH I+24	28480	9140-0831
A72L007	9140-0833	4	2	INDUCTOR	28480	9140-0833
A72L000	9140-0833	4		INDUCTOR	28480	9140-0833
A72L009	9140-0830	1		1040UH I+24	28480	9140-0830
A72LS001	0960-0483	9	1	ALARM-AUDIBLE RATED INPUT: 0.05W	28480	0960-0483
				A72 MISCELLANEOUS PARTS		
	1400-0116	8	1	PIN-GRV .062-IN-DIA .25-IN LG STL	28480	1400-0116
	3050-0696	2	1	WASHER FL NH 1/4 IN .3-IN-ID .535-IN-OD	28480	3050-0696
	3050-1082	8	1	WASHER FL NH NO. 6 .152-IN-ID .29-IN-OD	28480	3050-1082
	4040-0750	7	1	EXTR-PC BD RED POLYC .062 BD-THKNS	28480	4040-0750
	4040-0755	2	1	EXTR-PC BD VIO POLYC .062 BD-THKNS	28480	4040-0755
	5020-0387	1	1	MYLAR DISC	28480	5020-0387
	9170-1237	7	1	MOUNTING CLIP	28480	9170-1237

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A00	03561-66500	7	1	KEYBOARD ASSEMBLY (REVISION A)	20400	03561-66500
A00DS001	1990-0487	7	14	LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS002	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS003	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS004	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS005	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS006	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS007	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS008	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS009	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS010	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS011	1990-0486	6	1	LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4604
A00DS012	1990-0485	5	1	LED-LAMP LUM-INT=000UCD IF=30MA-MAX	20400	5002-4504
A00DS013	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS014	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS015	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504
A00DS016	1990-0487	7		LED-LAMP LUM-INT=1MCD IF=20MA-MAX BVR=5V	20400	5002-4504

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
AB1	03561-66581	0	1	KEYBOARD DRIVER ASSEMBLY (REVISION A)	28480	03561-66581
AB1C001	0160-4571	8	7	CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C002	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C003	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C004	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C005	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C006	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1C007	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB1RP001	1010-0320	0	1	NETWORK-RES 10-SIP10.0K OHM X 9	01121	210A103
AB1RP002	1010-0325	2	2	NETWORK-RES 16-DIP150.0 OHM X 8	01121	316B151
AB1RP003	1010-0325	2		NETWORK-RES 16-DIP150.0 OHM X 8	01121	316B151
AB1U001	1020-2951	5	1	IC DRVP TTL ALS BUS OCTL	28480	1020-2951
AB1U002	1020-1927	7	3	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
AB1U003	1020-1927	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
AB1U004	1020-1927	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	01295	SN74LS374N
AB1U005	1020-3238	3	1	IC TRANSCEIVER TTL ALS BUS OCTL	28480	1020-3238
AB1U006	1020-3376	0	2	IC INV TTL ALS HEX	28480	1020-3376
AB1U007	1020-3100	8	1	IC DCDR TTL ALS BIN 3-TO-B-LINE 3-IMP	28480	1020-3100
AB1U008	1020-3376	0		IC INV TTL ALS HEX	28480	1020-3376
AB1W081	03561-61605	9	1	CABLE ASSY	28480	03561-61605

See introduction to this section for ordering information  
 \*Indicates factory selected value



Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
AR2	03561-66562	1	1	REAR PANEL ASSEMBLY (REVISION B)	28480	03561-66562
AB2C001	0160-4571	8	6	CAPACITOR-FXD .1UF +80-20% 50VDC CER	28408	0160-4571
AB2C002	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB2C003	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB2C004	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB2C005	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB2C006	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	28480	0160-4571
AB2CR011	1902-1291	8	3	DIODE-ZNR 1N5338B 5.1V 5% PD=5W IR=10A	04713	1N5338B
AB2CR012	1901-0050	3	16	DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR013	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR014	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR015	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR016	1901-0704	4	8	DIODE-PWR RECT 1N4002 100V 1A DO-41	01295	1N4002
AB2CR017	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR018	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR019	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR020	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR021	1901-0704	4		DIODE-PWR RECT 1N4002 100V 1A DO-41	01295	1N4002
AB2CR022	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
AB2CR023	1902-1291	8		DIODE-ZNR 1N5338B 5.1V 5% PD=5W IR=10A	04713	1N5338B
AB2CR024	1901-0704	4		DIODE-PWR RECT 1N4002 100V 1A DO-41	01295	1N4002
AB2CR025	1901-0704	4		DIODE-PWR RECT 1N4002 100V 1A DO-41	01295	1N4002
AB2CR026	1901-0704	4		DIODE-PWR RECT 1N4002 100V 1A DO-41	01295	1N4002
AB2CR027	1902-1291	8		DIODE-ZNR 1N5338B 5.1V 5% PD=5W IR=10A	04713	1N5338B
AB2J002	1250-1687	3	4	CONNECTOR-RF BNC FEM SCL-HOLE-RR 50-OHM	28480	1250-1687
AB2J003	1250-1687	3		CONNECTOR-RF BNC FEM SCL-HOLE-RR 50-OHM	28480	1250-1687
AB2J004	1250-1687	3		CONNECTOR-RF BNC FEM SCL-HOLE-RR 50-OHM	28480	1250-1687
AB2J005	1250-1687	3		CONNECTOR-RF BNC FEM SCL-HOLE-RR 50-OHM	28480	1250-1687
AB2J006	1250-1512	3	1	CONNECTOR-RF SMA M PC 50-OHM	28480	1250-1512
AB2J007	1251-4040	0	1	CONNECTOR 24-PIN F MICRO RIBBON	28480	1251-4040
AB2R001	0683-5105	4	2	RESISTOR 51 5% .25W FC TC=-400/+500	01121	0683-5105
AB2R002	0757-1040	5	1	RESISTOR 50 1% .25W F TC=0/+100	24546	C5-1/4 TD-50R0-F
AB2R003	0683-7515	4	1	RESISTOR 750 5% .25W FC TC=-400/+600	01121	0683-7515
AB2R004	0683-5105	4		RESISTOR 51 5% .25W FC TC=-400/+500	01121	0683-5105
AB2R005	0837-0275	6	3	THERMISTOR DISC 50-OHM TC=+2.35%/C-DEG	28480	0837-0275
AB2R006	0837-0275	6		THERMISTOR DISC 50-OHM TC=+2.35%/C-DEG	28480	0837-0275
AB2R007	0837-0275	6		THERMISTOR DISC 50-OHM TC=+2.35%/C-DEG	28480	0837-0275
AB2U001	1820-2024			IC 74LS244	28480	1820-2024
ABFW082	03561-61605	9	1	CABLE ASSEMBLY	28480	03561-61605
				AB2 MISCELLANEOUS PARTS		
	0300-0741	2	2	STANDOFF-RVT-ON .187-IN LG 6-32THD	00000	ORDER BY DESCRIPTION

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A90	03561-66590	1	1	ANALOG DISPLAY DRIVER ASSEMBLY (REVISION A)	28480	03561-66590
A90C001	0160-4571	8	5	CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A90C002	0160-4800	4	1	CAPACITOR-FXD 470PF +-5% 100VDC CER	28480	0160-4800
A90C003	0100-0224	2	6	CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C004	0100-0061	5	1	CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D107G016E12
A90C005	0100-0224	2		CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C100	0100-0224	2		CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C101	0160-5271	7	1	CAPACITOR-FXD 30PF +-5% 100VDC CER 0+-30	28480	0160-5271
A90C102	0100-0224	2		CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C200	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A90C201	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A90C300	0160-4230	6	3	CAPACITOR-FXD .01UF +80-20% 1KVDC CER	71590	CAP-103
A90C301	0160-4230	6		CAPACITOR-FXD .01UF +80-20% 1KVDC CER	71590	CAP-103
A90C302	0160-4230	6		CAPACITOR-FXD .01UF +80-20% 1KVDC CER	71590	CAP-103
A90C303	0150-0012	3	1	CAPACITOR-FXD .01UF +-20% 1KVDC CER	56289	C022A102J103MS3B
A90C304	0100-0087	7	1	CAPACITOR-FXD 100UF+50-10% 150VDC AL	56289	30D106F150D12
A90C400	0160-0160	1	1	CAPACITOR-FXD .10UF +-10% 200VDC POLYE	28480	0160-0160
A90C401	0160-4571	0		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A90C402	0100-0224	2		CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C403	0100-0224	2		CAPACITOR-FXD 100UF+75-10% 16VDC AL	56289	30D106G016BA2
A90C404	0160-5404	8	1	CAPACITOR-FXD 360PF +-5% 100VDC CER	28480	0160-5404
A90C405	0160-4811	9	1	CAPACITOR-FXD 270PF +-5% 100VDC CER	28480	0160-4811
A90C406	0160-5349	0	1	CAPACITOR-FXD 200PF +-5% 100VDC CER	28480	0160-5349
A90C500	0160-4571	8		CAPACITOR-FXD .10UF +80-20% 50VDC CER	28480	0160-4571
A90C501	0160-4823	3	1	CAPACITOR-FXD 020PF +-5% 100VDC CER	28480	0160-4823
A90C502	0160-3847	9	1	CAPACITOR-FXD .010UF +100-0% 50VDC CER	28480	0160-3847
A90C503	0160-0161	4	1	CAPACITOR-FXD .010UF +-10% 200VDC POLYE	28480	0160-0161
A90CR001	1901-0050	3	9	DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR002	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR003	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR004	1902-0777	3	2	DIODE-ZNR 1N825 6.2V 5% DO-7 PD=.4W	04713	1N825
A90CR005	1902-0777	3		DIODE-ZNR 1N825 6.2V 5% DO-7 PD=.4W	04713	1N825
A90CR100	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR102	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR103	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR201	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR202	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR300	1901-0732	8	1	DIODE-PWR RECT 1KV 1A	28480	1901-0732
A90CR400	1902-0952	6	1	DIODE-ZNR 5.6V 5% DO-35 PD=.4W TC=+.046%	28480	1902-0952
A90CR500	1901-0050	3		DIODE-SWITCHING 80V 200MA 2NS DO-35	28480	1901-0050
A90CR900	1901-0028	5	1	DIODE-PWR RECT 400V 750MA DO-29	28480	1901-0028
A90DS300	2140-0028	2	1	LAMP-NEON	28480	2140-0028
A90J001	1251-5393	0	1	CONNECTOR 3-PIN M POST TYPE	28480	1251-5393
A90J300	1251-5346	1	1	CONNECTOR 10-PIN M POST TYPE	28480	1251-5346
A90J400	1251-5639	5	1	CONNECTOR 2-PIN M POST TYPE	28480	1251-5639
A90L100	9140-0748	0	2	INDUCTOR 250UH 25% .25DX.5LG Q=3	28480	9140-0748
A90L101	9140-0210	1	2	INDUCTOR RF-CH-MLD 100UH 5% .166DX.365LG	28480	9140-0210
A90L102	9140-0748	0		INDUCTOR 250UH 25% .25DX.5LG Q=3	28480	9140-0748
A90L200	9100-0539	3	1	INDUCTOR (HICC ITEM)	28480	9100-0539
A90L400	9140-0210	1		INDUCTOR RF-CH-MLD 100UH 5% .166DX.365LG	28480	9140-0210
A90Q001	1854-0215	1	7	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q002	1853-0036	2	4	TRANSISTOR PNP SI PD=310MW FT=250MHZ	28480	1853-0036
A90Q003	1853-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	28480	1853-0036
A90Q200	1853-0413	9	1	TRANSISTOR PNP 2N6049 SI TO-66 PD=75W	28480	1853-0413
A90Q201	1854-0072	0	1	TRANSISTOR NPN 2N3054 SI TO-66 PD=25W	3L565	2N3054
A90Q202	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q203	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q204	1853-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	28480	1853-0036
A90Q205	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q206	1853-0036	2		TRANSISTOR PNP SI PD=310MW FT=250MHZ	28480	1853-0036
A90Q400	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q401	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90Q500	1854-0477	7	1	TRANSISTOR NPN 2N2222A SI TO-18 PD=500MW	04713	2N2222A
A90Q501	1854-0215	1		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	2N3904
A90R001	2100-3274	2	1	RESISTOR-TRMR 10K 10% C SIDE-ADJ 1-TRN	28480	2100-3274
A90R002	2100-3352	7	1	RESISTOR-TRMR 1K 10% C SIDE-ADJ 1-TRN	28480	2100-3352
A90R003	0757-0446	3	1	RESISTOR 15K 1% .125W F TC=0+-100	24546	C4-1/B-T0-150C-F
A90R004	0683-1035	1	2	RESISTOR 10K 5% .25W FC TC=-400/+760	01121	C81035
A90R005	0683-2415	3	1	RESISTOR 240 5% .25W FC TC=-400/+600	01121	C82415

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A90R006	0603-5135	0	1	RESISTOR 5.1K 5% .25W FC TC=-400/+700	01121	CB5125
A90R007	0690-4510	4	1	RESISTOR 84.5K 1% .125W F TC=0+/-100	24546	C4-1/8-T0-0452-F
A90R008	0603-5135	0	2	RESISTOR 51K 5% .25W FC TC=-400/+800	01121	CB5135
A90R009	0603-1045	3	5	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CB1045
A90R010	0603-1045	3	3	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CB1045
A90R011	0690-4530	0	1	RESISTOR 232K 1% .125W F TC=0+/-100	24546	C4-1/8-T0-2323-F
A90R012	0757-0465	6	1	RESISTOR 100K 1% .125W F TC=0+/-100	24546	C4-1/8-T0-1003-F
A90R013	0690-4496	5	1	RESISTOR 45.3K 1% .125W F TC=0+/-100	24546	C4-1/0-T0-4532-F
A90R014	0690-4462	5	2	RESISTOR 760 1% .125W F TC=0+/-100	24546	C4-1/8-T0-760R-F
A90R015	0690-4462	5	5	RESISTOR 760 1% .125W F TC=0+/-100	24546	C4-1/8-T0-760R-F
A90R016	0757-0124	4	1	RESISTOR 39.2K 1% .125W F TC=0+/-100	20480	0757-0124
A90R100	2100-3273	1	1	RESISTOR-TRMR 2K 10% C SIDE-ADJ 1-TRN	20400	2100-3273
A90R101	0690-4431	0	1	RESISTOR 2.05K 1% .125W F TC=0+/-100	24546	C4-1/0-T0-2051-F
A90R102	0603-1515	2	2	RESISTOR 150 5% .25W FC TC=-400/+600	01121	CB1515
A90R103	0603-1045	3	3	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CB1045
A90R104	0603-1035	1	1	RESISTOR 10K 5% .25W FC TC=-400/+700	01121	CB1035
A90R105	0811-3329	3	2	RESISTOR 2.7 5% 3W PW TC=0+/-50	20480	0811-3329
A90R106	0603-5605	9	2	RESISTOR 56 5% .25W FC TC=-400/+500	01121	CB5605
A90R107	0603-3935	4	2	RESISTOR 39K 5% .25W FC TC=-400/+800	01121	CB3935
A90R108	0603-1015	7	6	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R109	0603-8215	3	3	RESISTOR 820 5% .25W FC TC=-400/+600	01121	CB08215
A90R110	0603-4715	0	2	RESISTOR 470 5% .25W FC TC=-400/+600	01121	CB4715
A90R111	0811-0070	5	1	RESISTOR 1.3K 1% 3W PW TC=0+/-20	20480	0811-0070
A90R112	0603-3025	3	1	RESISTOR 3K 5% .25W FC TC=-400/+700	01121	CB3025
A90R113	0603-4715	0	0	RESISTOR 470 5% .25W FC TC=-400/+600	01121	CB4715
A90R114	0603-0215	3	3	RESISTOR 820 5% .25W FC TC=-400/+600	01121	CB08215
A90R115	0603-1015	7	4	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R116	0603-3935	4	1	RESISTOR 39K 5% .25W FC TC=-400/+800	01121	CB3935
A90R117	0603-5605	9	3	RESISTOR 56 5% .25W FC TC=-400/+500	01121	CB5605
A90R118	0811-3329	3	1	RESISTOR 2.7 5% 3W PW TC=0+/-50	20480	0811-3329
A90R200	2100-3355	0	1	RESISTOR-TRMR 100K 10% C SIDE-ADJ 1-TRN	20400	2100-3355
A90R201	2100-3358	3	2	RESISTOR-TRMR 1M 20% C SIDE-ADJ 1-TRN	20400	2100-3358
A90R202	0603-2735	0	1	RESISTOR 27K 5% .25W FC TC=-400/+800	01121	CB2735
A90R203	0603-2715	6	2	RESISTOR 270 5% .25W FC TC=-400/+600	01121	CB2715
A90R204	0603-1015	7	7	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R205	0603-2715	6	6	RESISTOR 270 5% .25W FC TC=-400/+600	01121	CB2715
A90R206	0603-1015	7	7	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R207	0603-5615	1	2	RESISTOR 560 5% .25W FC TC=-400/+600	01121	CB5615
A90R208	0603-5615	1	1	RESISTOR 560 5% .25W FC TC=-400/+600	01121	CB5615
A90R300	2100-3358	3	3	RESISTOR-TRMR 1M 20% C SIDE-ADJ 1-TRN	20400	2100-3358
A90R301	0603-1055	5	3	RESISTOR 1M 5% .25W FC TC=-800/+900	01121	CB1055
A90R302	0603-1055	5	1	RESISTOR 1M 5% .25W FC TC=-800/+900	01121	CB1055
A90R303	0603-1045	3	3	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CB1045
A90R304	0603-1015	7	7	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R305	0764-0016	0	1	RESISTOR 1K 5% 2W MD TC=0+/-200	20480	0764-0016
A90R306	0690-3640	9	1	RESISTOR 1.9K 5% 2W MD TC=0+/-200	27167	CP42-2-T00 1801-J
A90R307	0603-2745	2	1	RESISTOR 270K 5% .25W FC TC=-800/+900	01121	CB2745
A90R308	0603-1055	5	5	RESISTOR 1M 5% .25W FC TC=-800/+900	01121	CB1055
A90R400	0603-1025	9	4	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A90R401	0603-1025	9	9	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A90R402	0603-2015	9	1	RESISTOR 200 5% .25W FC TC=-400/+600	01121	CB2015
A90R403	0603-2025	1	2	RESISTOR 2K 5% .25W FC TC=-400/+700	01121	CB2025
A90R404	0603-3015	1	2	RESISTOR 300 5% .25W FC TC=-400/+600	01121	CB3015
A90R405	0603-8215	3	3	RESISTOR 820 5% .25W FC TC=-400/+600	01121	CB08215
A90R406	0603-2025	1	1	RESISTOR 2K 5% .25W FC TC=-400/+700	01121	CB2025
A90R407	0603-1525	4	3	RESISTOR 1.5K 5% .25W FC TC=-400/+700	01121	CB1525
A90R500	0603-1525	4	4	RESISTOR 1.5K 5% .25W FC TC=-400/+700	01121	CB1525
A90R501	0690-4402	9	1	RESISTOR 17.4K 1% .125W F TC=0+/-100	03038	PME55-1/8-T0 1742-F
A90R502	0603-3015	1	1	RESISTOR 300 5% .25W FC TC=-400/+600	01121	CB3015
A90R503	0603-1015	7	7	RESISTOR 100 5% .25W FC TC=-400/+500	01121	CB1015
A90R504	0603-5135	3	3	RESISTOR 51K 5% .25W FC TC=-400/+800	01121	CB5135
A90R505	0603-1045	3	3	RESISTOR 100K 5% .25W FC TC=-400/+800	01121	CB1045
A90R506	0603-1025	9	9	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A90R507	0603-1525	4	4	RESISTOR 1.5K 5% .25W FC TC=-400/+700	01121	CB1525
A90R508	0150-3375	5	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20400	0150-3375
A90R509	0603-1515	2	2	RESISTOR 150 5% .25W FC TC=-400/+600	01121	CB1515
A90R600	0603-1025	9	9	RESISTOR 1K 5% .25W FC TC=-400/+600	01121	CB1025
A90TP001	1251-0600	0	20	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP100	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP101	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP102	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP103	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP200	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP300	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP301	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP302	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP303	1251-0600	0	0	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A90TP304	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP400	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP501	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP502	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP503	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP504	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP505	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP506	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP507	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP900	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90TP901	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	20400	1251-0600
A90U001	1026-0312	0	1	IC OP AMP GP QUAD 14-DIP-P PKG	04713	KC3403P
A90U500	1026-0119	5	1	IC TIMER TTL MONO/ASTBL	10324	NE555T
A90U501	1020-1322	2	1	IC GATE TTL S NGR QUAD 2-INP	01295	SN74S02N
A90U600	1020-0471	0	1	IC INV TTL HEX 1-INP	01295	SN7406N
				A90 MISCELLANEOUS PARTS		
	2190-0007	2	4	WASHER-LK INTL T NO. 6 .141-IN-ID	20400	2190-0007
	2420-0003	7	4	NUT-HEX-DEL-CHAM 6-32-THD .094-IN-THK	20400	2420-0003
	1205-0419	2	2	HEAT SINK	20400	1205-0419
	4040-0756	3	1	EXTR-WHITE PC BD	20400	4040-0756
	4040-0740	3	1	EXTR-BLACK PC BD	20400	4040-0740
	1480-0116	0	2	PIN-GRV .062-IN-DIA .25-IN-LG STL	20400	1480-0116

See introduction to this section for ordering information  
 \*Indicates factory selected value

**Table 4-3 Replaceable Parts (Cont'd)**

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A99	03561-66599	0	1	MOTHERBOARD ASSEMBLY (REVISION B)	28480	03561-66599
A99C001	0180-0059	1	3	CAPACITOR-FXD 100UF+75-10% 25VDC AL	56289	30D186G025BR2
A99C002	0180-0059	1		CAPACITOR-FXD 100UF+75-10% 25VDC AL	56289	30D186G025BR2
A99C003	0150-0012	3	1	CAPACITOR-FXD .01UF +-20% 1KVDC CER	56289	C023A102J103M038
A99C004	0180-0059	1		CAPACITOR-FXD 100UF+75-10% 25VDC AL	56289	30D186G025BR2
A99C5*	0160-3454	4	1	C-F 220 pF, 10% 1000 Vdc Max Voltage, Ceramic	28480	0160-3454
	0160-3455	5		C-F 470 pF, 10% 1000 Vdc Max Voltage, Ceramic	28480	0160-3455
	0160-3466	8		C-F 1000 pF, 10% 1000 Vdc Max Voltage, Ceramic	28480	0160-3466
A99C6* Same as A99C5			1			
A99C7* Same as A99C5			1			
A99C8* Same as A99C5			1			
A99C009	0180-2803	7	2	CAPACITOR-FXD 100UF+50-10% 50VDC AL	28480	0180-2803
A99C010	0160-3454	6		CAPACITOR-FXD 1000PF +-10% 1KVDC CER	28480	0160-3454
A99C011	0160-3455	5	2	CAPACITOR-FXD 470PF +-10% 1KVDC CER	28480	0160-3455
A99C100	0180-3307	4	2	CAPACITOR-FXD 1300UF+50-10% 250VDC AL	28480	0180-3307
A99C101	0180-3387	4		CAPACITOR-FXD 1300UF+50-10% 250VDC AL	28480	0180-3307
A99C102	0160-3830	0	1	CAPACITOR-FXD 50F +-10% 50VDC MET-PLYC	28480	0160-3830
A99C103	0180-2003	7		CAPACITOR-FXD 100UF+50-10% 50VDC AL	28480	0180-2803
A99C104	0160-3455	5		CAPACITOR-FXD 470PF +-10% 1KVDC CER	28480	0160-3455
A99C200	0180-0100	3	9	CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C201	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C202	0160-3622	8	7	CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C203	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C204	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C205	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C206	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C207	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C208	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C209	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C210	0180-3368	1	1	CAPACITOR 3300UF 25V AL	28480	0180-3368
A99C300	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C301	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C302	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C303	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99C304	0160-3622	8		CAPACITOR-FXD .1UF +00-20% 100VDC CER	26654	2130Y5V100R104Z
A99C305	0180-0100	3		CAPACITOR-FXD 4.7UF+-10% 35VDC TA	56289	150D475X9035B2
A99CR001	1901-0040	7	2	DIODE-PWR RECT 400V 3A 200NS	14713	MR854
A99CR002	1901-0048	7		DIODE-PWR RECT 400V 3A 200NS	04713	MR054
A99CR100	1906-0080	9	1	DIODE-FW BRDG 600V 10A	28480	1906-0080
A99CR200	1901-0743	1	10	DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR201	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR202	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR203	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR204	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR205	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR206	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR207	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR208	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR209	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR300	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR301	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR302	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR303	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR304	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR305	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR306	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99CR307	1901-0743	1		DIODE-PWR RECT 1N4004 400V 1A DO-41	01295	1N4004
A99E001	1970-0094	0	1	250V SPARK GAP	28480	1970-0094
A99F001	2110-0004	1	1	FUSE .25A 250V NTD 1.25X.25 UL	28480	2110-0004
A99J001	1251-6173	4	1	CONNECTOR 2-PIN H POST TYPE	28480	1251-6173
A99J010	1251-2915	4	2	CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J015	1251-1365	6	U	CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J021	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J022	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J031	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J032	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J041	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J042	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J051	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J052	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J061	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J062	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J065	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J070	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
* Whenever T100 is replaced, C5, C6, C7, and C8 must be reselected using the procedure given in Paragraph 730. C5, C6, C7, and C8 are factory selected components, and must be reselected whenever A99100 is replaced.						

See introduction to this section for ordering information  
\*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
A99J071	1251-2915	4	2	CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J072	1251-2915	4		CONNECTOR-PC EDGE 25-CONT/ROW 2-ROWS	28480	1251-2915
A99J081	1251-5721	6		CONNECTOR 40-PIN M POST TYPE	28480	1251-5721
A99J082	1251-5721	6		CONNECTOR 40-PIN M POST TYPE	28480	1251-5721
A99J090	1251-1365	6		CONNECTOR-PC EDGE 22-CONT/ROW 2-ROWS	28480	1251-1365
A99J300	1250-1339	2	1	CONNECTOR-RF SM-SLD M PC 50-OHM	28480	1250-1339
A99L001	9140-0748	0	1	INDUCTOR 250UH 25% .25DX.5LG Q=3	28480	9140-0748
A99L101	9140-0822	1	1	COIL-VAR 30UH-140UH Q=32 PC-MTC	28480	9140-0822
A99Q001	1854-0780	5	1	TRANSISTOR NPN SI TO-3 PD=60W FT=4MHZ	D2540	RUH83
A99R001	0811-1854	5	1	RESISTOR 50 5% 5W PW TC=0+-20	28480	0811-1854
A99R002	0811-3478	3	1	RESISTOR .1 1% 5W PW TC=0+-20	28480	0811-3478
A99R003	0683-1045	3	1	RESISTOR 100K 5% .25W FC TC=-400/+300	01121	081045
A99R100	0764-0040	8	2	RESISTOR 39K 5% 2W MO TC=0+-200	28480	0764-0040
A99R101	0764-0040	8		RESISTOR 39K 5% 2W MO TC=0+-200	28480	0764-0040
A99R102	0757-0159		1	RESISTOR 1K 5% 1/2W MO TC=0+-200	28480	0757-0159
A99R300	0698-3608	9	1	RESISTOR 20 5% 2W MO TC=0+-200	27167	FP42-2-T00-26R0-J
A99R113	0837-0135	7	1	THERMISTOR DISC 5-OHM TC=-3.3%/C-DEG	15454	5DA5R0-220-SIL-Z
A99S100	3101-2298	1	2	SWITCH-SL DPDT STD 5A 250VAC SLDR-LUG	28480	3101-2298
A99S101	3101-2298	1		SWITCH-SL DPDT STD 5A 250VAC SLDR-LUG	28480	3101-2298
A99T001	9100-0454	1	1	TRANSFORMER PRI IND: 9.4 MH NOM; SEC	28480	9100-0454
A99T002	T-106196	2	1	RIAS XFMR	28480	T-106196
A99T100	9100-4341	3	1	TRANSFORMER-FLYBACK FREQUENCY: 36.2KHZ	28480	9100-4341
A99W001	DS-JUMP-BLU	9	2	JUMPER, 22 AWG	28480	DS-JUMP-BLU
A99W002	DS-JUMP-BLU	9		JUMPER, 22 AWG	28480	DS-JUMP-BLU
A99W003	DS-JUMP-RED	2	2	JUMPER, 22 AWG	28480	DS-JUMP-RED
A99W004	DS-JUMP-WBL	4	1	JUMPER, 22 AWG	28480	DS-JUMP-WBL
A99W005	DS-JUMP-WGR	0	1	JUMPER, 22 AWG	28480	DS-JUMP-WGR
A99W008	DS-JUMP-WRE	6	2	JUMPER, 22 AWG	28480	DS-JUMP-WRE
A99W007	DS-JUMP-WYE	6	1	JUMPER, 22 AWG	28480	DS-JUMP-WYE
A99W008	DS-JUMP-YEL	2	2	JUMPER, 22 AWG	28480	DS-JUMP-YEL
A99W009	DS-JUMP-RED	2		JUMPER, 22 AWG	28480	DS-JUMP-RED
A99W010	DS-JUMP-WRE	6		JUMPER, 22 AWG	28480	DS-JUMP-WRE
A99W011	DS-JUMP-YEL	2		JUMPER, 22 AWG	28480	DS-JUMP-YEL
A99U200	1826-0147	9	2	IC 7012 V RGLTR TO-220	04713	MC7812CP
A99U201	1826-0147	9		IC 7012 V RGLTR TO-220	04713	MC7812CP
A99U202	1826-0221	0	1	IC V RGLTR TO-220	04713	MC7912CT
A99U203	1826-0146	0	1	IC 7008 V RGLTR TO-220	04713	MC7800CP
A99U204	1826-0122	0	2	IC 7005 V RGLTR TO-220	07263	7805UC
A99U205	1826-0122	0		IC 7005 V RGLTR TO-220	07263	7805UC
A99U300	1826-0214	1	1	IC V RGLTR TO-220	04713	MC7915CT
A99U301	1826-0106	0	1	IC 7015 V RGLTR TO-220	04713	MC7815CP
A99U302	1826-0150	4	1	IC 340T-24 V RGLTR TO-220	07263	7824UC
A99W070	03561-61607	1	1	CABLE ASSY 70/??	28480	03561-61607
A99 MISCELLANEOUS PARTS						
	0340-0564	3	1	INSULATOR-XSTR THRM-CONDCT	28480	0340-0564
	03561-01231	1	1	FLYBK SHLD, RIGHT	28480	03561-01231
	03561-01232	2	1	FLYBK SHLD, LEFT	28480	03561-01232
	0515-0054	7	1	SCREW-MACH M3 X 0.5 10MM-LG PAN-HD	28480	0515-0054
	0515-0055	8	7	SCREW-MACH M3 X 0.5 6MM-LG PAN-HD	28480	0515-0055
	0515-0104	8	13	SCREW-MACH M3 X 0.5 8MM-LG PAN-HD	28480	0515-0104
	0535-0004	9	2	NUT-HEX DR-L CHAM M3 X 0.5 2.4MM-THK	00000	ORDER BY DESCRIPTION
	0590-1088	7	1	THREADED INSERT-NUT M3 X 0.5 CARD-STL	28480	0590-1088
	0590-1220	9	2	THREADED INSERT-NUT M3 X 0.5 1.5-MM-LG	28480	0590-1220
	1205-0495	4	1	HEAT SINK	28480	1205-0495
	2110-0643	4	1	FUSEHOLDER-CLIP TYPE 15A 250 V	28480	2110-0643
	03561-01222	0	1	REG HEAT SINK	28480	03561-01222
	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ 5Q	28480	1251-0600
	03561-60601	3	1	FLYBK SHLD ASSY	28480	03561-60601
	2190-0004	9	15	WASHER-LK INTL T NO. 4 .115-IN-ID	28480	2190-0004
	2260-0609	3	2	NUT-HEX-W/LKWR 4-40-THD .094-IN-THK	00000	ORDER BY DESCRIPTION
	3050-0066	0	2	WASHER-FL MTLC NO. 6 .147-IN-ID	28480	3050-0066
	3050-0440	2	1	WASHER-SHLDR NO. 4 .115-IN-ID .2-IN-OD	28480	3050-0440

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)

Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
B1	3160-0439	2	1	FAN	28480	3160-0439
C1	0160-3622	8	1	CAPACITOR-FXD .10UF +80-20% 100VDC CER	26654	2130Y5V100R1C4Z
C2	0150-0812	3	1	CAPACITOR-FXD .01UF +-20% 1KVDC CER	56209	C023A192J103M53B
DS1	2140-0024	8	1	NEON LAMP	28400	2140-0024
F2 (110/120V)	2110-0003			FUSE 3A 250V NORMAL BLOW	28480	2110-0003
F2 (220/240V)	2110-0304			FUSE 1.5A	28480	2110-0304
MP001	03561-04101	0	1	TOP COVER	20480	03561-04101
MP002	03561-04102	1	1	BOTTOM COVER	28480	03561-04102
MP003	03561-01210	6	1	DIGITAL ASSEMBLY HOLDDOWN COVER	28480	03561-01210
MP004	03561-01211	7	1	POWER SUPPLY HOLDDOWN COVER	28480	03561-01211
MP005	03561-01205	9	1	A99 ASSEMBLY HOLDDOWN COVER	28480	03561-01205
MP006	03561-00601	7	1	CRT TUBE SHIELD	28480	03561-00601
MP007	03561-60605	7	1	MOTHERBOARD CAPACITOR HOLDDOWN BRACKET	28480	03561-60605
MP008	03561-41262	0	1	DIGITAL COVER NYLON SEPARATOR (SHORT)	28480	03561-41262
MP009	03561-41201	9	1	DIGITAL COVER NYLON SEPARATOR (LONG)	20480	03561-41201
MP010	03561-41203	1	1	POWER SUPPLY COVER NYLON SEPARATOR	28480	03561-41203
MP011	5040-0516	4	1	FRONT PANEL HELMET	28480	5040-0516
MP012	03561-01219	5	1	A10 ASSEMBLY COVER PLATE	28480	03561-01219
MP013	03561-01220	8	1	A10 ASSEMBLY SIDE SHIELD	28480	03561-01220
MP014	03561-23701	6	1	RIGHT SIDE RAIL	28480	03561-23701
MP015	03561-04304	5	1	LABEL, LINE SELECTION SWITCH	28480	03561-04304
MP016	03561-01216	2	1	A90 ASSEMBLY SIDE SHIELD	28480	03561-01216
MP017	03561-01225	3	1	FUSE SHIELD, PLASTIC	28480	03561-01225
MP018	03561-01222	0	1	PS REGULATOR HEAT SINK	28480	03561-01222
MP019	03561-23703	8	1	LEFT SIDE RAIL	28480	03561-23703
MP020	1540-0292	9	1	TOP COVER VINYL POUCH	28480	1540-0292
MP021	4324-0395	5	1	DIGITAL PC COVER FOAM PAD	28480	4324-0395
MP022	03561-44302	7	1	MAIN KEYPAD	28480	03561-44302
MP023	03561-44301	6	1	SOFTKEY KEYPAD	20480	03561-44301
MP024	3150-0210	4	1	FAN AIR FILTER	28480	3150-0210
MP025	03561-20002	4	1	REAR PANEL CASTING	28480	03561-20002
MP026	3160-0092	3	1	FAN GRILL	28480	3160-0092
MP027	03561-01217	3	1	FAN HOUSING	28480	03561-01217
MP028	03561-01209	3	1	REAR SUBPANEL	28480	03561-01209
MP029	03561-01206	0	1	FAN AIR DEFLECTOR	28480	03561-01206
MP030	03561-60603	5	1	REAR SHEET METAL ASSEMBLY GUIDE	28480	03561-60603
MP031	5041-2625	2	1	CARRYING HANDLE	28480	5041-2625
MP032	1460-0604	7	2	HANDLE COMPRESSION SPRING	28480	1460-0604
MP033	0380-1661	7	2	CRT MOUNTING STANDOFF	28480	0380-1661
MP034	5020-0735	3	2	HANDLE HUB GEAR	28480	5020-0735
MP035	1390-0084	8	1	1/4 TURN CLIP-ON NUT	28480	1390-0084
MP036	5020-0780	6	2	HANDLE RING GEAR	28480	5020-0780
MP037	0160-0467	1	4	RFI STRIP FINGERS	28480	0160-0467
MP038	5040-0511	9	2	HANDLE RING TRIM CAP	28480	5040-0511
MP039	0340-0564	3	9	REGULATOR INSULATORS	28480	0340-0564
MP040	03561-01230	0	1	CRT WIRE RING RETAINER	28480	03561-01230
MP041	03561-21201	7	1	CRT RUBBER GASKET	28480	03561-21201
MP042	03561-20001	3	1	FRONT PANEL CASTING	28480	03561-20001
MP043	0355-0013	0		FAN FILTER THUMB NUT	30200	ORDER BY DESCRIPTION
MP044	2950-0035	8		HP-1B BNC NUTS	00600	ORDER BY DESCRIPTION
MP045	9135-0212	2	1	LINE FILTER ASSEMBLY	28480	9135-0212
MP046	03561-01218	4	1	MOTHERBOARD SHIELD, PLASTIC	28480	03561-01218
MP047	03561-01208	2	1	A15 ASSEMBLY SIDE SHIELD	28480	03561-01208
MP048	1390-0532	1	3	A10 SHIELD PLASTIC NUT	94222	11-1R-106-12
MP049	03561-01213	9	1	REAR SHIELD INSULATOR, PLASTIC	28480	03561-01213
MP050	03561-01212	8	1	FRONT SHIELD INSULATOR, PLASTIC	28480	03561-01212
MP051	0403-0132	5	5	REAR PLASTIC ASSEMBLY GUIDES	28480	0403-0132
MP052	03561-60602	4	1	DIGITAL ASSEMBLY GUIDE, FRONT	28480	03561-60602
MP053	03561-60604	6	1	DIGITAL ASSEMBLY GUIDE, CENTER	28480	03561-60604
MP054	5040-5062	3	4	REAR FOOT BODY	20480	5040-5062
MP055	5041-0201	6	1	POWER SWITCH KEY CAP	28480	5041-0201
MP056	03561-60601	3	1	FLYBACK TRANSFORMER SHIELD	28480	03561-60601
MP057	1205-0495	4	1	A99 HEATSINK	28480	1205-0495
MP058	5040-5061	2	4	REAR FOOT CAP	28480	5040-5061
MP059	03561-01226	4	1	A50 ASSEMBLY ANALOG SHIELD	28480	03561-01226
MP060	03561-41101	0	3	A20 IC HEATSINK	28480	03561-41101
MP061	03561-41101	0		A29 IC HEATSINK	28480	03561-41101
MP062	03561-41101	8		A20 IC HEATSINK	28480	03561-41101
MP063	03561-23702	7	1	A10 SHIELD, COMPONENT SIDE	28480	03561-23702
MP064	03561-01227	5	1	A10 ATTENUATOR RING STANDOFF	28480	03561-01227
MP065	03561-20601	9	1	A10 SHIELD, CIRCUIT SIDE	28480	03561-20601
MP066	03561-01215	1	1	MEMORY SHIELD	28480	03561-01215
MP067	2110-0569	3	1	FUSEHOLDER COMPONENT NUT, THREAD M12.7	28480	2110-0569
MP068	1400-0090	9	1	FUSEHOLDER COMPONENT FOR USE ON	20480	1400-0090
MP069	2110-0564	8	1	FUSEHOLDER BODY 12A MAX FOR UL	H9027	311-1657
MP070	2110-0565	9	1	FUSEHOLDER CAP 12A MAX FOR UL	28480	2110-0565

See introduction to this section for ordering information  
 \*Indicates factory selected value

Table 4-3 Replaceable Parts (Cont'd)



Reference Designation	HP Part Number	C D	Qty	Description	Mfr Code	Mfr Part Number
MP071	03561-01229	7	1	PLASTIC INSULATOR, SIDE	28480	03561-01229
MP072	03561-04301	2	1	SIDE TRIM, FRONT (SHORT)	28480	03561-04301
MP073	03561-04302	3	1	SIDE TRIM, REAR (LONG)	28480	03561-04302
MP074	03561-64301	8	1	DRESS PANEL, FRONT	28480	03561-64301
MP075	03561-64302	9	1	DRESS PANEL, REAR	28480	03561-64302
MP076	1390-0532	1		PLASTIC NUT (A10 ISOLATION)	94222	F1-10-106-12
MP077	0400-0163	6	4	PLASTIC STRIP	28480	0400-0163
MP078	0160-0466	0	4	SIDE RAIL RFI STRIP	28480	0160-0466
S1	3101-2216	3	1	POWER SWITCH, LINE	28480	3101-2216
S2	3101-0199	7	1	SLIDE SWITCH	28480	3101-0199
V1	03561-62501	6	1	CRT/YOKE ASSEMBLY	28480	03561-62501
W10	03561-61602	6	1	INPUT CABLE ASSEMBLY	28480	03561-61602
W15	03586-61677	4	2	COAX CABLE 10"	28480	03586-61677
W50	03586-61677	4		COAX CABLE 10"	28480	03586-61677
W80	1251-0598	1	1	FOAM CABLE, KEYBOARD ASSEMBLY	28480	1251-0598
W90	03561-61608	2	1	CRT CONNECTOR ASSEMBLY	28480	03561-61608
MPO79	03561-01223			LEFT REAR SIDE RAIL SPACER	28480	03561-01223
MPO80	03561-01224			REGULATOR HEAT SINK BRACKET	28480	03561-01224



See introduction to this section for ordering information  
 \*Indicates factory selected value






Table 4-3 Replaceable Parts (Cont'd)


PART NUMBER	DESCRIPTION	WHERE USED	QTY:
1390-0088	1/4 Turn Fastener	Top & Bottom Covers (MP1, MP2)	8
1390-0211	1/4 Turn Retainer	Top & Bottom Covers (MP1, MP2)	8
1390-0084	1/4 Turn Clip On Nut	Front & Rear Panel Castings (MP42, 25)	8
2360-0117	6-32 Screw	Bail Handle To Ratchet (MP31)	4
0515-0072	Panhead Screw	Bail Handle To Siderail (MP31)	2
2190-0073	Lockwasher	Bail Handle To Siderail (MP31)	2
0515-0055	Panhead Screw	PC Assembly Holddown Covers (MP3, MP4)	8
0515-0076	Countersunk Screw	Nylon PC Holddown Retainers (MP8, MP9, MP10)	8
0515-0055	Panhead Screw	A90 Assembly Holddown Plate (MP5)	2
0515-0074	Panhead Screw	Motherboard Capacitor Bracket (MP7)	2
0535-0008	M2.5 Nut	Motherboard Capacitor Bracket (MP7)	2
2190-0004	Lockwasher	Motherboard Capacitor Bracket (MP7)	2
0515-0076	Countersunk Screw	Dress Panel To Frame (MP74)	4
2510-0107	8 x 32 Screw	Fnt & Rear Frame To Siderail (MP25, MP42)	8
2190-0009	Lockwasher	Fnt & Rear Frame To Siderail (MP25, MP42)	8
0515-0074	M2.5 Screw	Line Switch Mounting (S1)	2
0515-0104	Panhead Screw	Reg. Heat Sink To Siderail (MP19)	3
0515-0104	Panhead Screw	A90 Shield To Siderail	3
0515-0053	Panhead Screw	A10 and A15 Shields to Siderail (MP13, MP47)	9
0515-0104	Panhead Screw	A10 and A15 Shields to Siderail (MP13, MP47)	4
3050-0004	Insulated Washer	A10 and A15 Shields to Siderail (MP13, MP47)	4
0515-0077	Countersunk Screw	Motherboard Shield (MP46)	5
0515-0055	Panhead Screw	Motherboard To All Shields (A99)	17
2190-0004	Lockwasher	Motherboard To All Shields (A99)	17
0515-0231	Panhead Screw	Rear Feet To Casting (MP58, MP54)	4
2190-0003	Lockwasher	Rear Feet To Casting (MP58, MP54)	4
3050-0066	Flatwasher	Rear Feet To Casting (MP58, MP54)	4
2360-0115	Screw	Line Filter To Casting (by plug) (MP45)	2
0515-0067	Screw	Line Filter To Casting (by A82) (MP45)	1
0535-0007	M3.5 Nut	Line Filter To Casting (by A82) (MP45)	1
3050-0066	Flatwasher	Line Filter To Casting (by A82) (MP45)	1
0515-0147	Screw	Fan Mounting (MP27, B1)	4
2190-0007	Flatwasher	Fan Mounting (MP27, B1)	4
0535-0007	M3.5 Nut	Fan Mounting (MP27, B1)	4
0535-0013	Thumbnut	Fan Mounting (MP27, B1)	4
0380-0643	Stud	HP-IB Mounting	2
2190-0073	Lockwasher	HP-IB Mounting	2
2950-0035	BNC Nut	Rear Panel Output BNCs	4
0520-0128	2 x 56 Screw	Front Panel Isolation Switch (S2)	2
0810-0001	2 x 58 Nut	Front Panel Isolation Switch (S2)	2
0515-0937	M3.5 Screw	A80 To Front Casting (Hex)	23
2380-0318	6 x 23 Screw	CRT Standoff To Front Casting (MP33)	4
0380-1881	Standoff	CRT Mounting Standoffs (MP33)	4
2380-0121	8 x 32 Screw	CRT Retainer To Standoff (MP33)	4
3050-0066	Flatwasher	CRT Retainer To Standoff (MP33)	4
0515-0076	Screw	CRT Shield To Front Casting (MP6)	4
2950-0054	BNC Nut	Front Panel Input BNC (W10)	1
3050-0313	Insulating Washer	Front Panel Input BNC (W10)	1


























**SECTION V**  
**BACKDATING**

---

<b>Paragraph</b>	<b>Title</b>	<b>Page</b>
5-1	INTRODUCTION .....	5-1
5-2	MANUAL CHANGES .....	5-1
5-3	A10 Input Amplifier Assembly Backdating .....	5-2
5-4	A15 Digitizer Assembly Backdating .....	5-3
5-5	A20 Digital Filter Assembly Backdating .....	5-4
5-6	A30 FFT/RAM Assembly Backdating .....	5-4
5-7	A40 Processor/ROM Assembly Backdating .....	5-4
5-8	A50 Local Oscillator/Noise Source Assembly Backdating .....	5-7/5-8
5-9	A82 Rear Panel Assembly Backdating .....	5-13
5-10	A99 Motherboard Assembly Backdating .....	5-14

## SECTION V BACKDATING

---

### 5-1 INTRODUCTION

The purpose of this section is to provide the information necessary to modify this manual to apply to instruments which have revision A PC Assemblies only. Note that some of the circuit assemblies are revised for ease of manufacturing and do not necessarily incorporate circuit changes. For this reason, some revision A assemblies are identical to revision B assemblies.

### 5-2 MANUAL CHANGES

Table 5-1 lists the current revision letter for each PC Assembly. Refer to the assembly headings following Table 5-1 for the actual manual changes.

**Table 5-1 Revision A Assemblies Versus Revision B Assemblies**

<b>The following assemblies are currently revision A:</b>
A72 Power Supply Filter Assembly A80 Keyboard Assembly A81 Keyboard Driver Assembly A90 Analog Display Assembly
<b>The following assemblies are currently revision B:</b>
A10 Input Amplifier Assembly A15 Digitizer Assembly A20 Digital Filter Assembly A30 FFT/RAM Assembly A40 Processor/ROM Assembly A50 Local Oscillator/Noise Source Assembly *A60 Digital Display Driver Assembly *A65 CMOS/Bubble Memory Assembly (Option 001) *A66 CMOS Memory Assembly *A70 Power Supply PWM Assembly *A71 Power Supply Transformer Assembly A82 Rear Panel Assembly A99 Motherboard Assembly


\*These assemblies are revised for ease of manufacturing and do not incorporate circuit changes. For this reason, no backdating information is necessary.

### 5-3 A10 Input Amplifier Assembly Backdating

Do the following to modify the A10 Assembly information to reflect revision A:

1. Replace the A10 component locator in Section VII with the revision A component locator in Figure 5-1a.
2. Delete capacitor C7 (0160-4792 8.2pf) from the A10 schematic (Circuit E) and replaceable parts list.
3. Delete capacitor C8 (0160-4811 270pf) from the A10 schematic (Circuit D) and replaceable parts list.

Figure 5-1a A10 Assembly Revision A Component Locator




### 5-4 A15 Digitizer Assembly Backdating

Do the following to modify the A15 Assembly information to reflect revision A:

1. Delete Test Point "SOUT" from the A15 schematic (Circuit L).
2. Delete capacitor C501 (0160-4808 470PF) from the A15 schematic (Circuit L) and replaceable parts list.
3. Delete resistor R226 (0757-0484 619K) from the A15 schematic (Circuit L) and replaceable parts list.
4. Delete resistor R503 (0757-0443 11K) from the A15 schematic (Circuit L) and replaceable parts list.
5. Replace the A15 component locator in Section VII with the revision A component locator in Figure 5-1b.

Figure 5-1b A15 Revision A Component Locator



**5-5 A20 Digital Filter Assembly Backdating**

Do the following to modify the A20 Assembly information to reflect revision A:

1. Delete Test Point TP503 from the A20 schematic (Circuit U).
2. Delete Test Point TP504 from the A20 schematic (Circuit U).

**5-6 A30 FFT/RAM Assembly Backdating**

Do the following to modify the A30 Assembly information to reflect revision A:

1. Delete Test Point TP704 from the A30 schematic (Circuit H).
2. Delete Test Point TP705 from the A30 schematic (Circuit H).

**5-7 A40 Processor/ROM Assembly Backdating**

Do the following to modify the A40 Assembly information to reflect revision A:

1. Replace the A40 component locator in Section VII with the revision A component locator in Figure 5-2.





Do the following to modify the A50 Assembly information to reflect revision A:


- Figure 5-3 A50 Assembly Revision A Component Locator**




2. Delete the power supply RC filter circuits going to pins 4 and 7 of U401 (Circuit FF), U403 (Circuit CC), U404 (Circuit HH) and U902 (Circuit II) as shown in Figure 5-4.

**Figure 5-4 A50 Assembly RC Filter Deletion**

From this:




To this:




3. Delete the four  $\pm 12V$  .1 $\mu F$  filter capacitors C410, C411, C904 and C905 connected to L900 and L901 from the A50 schematic.
4. Delete the 10pF capacitor C907 connected between pins U404(2,6) from the A50 schematic (Circuit HH).
5. Delete the 100pF capacitor C906 connected between pins U902(2,6) from the A50 schematic (Circuit II).
6. Delete the 100 $\Omega$  resistor R905 connected between U902(2) and the cathode of CR900 (Circuit II) and replace with a short circuit. U902(2) should now connect directly to the cathode of CR900.
7. Change the Functional Circuit GCLOCK GENERATOR K as shown in Figure 5-5.

**Figure 5-5 A50 GCLOCK GENERATOR K Revision A Modification**

From this:



To this:




8. Change capacitor C401 from .1uF to 27pF on the A50 schematic (Circuit CC).
9. Delete inductor L902 from the A50 schematic (Circuit II).
10. Change resistor R902 from 10k $\Omega$  to 1k $\Omega$  on the A50 schematic (Circuit II).
11. Delete the following twelve .1uF capacitors (0160-4571) from the A50 replaceable parts list: C410, C411, C413, C414, C415, C416, C417, C418, C904, C905, C908 and C909.
12. Delete the following eight 48.7 $\Omega$  resistors from (0698-4381) the A50 replaceable parts list: R409, R410, R411, R412, R413, R414, R906 and R907.
13. Delete 10pF capacitor C907 (0160-4791) from the A50 replaceable parts list.
14. Delete 100pF capacitor C906 (0160-4801) from the A50 replaceable parts list.
15. Delete 100 $\Omega$  resistor R905 (0757-0401) from the A50 replaceable parts list.
16. Delete U010 (1820-2657) from the A50 replaceable parts list.
17. Change capacitor C401 from 0160-4786 (27pf) to 0160-4795 (4.7pf) in the A50 replaceable parts list.
18. Change resistor R902 from 0757-0280 (1K) to 0757-0401 (10K) in the A50 replaceable parts list.
19. Delete inductor L902 (9100-3551 1uH) from the A50 replaceable parts list.

### 5-9 A82 Rear Panel Assembly Backdating

Do the following to modify the A82 Assembly information to reflect revision A:

1. Replace the A82 component locator in Section VII with the revision A component locator in Figure 5-6.

**Figure 5-6 A82 Assembly Revision A Component Locator**




2. Delete U1 and C6 from the A82 schematic.
3. Delete U1 (1820-2024) from the A82 replaceable parts list.
4. Delete C6 (0160-4571) from the A82 replaceable parts list.

### 5-10 A99 Motherboard Assembly Backdating

Do the following to modify the A99 Assembly information to reflect revision A:

1. Replace the A99 component locator in Section VII with the revision A component locator in Figure 5-7.
2. Delete C104 from the A99 schematic and connect R102 directly across L101.
3. Delete capacitor C104 (0160-3455) from the A99 replaceable parts list.
4. Change resistor R102 from 0757-0159 (1k 1/2W) to 0764-0016 (1k 2W) in the A99 replaceable parts list.

Figure 5-7 A99 Assembly Revision A Component Locator



**SECTION VI**  
**FAULT ISOLATION**

---



Paragraph	Title	Page
6-1	INTRODUCTION .....	6-1
6-2	SAFETY CONSIDERATIONS .....	6-3
6-3	RECOMMENDED TEST EQUIPMENT: FAULT ISOLATION .....	6-4
6-4	SELF CALIBRATION .....	6-4
6-5	Calibration Procedure .....	6-4
6-6	Calibration Failures .....	6-5
6-7	TROUBLESHOOTING GUIDELINES .....	6-6
6-8	FAULT ISOLATION PROCEDURE .....	6-11
6-9	Using the Fault Isolation Procedure .....	6-11
6-10	TEST A: Bias Power Supply A71, A99 .....	6-12
6-11	TEST B: Main Power Supply A70, A71, A72, A99 .....	6-14
6-12	TEST C: Display Driver A60, A90, A99 .....	6-19
6-13	TEST D: Processor/ROM A40 .....	6-23
6-14	TEST E: FFT/RAM A30 .....	6-29
6-15	TEST F: Digital Filter A20 .....	6-35
6-16	TEST G: Input Amplifier/Digitizer A10, A15 .....	6-39
6-17	TEST H: Local Oscillator/Noise Source A50 .....	6-45
6-18	TEST I: CMOS/Bubble Memory A66, A65 .....	6-49
6-19	DIAGNOSTIC/SELF TEST DESCRIPTIONS .....	6-50
6-20	Introduction .....	6-50
6-21	Test Menu Explanation .....	6-52
6-22	General Error Code Format .....	6-54
6-23	Test 0: Power-On Test .....	6-55
6-24	Test 1 Quick Functional Test .....	6-61
6-25	Test 12 A30 FFT Test .....	6-63
6-26	Test 13 A20 Timing Counter Test .....	6-64
6-27	Test 14 A20 Digital Filter/DMA Channel R Test .....	6-65
6-28	Test 18 A20 DMA Channel G And Trigger Test .....	6-67
6-29	Test 19 A65/A66 CMOS Memory Test .....	6-69
6-30	Test 20 A65 Bubble Memory Test .....	6-69
6-31	Test 50 Display Pattern Test .....	6-71
6-32	Test 52 A10 Calibrator Adjustment .....	6-71
6-33	Test 53 A10 20dB Flatness Adjustment .....	6-72
6-34	Test 54 A10 40dB Flatness Adjustment .....	6-74
6-35	Test 110 A10 Front End Control Register Test .....	6-75
6-36	Test 111 - 116 A15 Timing and Control Circuit Setups .....	6-76
6-37	Test 118 Display Calibration Constants .....	6-76
6-38	Test 119 Clear Calibration Constant .....	6-77
6-39	Test 120 A20 Digital Filter DSA .....	6-77
6-40	Test 121 A20 Timing Counter DSA .....	6-77
6-41	Test 122 A20 DMA Channel G DSA .....	6-78
6-42	Test 123 A20 DMA Channel R DSA .....	6-78
6-43	Test 150 A50 Local Oscillator DSA .....	6-78
6-44	Test 151 A50 Analog Source Test .....	6-79
6-45	Test 152 A50 Noise Source DSA Setup 1 .....	6-79
6-46	Test 153 A50 Noise Source DSA Setup 2 .....	6-80
6-47	Test 154 A50 HP-IB I/O Verification Test Routine .....	6-80
6-48	Test 167 A65 Bubble Memory Read DSA .....	6-83
6-49	Test 168 A65 Bubble Memory Bootloop Routine .....	6-84
6-50	Test 169 A65 Bubble Memory Reseed Routine .....	6-92
6-51	Test 170 A65 Format Nonvolatile Memory Routine .....	6-93
6-52	OVERALL INSTRUMENT THEORY OF OPERATION .....	6-94
6-53	Introduction to Theory of Operation .....	6-94
6-54	Control Circuits and Bus Structure .....	6-94
6-55	Measurement Data Flow .....	6-95

## **SECTION VI**

# **FAULT ISOLATION**

---

### **6-1 INTRODUCTION**

The information given in this section is used to isolate failures to a circuit board. Once the failure is isolated to a circuit board, the information given in Section 7 is used to further isolate the failure to a component. Figure 6-1 illustrates the use of the information given in this section. The fault isolation procedure is the primary tool for isolating a failure to the circuit board level. To isolate a failure, start the fault isolation procedure with TEST A, and continue with each test in alphabetical order until one of the test fails. The failed test will indicate the circuit board which most likely caused the failure. Troubleshooting to the component level on the failed circuit board can then be continued in Section 7.


The self calibration paragraph describes the 3561A's self calibration procedure and lists the calibration failure messages.

The troubleshooting guidelines paragraph gives a list of failure symptoms and the corresponding circuit boards which most likely caused the failure. A recommended starting point in the fault isolation procedure is listed for each failure symptom.

The diagnostic/self-tests paragraph contains a description of each of the internal diagnostic routines. For each test, a description of how the test works and a list of return codes is given.

The overall instrument theory of operation paragraph gives a description of the interaction of the circuit boards in the -hp-3561A.

Figure 6-1 Fault Isolation Procedure Flow Chart



## 6-2 SAFETY CONSIDERATIONS

### WARNING

*Maintenance described herein is performed with power supplied to the instrument and with the protective covers removed. Such maintenance should be performed only by service-trained personnel who are aware of the hazards involved (for example, electrical shock and fire).*

*Any interruption of the protective grounding conductor inside or outside the instrument, or disconnection of the protective earth terminal, is likely to make the instrument hazardous.*

### WARNING

*$\pm 170$  Volts are present on the A70 and A71 Assemblies.  $\pm 170$  Volts are present on the heat sinks on the A70 Assembly. This voltage is exposed whenever the protective power supply cover is removed. Be extremely careful when working in proximity to this area. The high voltage can cause serious personal injury if contacted.*

### WARNING

*Capacitors in the power supply will remain charged to  $\pm 170$  Volts dc for at least three(3) minutes after power is removed from the instrument. Do not remove the power supply assemblies (A70, A71, A72) for at least three(3) minutes after power is removed from the -hp-3561A.*

### WARNING

*Only fuses with the required current rating and of the specified type should be used for replacement. The use of repaired fuses or short circuiting the fuse holder is not permitted. Whenever it is likely that the protection offered by the fuse has been impaired, the instrument must be made inoperative, and secured against any unintended operation.*

### WARNING

*+ 8000 Volts are present in the CRT AT ALL TIMES, EVEN WHEN POWER IS REMOVED FROM THE INSTRUMENT. Be extremely careful when working in proximity to this area. The high voltage can cause serious personal injury if contacted.*

### 6-3 RECOMMENDED TEST EQUIPMENT: FAULT ISOLATION

The test equipment required to perform the fault isolation procedure is listed in Table 1-5 and in Table 6-1. If the recommended equipment is not available, a substitute which meets or exceeds the required characteristics given in Table 1-5 may be used.

**Table 6-1 Recommended Test Equipment for Fault Isolation**

Description	Recommended Model Number
Frequency Synthesizer	-hp-3325A
Oscilloscope	-hp-1980A
Digital Voltmeter	-hp-3455A
Extender Card (44 pin)	-hp-03561-66595
Extender Card (50 pin)	-hp-03561-66596

### 6-4 SELF CALIBRATION

#### 6-5 Calibration Procedure

The -hp-3561A is equipped with a self calibration circuit which is used to determine measurement correction factors. A full calibration consists of three steps: 1) Auto Zero, 2) PRN Magnitude and Phase Calibration, and 3) Harmonic Calibration.

A full calibration is performed whenever the SINGLE CAL softkey is pressed and every 30 minutes after instrument warm up. During warm up, full calibrations are performed as follows:

- At turn on
- 5 minutes after turn on
- 15 minutes after turn on
- 35 minutes after turn on
- Every 30 minutes

In addition, auto zero is performed whenever the instrument range function is changed.

#### AUTO ZERO

The auto zero digital to analog converter on the A10 Assembly is programmed for a minimum DC response.

## PRN MAGNITUDE AND PHASE CALIBRATION

The PRN CAL signal which is generated on the A20 Assembly is selected as the input to the A10 cal level generator. A spectrum is taken and the results are used to calculate a set of magnitude and phase correction factors. These correction factors are stored by the processor and used to correct measurement data. Self test 118 may be used to read the correction factors and self test 119 may be used to clear the correction factors to zero. A complete description of these self tests is given in the diagnostics/self-test section of this manual.

## HARMONIC CALIBRATION

A 2 kHz square wave is selected as the input to the cal level generator on the A10 Assembly. A spectrum is measured and the results used to calculate a time delay correction factor used for triggered measurements. This correction factor is added to the magnitude and phase correction factors and may be read and cleared in the same way.

### 6-6 Calibration Failures

When the calibration procedure encounters a failure, a failure message is immediately displayed on the CRT screen and the calibration procedure is stopped. Failure messages are listed below in the order in which they occur in the calibration procedure. For each cal failure, the assemblies which most likely caused the failure, the recommended starting point in the fault isolation procedure, and possible adjustments to correct the failure are listed.

#### NOTE

*Calibration error messages remain on the CRT screen for ten seconds unless a second error is detected. A second failure message occurring less than one second after the original failure is not displayed. A second failure message occurring more than one second after the original failure replaces the original failure message.*

Table 6-2 Cal Failures

Error Message and Description	Assemblies	Fault Isolation	Adjustments
CAL FAILURE: DMA TIME OUT The Digital Filter or DMA counter on the A20 assembly is not responding to the micro-processor.	A20	TEST E	
CAL FAILURE: A/D COUNTER MISMATCH The timing and control counter on the A20 Assembly is giving inconsistent readings on consecutive measurements of the cal signal.	A15, A20	TEST F	
CAL FAILURE: FFT TIME OUT The FFT processor on the A30 assembly is not responding to the microprocessor.	A30	TEST E	
CAL FAILURE: PRN PHASE BAD AT 2 KHZ The phase of the PRN calibration signal is too far off to be corrected. Large amplitude errors or a DC offset error will also result in a phase error and this error message.	A10, A15 A20	TEST F	A10, A15
CAL FAILURE: CORRECTION TOO LARGE The Amplitude of the PRN calibration signal is too far off to be corrected.	A10, A15	TEST F	A10, A15
CAL FAILURE: NO TRIGGER No input trigger has been sent from the A15 Assembly trigger comparator.	A10, A15 A20	TEST F	
CAL FAILURE: 64 KHZ PHASE UNDEFINED Unable to calculate the phase of the A20 64 kHz harmonic.	A10, A15 A20	TEST F	

## 6-7 TROUBLESHOOTING GUIDELINES

Table 6-3 lists several failure symptoms, the assembly which most likely caused the failure, and the suggested starting point in the Fault Isolation Procedure. If a fault isolation test is not listed, proceed with troubleshooting in Section 7 with the first assembly listed in the table. These failure symptoms are guidelines to shorten the repair time but do not contain all possible failures. When in doubt about a particular failure, start the fault isolation procedure at TEST A. Failure symptoms listed in Table 6-3 are organized as either general symptoms or as a symptom associated with a particular front panel key operation.

## OPERATING DIAGNOSTIC MESSAGES

Diagnostic messages will be displayed during normal operation. Many of the messages indicate the status of the -hp-3561A such as the message "AVG COMPLETE," or an incorrect key sequence such as the message "COMMAND INVALID FOR TIME TRACE." The messages listed below may indicate a hardware failure.

Table 6-3 Failure Symptom Table

## OPERATING DIAGNOSTIC MESSAGES

Symptom of Failure (Diagnostic Message):	Troubleshooting	
	Assemblies	Fault Isolation
BUBBLE MEMORY ERROR: CANNOT INITIALIZE	A65	
BUBBLE MEMORY ERROR: RECALL FAILED	A65	
BUBBLE MEMORY ERROR: STORE FAILED	A65	
CANNOT PERFORM RECALL: FILE DATA INVALID	A66/65	
CHECKSUM ERROR DETECTED	A50	
CMOS MEMORY ERROR: RECALL FAILED	A66/65	
DMA ERROR DETECTED	A20, A30	TEST E
DMA ERROR DURING AUTO RANGE	A20, A30	TEST E
ESR PHASE COUNTER OVERFLOW	A20	
EXTERNAL SAMPLE CLOCK < 5HZ OR INCOMPATIBLE	A20	
EXTERNAL SAMPLE TOO FAST OR INCOMPATIBLE	A15, A20	TEST F
FFT ERROR DETECTED	A30	TEST E
FRONTEND PROGRAMMING ERROR DETECTED	A10, A15	TEST G
	A20	
NO INTERNAL CLOCK	A40, A20	TEST D
NONVOLATILE MEMORY ERROR: FORMAT REQUIRED	A65	
Indicates a hardware error only if the format routine (self test 170) fails to correct the failure.		

## GENERAL SYMPTOMS

Symptom of Failure:	Troubleshooting	
	Assemblies	Fault Isolation
Harmonic distortion failure.	A10, A15 A20	
Instrument completely dead, no front panel LEDs turned on, and no display.	A70, A71 A72	TEST A
Instrument locks during the power on test.	A70, A71 A72, A40	TEST A
Keyboard responds properly but display is incorrect.	A60, A90	TEST C
Input signal amplitude varies with frequency.	A15, A10	
Input signal amplitude is incorrect.	A15, A10 A20	TEST F
Noise Level is too high.	A10, A15 A20	TEST F
Power on Test Failure - RETURN CODE (0 X XX)	A40, A30 A20, A50 A60, A65	TEST B



**FRONT PANEL KEY - MODE****GENERAL HEADINGS - EXTERNAL SAMPLE, THIRD OCTAVE, FULL OCTAVE, TIME CAPTURE**

<b>Symptom of Failure:</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Instrument works properly in all modes except external sample mode.	A20, A82	TEST E
Instrument works properly in external sample mode but not in internal sample mode (external sample off).	A20	
Instrument works properly in all modes except third octave and full octave.	A30, A20	
Instrument works properly in third octave and full octave modes but not in narrow band mode.	A20, A30	

**FRONT PANEL KEY - TRIG SEL, ARM****GENERAL HEADINGS - INPUT TRIGGER, EXTERNAL TRIGGER, SOURCE TRIGGER, HP-IB TRIGGER**

<b>Symptom of Failure</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Instrument works properly with input trigger but not with external trigger.	A20, A82 W82	TEST F
Instrument works properly with external trigger but not with input trigger.	A15, A10 A20	
Instrument works properly with all triggers except HP-IB trigger or source trigger.	A50 W82	

**FRONT PANEL KEY - SOURCE****GENERAL HEADINGS - PERIODIC SOURCE, IMPULSE SOURCE, RANDOM SOURCE, SOURCE SYNC**

<b>Symptom of Failure</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Rear panel noise source output ("SOURCE OUT") is incorrect. Amplitude incorrect, flatness incorrect, etc.	A50, A82 W50	
Random noise source works properly but impulse or periodic source do not.	A50	
Impulse and periodic source work properly but random source does not.	A50	
Noise source output works properly, but the "SOURCE SYNC" output does not.	A50	

**FRONT PANEL KEY - DEFINE TRACE****GENERAL HEADINGS - MAGNITUDE, PHASE, TIME**

<b>Symptom of Failure</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Magnitude trace works properly, but phase trace does not work properly.	A20	TEST F
All traces work properly except input time and input magnitude.	A20	TEST F
Input time and input magnitude are the only traces that work properly.	A20	TEST F

**FRONT PANEL KEY - STORE/RECALL, SAVE, RECALL**

<b>Symptom of Failure</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Invalid data stored in M1 or M2, or in the six instrument states S1 -S6.	A30, A65	TEST D
Cannot store or recall a catalog file.	A65	TEST I
File catalog lost.	A65	TEST I

**FRONT PANEL KEY - RANGE**

<b>Symptom of Failure</b>	<b>Troubleshooting</b>	
	<b>Assemblies</b>	<b>Fault Isolation</b>
Instrument works properly in some range settings and improperly in other range settings.	A10, A15 A20	TEST G
Instrument does not auto-range.	A10, A15 A20	TEST G
Over-range LED or half-range LED is constantly on.	A10, A15 A20	TEST G

**FRONT PANEL KEY - INPUT****GENERAL HEADINGS - CALIBRATION/CAL SIGNAL, AD/DC COUPLING, A WEIGHT FILTER, ICP CURRENT SOURCE**

Symptom of Failure	Troubleshooting	
	Assemblies	Fault Isolation
Instrument fails in ac coupling only or in dc coupling only.	A10	TEST G
Instrument fails only when the A-Weight filter is enabled.	A10	
ICP current source fails.	A10	
Cal signal appears incorrect.	A10, A15	

**FRONT PANEL KEY - LCL, HP-IB BUS OPERATION****FAULT SYMPTOM OF FAILURE ASSEMBLIES ISOLATION**

Symptom of Failure	Troubleshooting	
	Assemblies	Fault Isolation
Instrument works properly from the front panel but does not respond to HP-IB commands.	A50, A82 W82	
Instrument works properly with INPUT TRIGGER and EXTERNAL TRIGGER but does not respond to HP-IB TRIGGER.	A50, A82 W82	
Instrument will not drive plotter.	A50, A82 W82	
Noise source output works correctly in Baseband mode, but not in zoom mode.	A50	

**FRONT PANEL KEY - FREQ****GENERAL HEADINGS - BASEBAND OPERATION, ZOOM OPERATION, FREQUENCY SPAN**

Symptom of Failure	Troubleshooting	
	Assemblies	Fault Isolation
Instrument works properly with a 100 kHz frequency span but not with a frequency span of less than 100 kHz.	A20	TEST F
Instrument works properly in baseband mode (start frequency = 0 Hz) but not in zoom mode (start frequency > 0 Hz or set center).	A50, A20	TEST F
Frequency readings are incorrect.	A40, A20 A15	TEST D

## 6-8 FAULT ISOLATION PROCEDURE

### WARNING

*Maintenance described herein is performed with power supplied to the instrument and with the protective covers removed. Review Paragraph 6-2, "SAFETY CONSIDERATIONS" before performing the Fault Isolation Procedures.*

### CAUTION

*Do not remove circuit assemblies when the -hp-3561A LINE power switch is ON.*

### CAUTION

*The -hp-3561A contains components which may be damaged as a result of static discharge. Remove circuit assemblies from the -hp-3561A only at a static protected work station.*

## 6-9 Using the Fault Isolation Procedure

The fault isolation procedure uses the internal diagnostic test routines and waveform comparison to isolate a failure to the circuit board level. The fault isolation procedure should be started with TEST A unless the symptoms of the failure indicate otherwise (see Paragraph 6-7, "Troubleshooting Guidelines"). Once the fault isolation procedure is started, the remaining tests should be run in sequence. When a fault isolation test fails, the test will indicate the assembly which most likely caused the failure, and the paragraph in Section 7 where troubleshooting can be continued to the component level. The experienced technician will be able to skip certain tests if the circuits are obviously working correctly (eg., the display driver tests may be skipped if the display is operational).

The fault isolation procedure does not detect every possible failure. If a failure is not detected, the performance test (Section 2) can be used to further test the -hp-3561A.

**NOTE**

*Except where otherwise noted, oscilloscope waveforms shown in this manual are measured with a 10:1 oscilloscope probe. To obtain the actual signal levels, multiply the volts per division value by ten(10).*

**NOTE**

*Some power supply failures may appear to be processor or RAM bus failures. In addition, some of the power supplies provide power to selected components (eg., the +8 Volt supply powers the digital filter only). A failure in one of these supplies may be mistaken for a component failure.*

**Table 6-4 Fault Isolation Procedure Summary**

Test Number	Description	Assemblies Tested
TEST A	Bias Power Supply	A71, A99
TEST B	Main Power Supply	A70, A71, A72, A99
TEST C	Display Driver	A60, A90, A99
TEST D	Processor/ROM	A40, A81
TEST E	FFT/RAM	A30
TEST F	Digital Filter	A20
TEST G	Digitizer/Input Amplifier	A15, A10
TEST H	Local Oscillator/Noise Source	A50
TEST I	CMOS/Bubble Memory	A65, A66

**6-10 TEST A: Bias Power Supply A71, A99**

The bias power supply provides power to the main power supply components.



**WARNING**

*±170 Volts are present on the A70 and A71 Assemblies. ±170 Volts are present on the heat sinks on the A70 Assembly. Be extremely careful when working in proximity to this area. The high voltage can cause serious personal injury if contacted.*

1. Turn the -hp-3561A LINE power switch ON.
2. Check for  $+12 \pm 0.6$  Vdc at test point A71 TP''+12BIAS'', and for  $-12 \pm 0.6$  Vdc at test point A71 TP''-12BIAS'' as shown in Figure 6-2.
3. If the bias supply voltages are incorrect, proceed with troubleshooting the A71 Assembly (Section 7: "Power Supply").

Continue with **TEST B** on Page 6-14 .

Figure 6-2 A71 Component Locator



**6-11 TEST B: Main Power Supply A70, A71, A72, A99****WARNING**

*±170 Volts are present on the A70 and A71 Assemblies. ±170 Volts are present on the heat sinks on the A70 Assembly. Be extremely careful when working in proximity to this area. The high voltage could cause serious personal injury if contacted.*

The main power supply is a switching-regulated, +5V logic supply. Several other linear-regulated supply voltages are derived from this "master" +5 Volt supply. Thus, a failure in the +5 Volt logic supply will affect all other power supply voltages. A shut-down protection circuit monitors all of the power supply outputs for an over-voltage, or a primary over-current condition. If a failure is detected, the protection circuit will shut down the power supply and light an LED to indicate the cause of the failure.

Power supplies in the -hp-3561A are divided into two categories: power supplies referenced to the chassis ground, and power supplies referenced to the isolated (or floating) ground. The isolated ground is a completely separate ground derived from the power transformer. All voltages referenced to the isolated ground are marked with an "I" (eg. +15 V<sub>I</sub>). Voltages referenced to the isolated ground cannot be measured in with respect to the chassis ground unless the front panel ground switch is in the CHASSIS position.

TEST B: Main Power Supply








Figure 6-5 Voltage Regulator Locations and Pinouts



**6-12 TEST C: Display Driver A60, A90, A99****WARNING**

*+450 Volts and -150 Volts are present on the A90 and A99 Assemblies. Be extremely careful when working in proximity to this area. The high voltage could cause serious personal injury if contacted.*

The -hp-3561A display driver is divided into two circuit assemblies, the digital display driver (A60), and the analog display driver (A90). The digital display driver receives display data directly from the central processor. It then reformats the data into the CRT video drive, horizontal sweep, and vertical sweep signals. The analog display driver converts these signals into the actual analog CRT drive signals.

Figure 6-6 -hp-3561A CRT Test Pattern






Figure 6-9 PLANE1 Full Bright Waveforms



Probe: 10:1  
Ch1: Connection- A60TP201 "VIDF"  
Coupling- dc  
Ground- Center Graticule  
Trigger: External- A60TP302 "SSYNC"  
Slope- Positive  
Bandwidth Limit: OFF

Figure 6-7 A60 Component Locator



**TEST C: Display Driver**

**Display Test**

1. Turn the -hp-3561A LINE power switch ON.
2. Move the A60 Assembly test jumper J100 to the PLANE2 (half bright) position as shown in Figure 6-7.
3. Check the -hp-3561A CRT screen for the display shown in Figure 6-6. Check for brightness, alignment, size, focus, and vibration of the pattern.
4. Move the A60 Assembly test jumper J100 to the PLANE1 (full bright) position as shown in Figure 6-7.
5. Check the -hp-3561A CRT screen for the display shown in Figure 6-6. The pattern should be brighter than the PLANE2 pattern. Check for brightness, alignment, size, focus, and vibration of the pattern.
6. If both display patterns are correct, move test jumper A60 J100 back to the RUN position, and press the -hp-3561A front panel PRESET key.

Fail: One or both CRT patterns are incorrect.

**Digital Display Driver**

1. Move the A60 Assembly test jumper J100 to the PLANE2 (half bright) position as shown in Figure 6-7, and use an oscilloscope to check for the waveforms shown in Figure 6-8.
2. Move the A60 Assembly test jumper J100 to the PLANE1 (full bright) position as shown in Figure 6-7, and use an oscilloscope to check for the waveforms shown in Figure 6-9.
3. Move the A60 Assembly test jumper J100 back to the RUN position and press the front panel PRESET key.

Fail: One or more of the waveforms is incorrect.

Pass: All of the waveforms are correct.

Pass: Both CRT patterns are correct.

**TEST C Complete.**  
Continue with  
**TEST D**

Troubleshoot the A60 Assembly (Section 7:"Digital Display Driver")

Troubleshoot the A90, A99 Assemblies  
(Section 7:"Analog Display Driver").

### 6-13 TEST D: Processor/ROM A40

The A40 Assembly contains the central processor, ROM, and the master 20.48 MHz clock. Failures on the A40 Assembly will usually result in the instrument not completing its power up routine, or in a power on test return code. This test gives a high probability of isolating the failure, but does not exhaust all possible failures. If a bus failure is suspected which is not isolated by this routine, a more complete bus test using signature analysis is given in the "Processor/ROM" paragraph of Section 7.

When the power is turned on, the main processor will perform diagnostic self tests 0 and 1. For more information on these tests, refer to Paragraph 6-18 "Diagnostic/Self-Test Descriptions."

### DISPLAY ACTIVITY DURING POWER ON TEST

When power is first applied, the message "POWER ON TEST IN PROGRESS" is displayed at the top of the CRT screen for approximately three seconds (for approximately one second when the A30 Assembly is removed). A test pattern is then displayed and erased, which requires approximately three seconds. When the display pattern is completely erased, the "POWER ON TEST IN PROGRESS" message is again displayed at the top of the CRT screen for approximately two seconds. The power on test is then complete and initiates the measurement display if no failures are encountered, or displays a return code for each failure encountered.

### FRONT PANEL LED ACTIVITY DURING POWER ON TEST

When power is first applied, all of the front panel LEDs turn on for approximately three seconds (for approximately one second when the A30 Assembly is removed). The LEDs then turn off for approximately three seconds while the test pattern is being displayed and erased on the CRT. The LEDs then turn on for approximately two more seconds. The power on test is then complete and initiates normal measurement operation if no failures are encountered or displays a return code on the LEDs for the failures encountered. The front panel LED return code descriptions are given in Figure 6-10.

### SUMMARY OF TEST 0 RETURN CODES

#### Processor Failures (A40)

**0 3 25**

**0 8 01 through 0 8 24**

#### RAM Failures (A30)

**0 7 26**

**0 3 27**

**0 7 31**

#### Interrupt Failure (A40)


**0 2 30**

#### Display Failures (A60)

**0 7 28**

**0 3 29**

Figure 6-10 Front Panel LED Return Codes



Example:

EXT SAMP	-ON	16
AVG	-OFF	0
TIME BUFFER	-OFF	0
MEAS	-ON	2
TRIG	-OFF	0
Return Code = 18		

LED	Description
EXT SAMP	Has a value of 16 in the return code when turned on.
AVG	Has a value of 8 in the return code when turned on.
TIME BUFFER	Has a value of 4 in the return code when turned on.
MEAS	Has a value of 2 in the return code when turned on.
TRIG	Has a value of 1 in the return code when turned on.
ARM	More than one failure occurred during the power on test.
RMT	An A40 Assembly failure occurred during the power on test.
SRQ	An A60 Assembly failure occurred during the power on test.
LTN	An A30 Assembly failure occurred during the power on test.






Figure 6-13 A40 Component Locator




Figure 6-14 20.48 MHz Master Clock Waveform





Figure 6-15 RAM Handshake Waveforms



**6-14 TEST E: FFT/RAM A30**

The A30 Assembly contains the instrument RAM and the FFT Processor. The FFT processor is a separate microprocessor with its own ROM and an asynchronous clock. This test uses the power up test and self test 12 to verify proper operation of the A30 Assembly.






Figure 6-16 A40 Component Locator




Figure 6-17 A30 Component Locator






Figure 6-18 RAM Bus Arbitrator Waveforms





**6-15 TEST F: Digital Filter A20**

The A20 Assembly contains the digital filters, DMA address counters, main trigger counter, and phase counter. The digital filters receive data from the A15 Assembly and the A50 Assembly. The processed data is then transferred to the main RAM on the A30 Assembly. This test uses self tests 13, 14, and 18 to verify correct operation of the A20 Assembly and assumes proper operation of the A30 Assembly.




Figure 6-19 A20 Component Locator





Figure 6-20 A20 I/O Signal Waveforms



**6-16 TEST G: Input Amplifier/Digitizer A10, A15**

The A10 Assembly contains the input amplifiers and attenuators used to set the instrument range. The A15 Assembly contains the 100 kHz low pass anti-alias filter, the A/D converter, the trigger level comparators, and the overload/underload comparators.

The central processor controls the A10 and A15 Assemblies through the front end control latch on the A20 Assembly. Programming data is passed first through the A10 Assembly, and then to the A15 Assembly. Thus, the A10 Assembly must be installed for the A15 Assembly to operate.

Test G does not check for distortion failures. To isolate known distortion failures between the A10 Assembly and the A15 Assembly, refer to the A10 Assembly troubleshooting information given in Section 7 (Section 7: "Input Amplifier").

6-23 A10 Assembly Output Waveforms


Probe: 10:1

Ch1: Connection- A10 TP"OUTPUT"  
Coupling- dc  
Ground- Center Graticule

Trigger: Internal- Ch1  
Slope- Positive

Bandwidth Limit: ON

Signal Amplitude = .2281  $\pm$  .04 Vrms



Probe: 10:1

Ch1: Connection- A15 TP"COMP IN"  
Coupling- dc  
Ground- Center Graticule

Trigger: Internal- Ch1  
Slope- Positive

Bandwidth Limit: ON

Signal Amplitude = .9124  $\pm$  .18 Vrms




Figure 6-21 Input Signal Test Equipment Setup





Figure 6-22 8 kHz Sine Wave



TEST G: Input Amplifier/Digitizer

Input Signal Test

**NOTE**  
This test can be repeated at any -hp-3561A range setting. The waveforms given in Figure 6-23 are valid as long as the amplitude of the input sine wave is equal to the -hp-3561A range setting.

- Connect the frequency synthesizer output to the -hp-3561A front panel input through a 50  $\Omega$  feedthrough termination as shown in Figure 6-21.
- Set the frequency synthesizer controls as follows:  
  
Frequency ..... 8 kHz  
Amplitude ..... 1 Vrms (0 dBV)  
Function ..... Sine Wave
- Set the -hp-3561A controls as follows:  
  
PRESET .....  
RANGE ..... DEFINE RANGE ..... 0 dBV  
TRIGGER SELECT TRIGGER  
INPUT TRIGGER  
SETUP SELECT ..... DEFINE % OF RNG. 50 %  
SLOPE POS  
Marker ..... DEFINE MKR POS ..... 8 kHz
- The -hp-3561A CRT screen should appear as shown in Figure 6-22. The front panel "OVER" LED should be off, the "TRIG" and "MEAS" LEDs should be blinking, and the "ARM" and "HALF" LEDs should be on.

Pass: The -hp-3561A display and front panel LEDs are correct  
TEST G Complete.  
Continue with TEST H

Fail: The -hp-3561A display or front panel LEDs are incorrect.

A10 Output Signal Test

- Do not change the frequency synthesizer or the -hp-3561A controls or connections.
- Use an oscilloscope to check the waveforms shown in Figure 6-23. The signal test locations are shown in Figure 6-24.
- Check the voltage at the A15 Assembly test point TP"TRIG LVL" for .64  $\pm$  .06 Vdc.


Fail: One of the signals or the trigger level voltage is incorrect.

Troubleshoot the A10 Assembly (Section 7: "Input Amplifier").

Pass: Both of the signals and the trigger level voltage are correct.

TEST G Continued on next page.

Figure 6-24 A10/A15 Component Locators






Figure 6-25 A20 Component Locator




Figure 6-26 A15 Component Locator




Figure 6-27 A15 Programming Waveforms





Figure 6-28 A20 Programming Waveforms



**6-17 TEST H: Local Oscillator/Noise Source A50**

The A50 Assembly contains the noise source, the HP-IB interface, and the local oscillator circuits.

The noise source provides three types of noise outputs; random, periodic, and impulse. When the periodic source is selected, the "SOURCE SYNC" rear panel output provides a trigger pulse. If problems are encountered with the noise source, and the A20 I/O signal test passed, the failure is most likely on the A50 Assembly. Troubleshoot the A50 Assembly noise source circuit (Section 7:"Local Oscillator/Noise Source").

The HP-IB circuit provides an interface between the central processor and the rear panel HP-IB connector. If problems are encountered during HP-IB operation only, troubleshoot the A50 Assembly HP-IB circuit (Section 7:"Local Oscillator/Noise Source").

The local oscillator provides a digital sine wave to both the digital filter and the noise source. The local oscillator frequency is set equal to the center frequency when the -hp-3561A is operated in "zoom" mode (when the start frequency is set to greater than 0 Hz or the "SET CENTER" softkey is used). For a more complete test of the local oscillator refer to the "Local Oscillator/Noise Source" paragraph in Section 7.

**NOTE**

*If the -hp-3561A passes the local oscillator test but does not operate correctly in "zoom" mode, the most likely cause of the failure is the data latch or the digital filters on the A20 Assembly (Section 7:"Digital Filter")*



**TEST H: Local Oscillator/Noise Source**

**Local Oscillator Test**

In this test, the noise source circuitry is used to output the local oscillator signal. The noise source output is checked first to verify the signal path, then self test 151 is used output the local oscillator signal.

1. Connect the -hp-3561A rear panel "SOURCE OUT" output to the 3561's front panel BNC connector.
2. Set the -hp-3561A controls as follows:  
  
PRESET  
WINDOW .....UNIFORM  
SOURCE .....PERIODIC NOISE  
                DEFINE ATTEN.....0 dB  
TRIGger SElect TRIGGER  
                SOURCE TRIGGER
3. The -hp-3561A display should appear as shown in Figure 6-29. This verifies that the noise source signal path is operational. The marker should read -23 dBV  $\pm$  1.5 dB at 50 kHz.
4. Set the -hp-3561A controls as follows:  
  
PRESET  
MODE .....TEST SELECT.....DEFINE TEST NUM .151 ENTER  
                                  START CONT TST
5. Use an oscilloscope to check the local oscillator signal at the "SOURCE OUT" rear panel connector. The sine wave should appear as shown in Figure 6-30.


**Fail:** The local oscillator Sine wave is incorrect.

Troubleshoot the A50 Assembly (Section 7:"Local Oscillator/Noise Source").


**Pass:** The local oscillator sine wave is correct.

**TEST H** Complete.  
Continue with  
**TEST I**

**Figure 6-29 Periodic Noise Source Display**



**Figure 6-30 Local Oscillator Output in self test 151**



**6-18 TEST 1 CMOS/Bubble Memory A65, A66**

Every instrument is equipped with either an A65 or an A66 Assembly. The A65 Assembly contains CMOS and bubble memory; the A66 Assembly contains only CMOS memory. Use the bubble memory test only if the instrument under test is equipped with an A65 Assembly.



*Removing power, or turning the LINE power switch OFF while self test 20 is running, could result in permanent damage to the bubble memory.*

**CMOS Memory Test**

1. Set the -hp-3561A controls as follows:

PRESET  
MODE .....TEST SELECT .....DEFINE TEST NUM ...19 ENTER  
START SNGL TST

2. The test should complete with no return codes. If any return codes are given, troubleshoot the CMOS memory on the A66/65 Assembly (Section 7: "CMOS/Bubble Memory").

**Bubble Memory Test**

1. Set the -hp-3561A controls as follows:

PRESET  
MODE .....TEST SELECT .....DEFINE TEST NUM ...20 ENTER  
START SNGL TST

2. The test should complete with no return codes. If any return codes are given, troubleshoot the bubble memory on the A65 Assembly (Section 7: "CMOS/Bubble Memory").

## 6-19 DIAGNOSTIC/SELF-TEST DESCRIPTIONS

### 6-20 Introduction

#### NOTE

*The following information documents the meaning of the diagnostics and their Error Return Codes. If the -hp-3561A displays an Error Return Code during power-on or operation, refer to the Fault Isolation information in the front of this section for failure identification.*

The -hp-3561A has many built-in diagnostic routines. These diagnostic routines are used during instrument power-up, adjustments and troubleshooting. There are four types of test routines which are identified by their test number as follows:

Power-On Routine                      Number 0

This routine is only performed on power-on or if the 68000 CPU IC reset line is activated (manually by the technician or automatically by the Low-Line monitor circuit in the Power Supply). Test 1 is also executed as part of the power-on routine.

Functional Routines                      Numbers 1 through 49

In these test routines, the processor tests and verifies the results of the tests. Test failures will be indicated on the CRT.

Adjustment Routines                      Numbers 50 through 99

In these test routines, the instrument is programmed to make a measurement and display the resultant data on the CRT.

Service Tests                              Numbers 100 and up

In these test routines, specific instrument circuits are set to defined conditions which are then verified by external equipment. For example, a circuit can be stimulated or set-up so that digital signature analysis or oscilloscope timing waveforms can be observed. The processor does not verify the results of the setups.

All of the test routines depend on the proper operation of the Processor/ROM (A40), Power Supply (A70,A71,A72 and A99), the Display (A60 and A90) and the Front Panel Keyboard (A80 and A81) except for the power up routine Test #0. The power up routine depends on proper operation of the power Supply, Processor/ROM and either the Display or the Front Panel.

Note that even though there are tests with numbers greater than 100, there are only 34 test routines in the instrument. These 34 test routines and their names are listed in Table 6-12 and described in paragraphs 6-23 through 6-51.

**Table 6-12 -hp-3561A Diagnostic/Self Tests**

<b>Test Number</b>	<b>Description</b>
0	Power-On Test: Only run at power-on or when the microprocessor reset input is activated. This test checks the processor and its support circuitry. The routine cannot be initiated from the front panel.
1	Quick Functional Test: causes the -hp-3561A to make one measurement and verify the result. Test 1 is automatically run after Test 0 as part of the power-on routine.
12	Test 12 tests the FFT circuitry on the A30 FFT/RAM Assembly. The processor initiates the FFT circuits to perform a transform on fixed data and then checks the result.
13	A20 Timing Counter Test: Checks the operation of the Timing Counter IC and its support circuitry. Both circuits are located on the A20 Assembly.
14	Digital Filter/DMA Channel R Test: Used to test the Digital Filter and Channel R DMA Address Counter circuits on the A20 Digital Filter Assembly.
18	DMA Channel G/ Trigger Test: Used to test the Channel G DMA Address Counter and Trigger circuits on the A20 Digital Filter Assembly.
19	CMOS Memory Test: Writes and reads a known pattern to the A66 CMOS Memory Assembly to check the CMOS memory IC. This test is also used to check the CMOS memory IC on the optional A65 CMOS/Bubble Memory Assembly
20	Bubble Memory Test: Writes and reads a known pattern to the A65 CMOS/Bubble Memory Assembly to check the Bubble Memory module. Note: Bubble Memory is an option for the -hp-3561A.
50	Display Pattern Test: Used for the alignment of the CRT display.
52	Calibrator Adjust Test: Used in the adjustment procedure to properly set the Calibrator Signal.
53	20dB Attenuator Adjustment Test: Places the -hp-3561A in a mode of operation used to adjust the A10 Input Assembly 20dB attenuator flatness.
54	40dB Attenuator Adjustment Test: Places the -hp-3561A in a mode of operation used to adjust the A10 Input Assembly 40dB attenuator flatness.
110	Front End Control Register Test: Used in troubleshooting to check the A10 Input Assembly Front End Control Register.
111 through 116	Digitizer Test Register Setups: Used in troubleshooting the A15 Digitizer Assembly. These tests program various circuits on the A15 assembly enabling waveform verification using an oscilloscope.
118	Display Calibration Correction: Prints the Calibration constant on the CRT.
119	Clear Calibration Correction: Resets the Calibration Constant.
120	Digital Filter DSA Test: Programs the A20 Digital Filter Assembly for digital signature analysis. Test Description Number.
121	Timing Counter DSA Test: Programs the Timing Counter IC on the A20 Digital Filter Assembly for troubleshooting.

**Table 6-12 (Cont'd)**

122	DMA Channel G DSA Test: Used to troubleshoot the A20 DMA Channel G address counter circuit using Digital Signature Analysis.
123	DMA Channel R DSA Test: Used to troubleshoot the A20 DMA Channel R address counter circuit using Digital Signature Analysis.
150	Local Oscillator DSA Test: Programs the A50 Assembly for Digital Signature Analysis.
151	Analog Source DSA Test: Used to test the analog portion of the source output. The processor programs the source to output a sinewave of approximately 250Hz at 8Vp-p.
152	Noise Source DSA Setup 1: Programs the A50 Assembly for Digital Signature Analysis.
153	Noise Source DSA Setup 2: Programs the A50 Assembly for Digital Signature Analysis.
154	HP-IB Interface Test: Programs the -hp-3561A to continually read the HP-IB I/O lines and display their state on the CRT.
167	Bubble Memory Read DSA Test: Used to troubleshoot the A65 Bubble Memory Assembly in its Read mode using Digital Signature Analysis.
168	Bubble Memory Bootloop Routine: Rewrites the bootloop in the Bubble Memory. This test can only be accessed and executed through HP-IB. All stored data is destroyed by this test routine.
169	Bubble Memory Reseed Routine: Used to Reseed the Bubble Memory module. This routine requires the use of the Reseed module -hp- Part Number 1818-3304. This module is part of the -hp-3561A Service Kit P/N 03561-80004. Note: This routine causes all data in the Bubble Memory module to be lost.
170	Bubble Memory Format Routine: Used to format the A65 CMOS with Bubble information. This test routine is necessary to run only if the A65 CMOS IC or the battery were replaced. When executed, the instructions will be displayed on the front panel CRT.

### 6-21 Test Menu Explanation

The Test Menu is the CRT display which defines the softkeys used to access and control the built-in -hp-3561A test routines. The Test Menu is displayed by pressing the following -hp-3561A front panel keys:


```

PRESET
MODE ..... TEST SELECT

```

This will cause the CRT to display the Test Menu shown in Figure 6-31.

Figure 6-31 -hp-3561A Test Menu



The following text describes the meaning and uses of each of the Softkey functions.

**DEFINE TEST NUMBER:** Pressing this key allows the operator to enter the test routine number to be executed. When pressed, the CRT will change the softkey definitions to ENTER and CANCEL. At this point, press the front panel numeric keys to define the test routine number. When entering the test routine number from the front panel keyboard, the entries are displayed in the upper left-hand portion of the CRT. If an incorrect number is entered, use the BACK SPACE key or press the CANCEL softkey. Pressing the CANCEL softkey will cause the CRT to display the Test Menu. Press the ENTER menu key to store the number into the instrument and redisplay the test menu.

**START SINGLE TEST:** Press this key to execute the test routine once. When pressed, the CRT will indicate that the test is in progress and then complete. Some tests are very short and the "test in progress" may not be seen. Any errors will also be displayed.

START CONTInuous TeST:	Press this key to loop continuously on a test routine. When pressed, the CRT will indicate that the test is in progress. Also listed on the CRT will be any detected errors or continually updated test results.
STOP TEST:	Pressing this key will halt a test routine which is running.
ERRor STOP ON OFF	Pressing this key toggles the "stop on error" function. When on, the test stops on the first error detected and displays the error return code on the CRT. When off, the test will display any error return code on the CRT and continue executing the test routine.
EXIT TeST MODE:	Pressing this key will cause the instrument to terminate the test mode, execute a PRESET, and display the MODE menu on the CRT. This key is not active while a test is in progress.
CONTINUE:	This key is used by some of the tests which pause to display a message. Pressing this key will cause the test routine to continue its operation.

## 6-22 General Error Code Format

The general error code format is a CRT displayed message with a three section number. The message is "RETURN CODE =" and the three section number defines the error. The three sections identify the test routine number, the class of error and the error type, in that order. The test routine section can be a one, two or three digit number depending on the test routine number. The class section is always a single digit number from one to nine. The error type is always a two digit number.

For example:           RETURN CODE = 1 2 00

In the above example, the error detected is in test routine #1 as indicated by the first section number 1.

The second section is a 2 which indicates a timeout/no trigger problem. The explanation of the second section, error class, is given in Error Class Description following the next paragraph.

The third section is a 00 which indicates a DMA timeout problem. All third section error numbers are unique to the individual test routines. Their meaning is covered in the individual test descriptions in paragraphs 6-23 through 6-51.

## ERROR CLASS DESCRIPTION

The second section of the error code indicates the class of error. It is a single digit number from 1 to 9. The classes are explained as follows:

- Class 1 = Programming error which is the case when the processor performs a setup on a circuit and then cannot read or reads back an incorrect setup.
- Class 2 = Timeout error which occurs when a function is triggered or initiated and does not return a "finished" signal within the correct time.
- Class 3 = DTACK error where DTACK is the DaTa ACKnowledge signal used during the handshaking of data. An error results if the DTACK signal does not occur within a time period determined by the particular data transfer.
- Class 4 = Undefined
- Class 5 = Overload error.
- Class 6 = Random/Undefined data error.
- Class 7 = RAM data error.
- Class 8 = ROM checksum error.
- Class 9 = DMA address counter contains incorrect data.

## 6-23 Test 0 Power-On Test

### TEST DESCRIPTION

Test number 0 is automatically run during the initial power-on of the instrument (Test 1 is also run as part of the power-on routine). The power-on test checks the circuit block operations of the A30 FFT/RAM, A40 Main Processor and A60 Digital Display Driver Assemblies. These are the assemblies required to run the operating system. A failure during this test will result in an error message on the CRT display and an error pattern on the -hp-3561A front panel LEDs. Figure 6-32 shows the front panel LEDs used for error detection. The error numbers and their meaning are listed after the explanation of the test. Note that when more than one error is detected, only the first occurring error is indicated by the LEDs and the greater-than-one LED is illuminated. Also indicated by the LEDs is the assembly causing the error. The failing assembly would be the A30 FFT/RAM, A40 Processor or the A60 Digital Display Assemblies. However, all the errors detected are displayed on the CRT.



The circuits of the A30, A40 and A60 Assemblies are tested in the following order:


1. Turn on the front panel LEDs.
2. Check the main RAM on the A30 Assembly by writing and reading a known pattern.
3. Turn off the front panel LEDs.
4. Check the display RAM on the A60 Assembly by writing and reading a known pattern.
5. Turn on the front panel LEDs.
6. Check main ROM on the A40 Assembly by verifying their checksums.
7. Check the DaTACKnowledge signal for proper operation.
8. Turn off the front panel LEDs.
9. Display any errors and initiate the instrument's operating system.
10. Perform Test 1.

## **DEPENDENCY**

Test 0 depends on the proper operation of the following assemblies:

1. A70,A71,A72,A99 Power Supply Assemblies
2. A80 and A81 Front Panel Assemblies or A60,A90 Display Assemblies

Figure 6-32 Front Panel LED Error Indicators For Test 0



Example:

EXT SAMP    - ON            16  
AVG            - OFF         0  
TIME BUFFER- OFF         0  
MEAS         - ON            2  
TRIG          - OFF         0  
Return Code =               18

LED	Description
EXT SAMP	Has a value of 16 in the return code when turned on.
AVG	Has a value of 8 in the return code when turned on.
TIME BUFFER	Has a value of 4 in the return code when turned on.
MEAS	Has a value of 2 in the return code when turned on.
TRIG	Has a value of 1 in the return code when turned on.
ARM	More than one failure occurred during the power on test.
RMT	An A40 Assembly failure occurred during the power on test.
SRQ	An A60 Assembly failure occurred during the power on test.
LTN	An A30 Assembly failure occurred during the power on test.


**TEST 0 ERROR CODE DESCRIPTION**

The following is a list of all the error RETURN CODES which could be displayed during the power-on test 0. Included with the list of error RETURN CODES are their meaning.

**RETURN CODE      DESCRIPTION**


0 8 01  
through  
0 8 24

ROM Checksum Error where the defective ROM is identified by the two digit number of the return code. For example, return code 0 3 18 indicates a ROM checksum error in ROM U305 on the A40 Processor Assembly as indicated in the drawing below.



RETURN CODE	DESCRIPTION
-------------	-------------

0 3 25	DTACK error indicating that the Data handshake signal DaTaACKnowledge is not functioning properly.
0 7 26	Main RAM Error determined by writing to and reading from RAM and comparing the actual with the expected value. Also indicated with this error is a Chip Code which is displayed at the bottom of the CRT screen. The Chip Code will be a single hexadecimal number from 0 through F for each failure, indicating which RAM chip is defective. For example, if the Chip Code is B, then RAM U210 on the A30 FFT/RAM Assembly is defective as indicated in the drawing below.



RETURN CODE	DESCRIPTION
-------------	-------------


0 3 27	Main RAM DTACK Error indicates that the Main RAM DaTaACKnowledge handshake signal is not functioning properly.
0 7 28	Display RAM Error determined by writing to and reading from the Display RAM and comparing the actual with the expected value. Also indicated with this error is a Chip Code which is displayed at the bottom of the CRT screen. The Chip Code will be a single alpha character between G and Z for each failure, which will indicate the defective RAM. Use the following Plane Bit Vs. Chip table to determine which Display Ram is defective.

Plane 1 bit: 0 1 2 3 4 5 6 7  
Chip Code : G H J K L M N P

Plane 2 bit: 0 1 2 3 4 5 6 7  
Chip Code : R T U V W X Y Z

For example, if the RETURN CODE was 0 7 28 with a chip code of N, this indicates a Display RAM IC error in bit 6 of Plane 1 which is A60U5. See the diagram below to cross-reference the chip codes with the actual IC.

0 3 29	Display DTACK Error indicates that the Display RAM DaTaACKnowledge handshake signal is not functioning properly.
--------	--



RETURN CODE	DESCRIPTIONS
0 2 30	Unexpected Interrupt indicates that an interrupt was generated out of sequence.
0 7 31	RAM Refresh Test Error

## **6-24 Test 1 Quick Functional Test**

### **TEST DESCRIPTION**

The Quick Functional Test takes a zoom measurement on the built in 4kHz cal signal and checks for a correct spectrum. This test is meant to be a global confidence test. The cal signal is input to the A10 Input Assembly and processed through the entire signal path. This test is run automatically after the Power-On Test 0. If any errors are detected, their RETURN CODE is displayed on the CRT.

In Test 1, the following takes place:

1. Initialize I/O Ports on the A10 Front End Register, A50 Local Oscillator, A20 DMA, A50 Source, and A20 Trigger and Calibrate circuits.
2. Start the A20 Channel G in triggered mode.
3. Initiate and start the A20 FFT.
4. Compare the actual spectrum with the expected.

### **DEPENDENCY**

Test 1 is meant to be a global confidence test. As such, all boards are tested and must be functionally operational.

### **TEST 1 ERROR CODE DESCRIPTIONS**

The following is a list of all of the error RETURN CODES which could be displayed during the quick functional test. Included with the list of error RETURN CODES are their meaning.

RETURN CODE	DESCRIPTION
1 1 00	Front End Programming error occurs when the Front End Control Register circuit setup is read by the processor and is found to be incorrectly set.
1 1 01	Timing Counter Programming error indicates that the A20 Timing Counter setup is incorrect.
1 2 00	DMA Timeout error can occur if DMA does not request a data transfer when expected.
1 2 01	Trigger Timeout error indicates the trigger did not occur when expected.
1 2 02	FFT Timeout error indicates that the FFT circuitry did not request a data transfer when expected.
1 2 03	Autozero DMA Timeout error.
1 5 00	Front End/Digital Filter Overload occurs if the Front End Control Register or the Digital Filter circuits overload or if they did not overload when expected.
1 5 01	FFT Overload error indicates the A20 FFT circuitry overloaded or did not overload when expected.
1 6 00	Fundamental incorrect.
1 6 01	Even Harmonic incorrect.
1 6 02	Odd Harmonic incorrect.
1 6 03	DC bin error.
1 6 04	Noise Floor error.

## 6-25 Test 12 A30 FFT Test

### TEST DESCRIPTION

In Test 12, the processor uses the FFT circuitry on the A30 Assembly to perform an FFT on fixed data. The processor then compares the actual results with the expected results.

### DEPENDENCY

Test 12 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A50 Local Oscillator Noise Source Assembly
4. A20 Digital Filter Assembly

### TEST 12 ERROR CODE DESCRIPTIONS

RETURN CODE	DESCRIPTION
12 2 00	FFT Timeout error indicating that the A20 FFT circuitry did not request a data transfer when expected.
12 5 00	FFT Overload error indicates that the A20 FFT circuitry overloaded or did not overload when expected.
12 6 00	FFT Auto Scaling error.
12 6 02	Time Buffer Corrupted error.
12 6 05	FFT Output Bad error.
12 6 06	Both errors 02 and 05 occurred.
12 6 07	No FFT Output error.
12 6 08	Both errors 02 and 07 occurred.
12 6 98	Twiddle buffer error.
12 6 99	Window Buffer error.



## **6-26 Test 13 A20 Timing Counter Test**

### **TEST DESCRIPTION**

In this test, the processor uses the Timing Counter on the A20 Assembly to read a fixed clock which tests the operation of the Timing Counter, the processor interface to it and the fixed clock, all of which are on the A20 Digital Filter Assembly. The Timing Counter is tested with two signal frequencies; 2.048 MHz and 5.12 MHz. At each of those frequencies, the Timing Counter's outputs are read by the processor and the data is compared with the expected result. The tested circuits of the A20 Assembly are checked in the following order:

1. The Timing Counter is initialized and verified by the processor through the Timing Counter I/O.
2. The Timing Counter Clock is preset to 2.048 MHz and enabled.
3. The Timing Counter Clock is disabled after 100 mS and the processor reads the output states of the Timing Counter through the Timing Counter I/O.
4. The processor compares the actual data with the expected data and displays any errors on the CRT.

Steps 1 through 3 are repeated with step 2 setting the Timing Counter Clock to 5.12MHz. These two tests are repeated 6 times using a different Timing Counter Circuit setup each time, thereby checking all operating combinations of the Timing Counter IC.

### **DEPENDENCY**

This test depends on the proper operation of the following circuits:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**TEST 13 ERROR CODE DESCRIPTIONS**

The following is a list of all of the error RETURN CODES which could be displayed during the A20 Timing Counter Test. Included with the list of error RETURN CODES are their meaning.

RETURN CODE	DESCRIPTION
13 1 00 through 13 1 05	Timing Counter Programming error is displayed if the processor reads the Timing Counter after the setup and the result is incorrect. The third section number 00 through 05 indicates which of the six Timing Counter Setups failed.
13 6 00 and 13 6 01	Timing Counter error determined by reading the Timing Counter outputs and verifying that the actual data does not match the expected data.

**6-27 Test 14 A20 Digital Filter/DMA Channel R Test****TEST DESCRIPTION**

In Test 14, the processor writes data to the A20 Digital Filter Assembly. The Digital Filter then processes the data and transfers the result to RAM. The RAM address is established by the DMA Channel R counters. This test exercises the A20 Digital Filters, the DMA Channel R counters, the RAM BUS Arbitrator and the Channel Select circuits.

**DEPENDENCY**

This test depends on the proper operation of the following assemblies:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**TEST 14 ERROR CODE DESCRIPTIONS**

The following is a list of all of the error RETURN CODES which could be displayed during the Digital Filter/DMA test. Included with the list is a description of each of the codes.

<b>RETURN CODE</b>	<b>DESCRIPTION</b>
14 2 00 through 14 2 11	DMA Timeout occurs if the DMA Channel R does not request a DMA transfer when expected. This error can also occur if the Digital Filter IC's do not request a DMA transfer. There are twelve subtests where the DMA transfer request is monitored and a problem in any one can cause a unique RETURN CODE as indicated by the last two-digit number 00 to 11. The twelve subtests are listed following the Test 14 RETURN CODE descriptions.
14 2 20	FFT Timeout error indicates that the A20 FFT circuitry did not request a data transfer when expected.
14 5 00 through 14 5 11	Digital Filter Overload occurs if after the subtest routine, the Digital Filter IC indicates an overload when not expected or does not indicate an overload when expected. There are twelve subtests where an overload can occur as indicated by the last two-digit number (00 to 11) in the RETURN CODE. Those subtests are listed following the Test 14 RETURN CODE descriptions.
14 5 20	FFT Overload error indicates the A20 FFT circuitry overloaded or did not overload when expected.
14 6 00 through 14 6 11	Digital Filter Data Error occurs when the data transferred from the Digital Filter IC to memory is not as expected. There are twelve subtests where a data error can occur as indicated by the last two-digit number of the RETURN CODE. Those twelve subtests are listed next.

**TEST 14 SUBTESTS**

00 The instrument is programmed to the Local Oscillator and Digitizer test mode. The test then verifies this setup.

The following 11 subtests alternately check the Real and Imaginary Digital Filter IC's with the various Decimation Amounts as indicated.

Subtest	Real/Imaginary	Decimation Amount
01	R	0
02	I	0
03	R	/5
04	I	/5
05	R	/10
06	I	/10
07	R	/20
08	I	/20
09	R	/2/10
10	I	/2/10
11	R	/2/5 (Zoom mode)

**6-28 Test 18 A20 DMA Channel G and Trigger Test****TEST DESCRIPTION**

In this test, the processor checks the Trigger and DMA Channel G counters on the A20 Digital Filter Assembly by presetting the A20 Trigger circuits and verifying the setup. It then checks the Channel G DMA counters and their ability to DMA data by starting a transfer into memory. The data transferred is written to the processor input port of the Digital Filter ICs and then to memory. The data in memory is then checked for validity.

**DEPENDENCY**

This test depends on the proper operation of the following assemblies:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**TEST 18 ERROR CODE DESCRIPTIONS**

The following is a list of all the error RETURN CODEs which could be displayed during Test 18. Included with the list of error codes are their meaning.

<b>RETURN CODE</b>	<b>DESCRIPTION</b>
18 1 01 through 18 1 06	Timing Counter programming error is displayed if the processor reads the Timing Counter after the setup and the setup is incorrect. The third section number 01 through 06 indicates which of the Timing Counter setups failed.
18 3 01	Unexpected Trigger occurred when the Timing Counter was forced clear.
18 3 02	Unexpected Trigger occurred when the Timing Counter was armed.
18 3 03	Unexpected Trigger occurred when the Timing Counter was forced clear.
18 3 04	Unexpected Trigger occurred when the Timing Counter was forced clear.
18 3 05	Missing Trigger when triggered.
18 3 06	Missing Trigger when forced set.
18 3 07	DMA Channel G not done.
18 5 01	Digital Filter Overload error.
18 6 01	RAM changed during DMA off test.
18 6 02	Digital Filter data bad.
18 8 00 through 18 8 15	DMA Channel G address incorrect when testing block numbers 0 through 15.
18 9 01	DMA Address changed when DMA was off.
18 9 02	DMA Address was incorrect when DMA was enabled.
18 9 03	DMA Address was incorrect when DMA was finished.
18 9 04	DMA Address changed after DMA was completed.

## **6-29 Test 19 A65/A66 CMOS Memory Test**

### **TEST DESCRIPTION**

In this test, the processor checks the operation of the CMOS IC on the A65/A66 Assemblies. The first step in the test is to read all data which is stored in CMOS and place it in main RAM. This is done so the data in CMOS is not destroyed. After the test, the data is written back into CMOS. During the test, the processor writes data into the CMOS memory and then reads it out again. The processor then compares the data and displays any error codes on the CRT display. This test checks the CMOS memory, the processor interface and the CMOS paging circuit.

### **DEPENDENCY**

This test depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A20 FFT/RAM Assembly
4. A50 Local Oscillator/Noise Source Assembly

### **TEST 19 ERROR CODE DESCRIPTIONS**

There is only one error RETURN CODE in the CMOS Test 19. This error code indicates the actual data does not match the expected data. The problem could exist in the CMOS memory IC, the processor interface or the CMOS paging circuit.

The RETURN CODE is 19 6 00.

## **6-30 Test 20 A65 Bubble Memory Test**

### **TEST DESCRIPTION**

In this test, the processor writes data to the A65 Bubble memory module and then reads it back again. The processor then compares the actual data with the expected data. If a mismatch is detected, an error condition exists and an ERROR CODE is displayed on the CRT. This test checks all of the Bubble Memory control circuits, the processor interface and the Bubble Memory module.

**DEPENDENCY**

This test depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A20 Digital Filter Assembly
4. A50 Local Oscillator/Source Assembly

**TEST 20 ERROR CODE DESCRIPTIONS**

The following is a list of all the error RETURN CODES which could be displayed during the A65 Bubble Memory Test. Included with the list of error RETURN CODES are their meaning.

<b>RETURN CODE</b>	<b>DESCRIPTION</b>
20 1 00	No bubble is present or bad communication between the A40 Processor and A65 Bubble Controller.
20 2 00	The Bubble circuitry failed during a read operation.
20 2 01	The Bubble circuitry failed during a write operation.
20 2 02	RETURN CODEs 20 2 00 and 20 6 03 both occurred.
20 2 03	RETURN CODEs 20 2 01 and 20 6 03 both occurred.
20 6 00	The FIFO in the A65 Bubble Controller is not functioning properly.
20 6 01	The A65 Bootloop Register in the Sense Amplifier is not communicating with the Bubble Controller.
20 6 02	The Bubble cannot be initialized.
20 6 03	Data read from the Bubble memory at initialization does not match the fixed pattern. The first time this test is performed, this failure will occur since the stored pattern will not yet be in place. However, Test 20 checks and writes the fixed pattern twice, and if it fails the second time also, the next RETURN CODE 20 6 04 will be displayed.
20 6 04	Data read from the Bubble memory does not match the fixed pattern. See also RETURN CODE 20 6 03.
20 6 05	RETURN CODEs 20 2 00 and 20 2 01 both occurred.

## **6-31 Test 50 Display Pattern Test**

### **TEST DESCRIPTION**

In this test, the processor writes to the A60 Digital Display Assembly causing a defined pattern to be displayed on the CRT. This pattern is used in the adjustments to align the CRT display. There are no error codes in this test.

### **DEPENDENCY**

This test depends on the proper operation of the following circuits:

1. A40 Processor Assembly
2. A60 Digital Display Assembly
3. A70,A71,A72,A99 Power Supply Assemblies
4. A90 Analog Display Assembly

### **TEST 50 ERROR CODE DESCRIPTIONS**

There are no error RETURN CODEs in Test 50.

## **6-32 Test 52 A10 Calibrator Adjustment**

### **TEST DESCRIPTION**

In this test, the processor compares the internally generated Calibration signal with an external reference signal. Test 52 programs the -hp-3561A to make a measurement on an external reference with a frequency of 1 kHz and an amplitude of 200 mVrms, and then measure the internal calibrator signal. The difference between the two signals is then calculated and displayed on the CRT display. The adjustment is made to yield a difference of zero. The measurement and display routines are continuous. This allows the real-time adjustment of the internal Calibration signal.

### **DEPENDENCY**

This test depends on the proper operation of all the assemblies with the exception of the A50 Local Oscillator/Noise Source and A65/66 CMOS Bubble Memory Assemblies.



**TEST 52 ERROR CODE DESCRIPTIONS**

The following is a list of all the error RETURN CODES which could be displayed during Test 52. Also included is description of the error.

<b>RETURN CODE</b>	<b>DESCRIPTION</b>
52 1 00	Front End Programming error occurs when the Front End Control Register circuit setup is read by the processor and is found to be incorrect.
52 1 01	Timing Counter programming error is displayed if the processor reads the A20 Timing Counter after the setup and the setup is incorrect.
52 2 00	DMA/Trigger Timeout error which can occur if DMA does not request a transfer when expected.
52 2 01	Trigger Timeout error indicates the trigger did not occur when expected.
52 2 02	FFT Timeout error indicates that the A20 FFT circuitry did not request a data transfer when expected.
52 2 03	Autozero DMA Timeout error. 52 5 00 Front End/Digital Filter Overload occurs if the Front End Control Register or the Digital Filter circuits overloaded or they did not overload when expected.
52 5 01	FFT Overload error indicates the A20 FFT circuitry overloaded or did not overload when expected.
52 6 00	Input Signal Out-Of-Range.

**6-33 Test 53 A10 20dB Flatness Adjustment****TEST DESCRIPTION**

In this test, the processor programs the -hp-3561A to make a measurement on the internal Calibration Signal which is programmed to go through the 20dB attenuator on the A10 Assembly. This signal passes through the 20dB attenuator on the A10 Assembly. The measurement is made twice, once at each of two frequencies. Those frequencies are 1 kHz and 64 kHz. The processor then compares the magnitude of the two measurements. The difference in the magnitudes is then displayed on the CRT. This test is run continuously and the CRT is updated approximately every 100 ms.

**DEPENDENCY**

This test depends on the proper operation of all the assemblies with the exception of the A50 Local Oscillator/Noise Source and A65/66 CMOS Bubble Memory Assemblies.

**TEST 53 ERROR CODE DESCRIPTIONS**

The following is a list of all the error RETURN CODES which could be displayed during Test 53. Also included is the description of the error.

<b>RETURN CODE</b>	<b>DESCRIPTION</b>
53 1 00	Front End Programming error which occurs when the front end control circuit setup is read by the processor and is found to be incorrect.
53 1 01	Timing Counter programming error is displayed if the processor reads the A20 Timing Counter after the setup and the setup is incorrect.
53 2 00	Dma/Trigger Timeout error which can occur if DMA does not request a transfer when expected.
53 2 01	Trigger Timeout error indicates the trigger did not occur when expected.
53 2 02	FFT Timeout error indicates that the A20 FFT circuitry did not request a data transfer when expected.
53 2 03	Autozero DMA Timeout error.
53 5 00	Front End/Digital Filter Overload occurs if the Front End Control Register or the Digital Filter circuits overloaded or they did not overload when expected.
53 5 01	FFT Overload error indicates the A20 FFT circuitry overloaded or did not overload when expected.

**6-34 Test 54 A10 40dB Flatness Adjustment****TEST DESCRIPTION**

In this test, the processor programs the -hp-3561A to make a measurement on the internal Calibrator Signal which is programmed to go through the 40dB attenuator on the A10 Assembly. The calibrate signal passes through the 40dB attenuator on the A10 Assembly. The measurement is made twice, once at each of two frequencies. Those frequencies are 1 kHz and 64 kHz. The processor then compares the magnitude of the two measurements. The difference in the magnitudes is then displayed on the CRT. This test is run continuously and the CRT is updated approximately every 100 mS.

**DEPENDENCY**

This test depends on the proper operation of all the assemblies with the exception of the A50 Local Oscillator/Noise Source and A65/66 CMOS Bubble Memory Assemblies.

**TEST 54 ERROR CODE DESCRIPTIONS**

The following is a list of all the error RETURN CODES which could be displayed during Test 54. Also included is the description of the error.

RETURN CODE	DESCRIPTION
54 1 00	Front End Programming error which occurs when the front end control circuit setup is read by the processor and is found to be incorrect.
54 1 01	Timing Counter programming error is displayed if the processor reads the A20 Timing Counter after the setup and the setup is incorrect.
54 2 00	Dma/Trigger Timeout error which can occur if DMA does not request a transfer when expected.
54 2 01	Trigger Timeout error indicates that the trigger did not occur when expected.
54 2 02	FFT Timeout error indicates that the A20 FFT circuitry did not request a data transfer when expected.

RETURN CODE	DESCRIPTION
54 2 03	Autozero DMA Timeout error.
54 5 00	Front End/Digital Filter Overload occurs if the Front End Control Register or the Digital Filter circuits overloaded or if they did not overload when expected.
54 5 01	FFT Overload error indicates that the A20 FFT circuitry overloaded or did not overload when expected.

### 6-35 Test 110 A10 Front End Control Register Test

#### TEST DESCRIPTION

Test 110 is used for troubleshooting the Front End Control Register on the A10 Input Assembly and the Test Control Register circuitry on the A15 Assembly. The processor sends a clock which is latched by the Front End Register. This is repeated for as long as Test 110 is allowed to run. This process generates defined states on the outputs of the Registers which enable Digital Signature Analysis or oscilloscope waveform analysis to be performed.



*This test routine should not be used for periods longer than 30 minutes or the A10 relays may be damaged.*

There are no error RETURN CODEs in Test 110.

#### DEPENDENCY

This test depends on the proper operation of all the assemblies with the exception of the A50 Local Oscillator/Noise Source and A65/66 CMOS Bubble Memory Assemblies.

**6-36 Test 111 Through 116 A15 Timing And Control Circuit Setups****TEST DESCRIPTION**

These tests are used to setup the A15 Timing And Control circuitry for troubleshooting. There are six setups which completely test the A15 Timing and Control circuitry.

**NOTE**

*These setup tests cannot be changed by the operating system. It is important to exit these test modes by pressing the softkey EXIT TEST or by pressing the front panel PRESET key when you are finished with troubleshooting.*

There are no error RETURN CODEs in Tests 111 through 116.

**DEPENDENCY**

These tests depend on the proper operation of all the assemblies with the exception of the A50 Local Oscillator/Noise Source and A65/66 CMOS Bubble Memory Assemblies.

**6-37 Test 118 Display Calibration Constants****TEST DESCRIPTION**

Test routine 118 causes the Calibrate Correction Constants to be displayed on the CRT. This test disrupts normal instrument operation if PRESET or EXIT TEST mode keys are not pressed to exit Test 118. After initiating the test routine, press the MODE key to display the normal measurement screen. Use the MARKER to display the desired Calibrate Correction. In the Frequency display, the MARKER value X indicates the frequency and Y indicates the Calibrate Correction. In the Phase display, the MARKER value X indicates degrees and Y indicates the Calibration Correction.

There are no error RETURN CODEs in Test 118.

**6-38 Test 119 Clear Calibration Constant****TEST DESCRIPTION**

Test routine 119 resets the Calibrate Constant to zero. This test disrupts normal instrument operation if PRESET or EXIT TEST mode keys are not pressed to exit Test 119.

There are no error RETURN CODEs in Test 119. \*SEC\* 6-39 Test 120 A20 Digital Filter DSA

**6-39 Test 120 A20 Digital Filter DSA****TEST DESCRIPTION**

Test 120 is used to troubleshoot the A20 Digital Filter circuits. The processor continually writes to the Digital Filter allowing Digital Signature Analysis.

There are no error RETURN CODEs in Test 120.

**DEPENDENCY**

Test 120 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A50 Local Oscillator/Noise Source Assembly
4. A65/66 CMOS Bubble Memory Assemblies

**6-40 Test 121 A20 Timing Counter DSA****TEST DESCRIPTION**

Test 121 is used to troubleshoot the Timing Counter and associated circuitry on the A20 Digital Filter Assembly using Digital Signature Analysis.  
There are no error RETURN CODEs in Test 121.

**DEPENDENCY**

Test 121 depends on the proper operation of the following assemblies:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**6-41 Test 122 A20 DMA Channel G DSA****TEST DESCRIPTION**

Test 122 is used to set up the A20 Digital Filter Assembly for troubleshooting the DMA Channel G circuitry using an oscilloscope to check the output timing waveforms.

There are no error RETURN CODEs in Test 122.

**DEPENDENCY**

Test 122 depends on the proper operation if the following assemblies:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**6-42 Test 123 A20 DMA Channel R DSA****TEST DESCRIPTION**

Test 123 is used to set up the A20 Digital Filter Assembly for troubleshooting the DMA Channel R circuitry using an oscilloscope to check the output timing waveforms.

There are no error RETURN CODEs in Test 123.

**DEPENDENCY**

Test 123 depends on the proper operation of the following assemblies:

1. A20 Digital Filter Assembly
2. A30 FFT/RAM Assembly

**6-43 Test 150 A50 Local Oscillator DSA****TEST DESCRIPTION**

This test sets up the A50 PRN circuitry for troubleshooting using Digital Signature Analysis.

There are no error RETURN CODEs in Test 150.

**DEPENDENCY**

Test 150 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A65/66 CMOS Bubble Memory Assembly

**6-44 Test 151 A50 Analog Source Test****TEST DESCRIPTION**

Test 151 programs the -hp-3561A to output an 8Vp-p 250Hz sinewave signal out the rear panel SOURCE BNC connector. This test is used to verify proper operation of the built-in source signal. It checks both the digital and the analog circuitry.

There are no error RETURN CODEs in Test 151.

**DEPENDENCY**

Test 151 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A65/66 CMOS Bubble Memory Assembly

**6-45 Test 152 A50 Noise Source DSA Setup 1****TEST DESCRIPTION**

Test 152 is used to troubleshoot the Noise Source circuitry on the A50 Assembly using Digital Signature Analysis and oscilloscope waveform analysis.

There are no error RETURN CODEs in Test 152.



**DEPENDENCY**

Test 152 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A65/66 CMOS Bubble Memory Assembly

**6-46 Test 153 A50 Noise Source DSA Setup 2****TEST DESCRIPTION**

Test 153 is used to troubleshoot the PRN ROM using Digital Signature Analysis and oscilloscope waveform analysis.

There are no error RETURN CODEs in Test 153.

**DEPENDENCY**

Test 153 depends on the proper operation of all the assemblies with the the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A65/66 CMOS Bubble Memory Assembly


**6-47 Test 154 A50 HP-IB I/O Verification Test Routine****TEST DESCRIPTION**

In this test, the HP-IB I/O circuitry is checked for proper operation. Test 154 is a user interactive test. While the test is running, the HP-IB connector pins must be shorted to ground, one pin at a time. When this is done, the CRT will so indicate. The HP-IB connector is located on the rear panel of of the -hp-3561A. See Figure 6-33 for the pinout configuration.

There are no error RETURN CODEs in Test 154.

Note: Test 154 can only be accessed through the front panel.

Figure 6-33 HP-IB Connector Pinout Configuration




**CAUTION**

The -hp-3561 contains metric threaded HP-IB cable mounting studs as opposed to English threads. Metric threaded -hp-10833A, B, C or D HP-IB cable lock screws must be used to secure the cable to the instrument. Identification of the two types of mounting studs and lock screws is made by their color. English threaded fasteners are colored silver and metric threaded fasteners are colored black. DO NOT Mate silver and black fasteners to each other or the threads of either or both will be destroyed. Metric threaded HP-IB cable hardware illustrations and part numbers follow.

Pin	Line
1	D101
2	D102
3	D103
4	D104
13	D105
14	D106
15	D107
16	D108
5	EOI
17	REN
6	DAV
7	NRFD
8	NDAC
9	IFC
10	SRQ
11	ATN
12	SHIELD - CHASSIS GROUND
18	P/O TWISTED PAIR WITH PIN 6
19	P/O TWISTED PAIR WITH PIN 7
20	P/O TWISTED PAIR WITH PIN 8
21	P/O TWISTED PAIR WITH PIN 9
22	P/O TWISTED PAIR WITH PIN 10
23	P/O TWISTED PAIR WITH PIN 11
24	ISOLATED DIGITAL GROUND

**NOTE**  
The HP-IB is Hewlett-Packard implementation of IEEE std 488-1978, "Standard Digital Interface for Programmable Instrumentation."

THESE PINS  
ARE INTERNALLY  
GROUNDED



**HP-IB Interconnect Cables**

Part Number	Length
10833A	1 m (3.3 ft)
10833B	2 m (6.6 ft)
10833C	4 m (13.2 ft)
10833D	0.5 m (1.6 ft)

**TEST OPERATING PROCEDURE**

Use the following procedure to initiate and operate the HP-IB I/O Verification Routine:

1. Program the -hp-3561A to run Test 154 by pressing the following front panel keys:

```

PRESET
MODE ..... TEST SELECT .....154 ENTER
START CONT ..... TeST

```

The CRT should indicate that Test 154 is in progress and to press the STOP TEST key to ABORT the test. The STOP TEST key must be pressed to exit this test! Failure to do this will result in -hp-3561A operating errors! The CRT should also display the HP-IB I/O connector signal names, pin numbers and pin-state in six columns as shown next:

DIO1	1	O	O	13	DIO5
DIO2	2	O	O	14	DIO6
DIO3	3	O	O	15	DIO7
DIO4	4	O	O	16	DIO8
EOI	5	O	O	17	REN
DAV	6	O	O	18	GND
NRFD	7	O	O	19	GND
NDAC	8	O	O	20	GND
IFC	9	O	O	21	GND
SRQ	10	O	O	22	GND
ATN	11	O	O	23	GND
SHLD	12	O	O	24	IGND

where columns one and six identify the signal names, columns two and five identify the connector pin numbers and columns three and four identify the state of the pins (O indicates a high state).

2. Short the I/O pins to chassis (ground) one at a time. The shorted pin will cause the CRT to display a # instead of an O next to the corresponding pin number.

For example: Short pin number 1 of the HP-IB connector to ground. This will cause the CRT to display

```

DIO1    1    #    instead of    DIO1    1    O

```

No other pins should be affected. If any other pins are affected, troubleshoot the HP-IB circuitry.

Only pin 11, ATN, will cause changes to other pins. When pin 11 is grounded, the CRT will display the following:

DIO1	1	?	?	13	DIO5
DIO2	2	?	?	14	DIO6
DIO3	3	?	?	15	DIO7
DIO4	4	?	?	16	DIO8
EOI	5	?	?	17	REN
DAV	6	?	O	18	GND
NRFD	7	?	O	19	GND
NDAC	8	?	O	20	GND
IFC	9	?	O	21	GND
SRQ	10	?	O	22	GND
ATN	11	#	O	23	GND
SHLD	12	O	O	24	IGND

Note that the SHLD and GND pins will never change. Their state will always display a O.

Remember, press the STOP TEST key before changing test modes or exiting Test 154.

#### DEPENDENCY

Test 154 depends on the proper operation of the following circuits:

1. A30 FFT/RAM Assembly

#### 6-48 Test 167 A65 Bubble Memory Read DSA

#### TEST DESCRIPTION

Test 167 is used to troubleshoot the A65 Bubble Memory Assembly using Digital Signature Analysis. In this test, the processor continually reads a fixed pattern from record 128 of the Bubble Memory module. Note that this test does not destroy any data stored in the Bubble Memory module.

#### DEPENDENCY

Test 167 depends on the proper operation of all the assemblies with the exception of the following:

1. A10 Input Assembly
2. A15 Digitizer Assembly
3. A20 Digital Filter Assembly
4. A50 Local Oscillator/Noise Source Assembly

**TEST 167 ERROR CODE DESCRIPTIONS**

There is only one error RETURN CODE in Test 167. It is 167 1 00. This error indicates that the A65 Assembly is not installed or that the communication between the A65 Assembly and the A40 Processor is not functioning properly.

**6-49 Test 168 A65 Bubble Memory Bootloop Routine****TEST DESCRIPTION**

Test Routine 168 is used to rewrite the Bootloop into the Bubble Memory module. The purpose of the Bootloop is to provide a map that shows which storage loops are good and which are defective. This map is stored internally to the Bubble Memory module. It is also copied on a label on the outside of the Bubble Memory module (A65 U4) which is used by this routine. The Bootloop also contains a synchronization code which is used in positioning the data storage loops to provide a physical address reference.

The Bootloop will normally never need to be rewritten during the useful life of the Bubble Memory module. However, when the Bootloop is rewritten, all data stored in the Bubble Memory module is lost.

Note: This test routine can only be accessed through HP-IB!

**BOOTLOOP ROUTINE OPERATING PROCEDURE**

The Bootloop Routine requires an -hp-9836 HP-IB controller. The program listed in the following pages must first be loaded into the controller. To run the program, answer the prompts which will be displayed on the controller CRT. The prompts are explained following the error code descriptions.

**TEST 168 ERROR CODE DESCRIPTIONS**

There is only one error RETURN CODE in Test 168. It is 168 1 00. This error indicates that the A65 Bubble Memory Assembly is not installed or that the communication between the A40 Processor and the A65 Bubble Memory Assemblies is not functioning properly.

**BOOTLOOP PROGRAM PROMPT EXPLANATIONS**

*Turn power off before removing or installing the A65 Assembly.*

There are two methods to load the Bootloop program into the controller. The first method is to type the program listed in the following pages into the controller and pressing RUN. The second method is to load the program from the 5¼ inch floppy disk P/N 03561-69400 and pressing RUN. If the 5¼ inch floppy disk is available, use the following procedure to load and run the Bootloop program:

1. Insert the floppy disk P/N 03561-69400 into the right drive of the -hp-98364 Controller.
2. Type "LOAD BOOTLOOP" and press the RUN key.

All operating instructions are displayed on the controller CRT and explained in the following paragraphs.

After loading the basic program into the controller, type RUN to begin. The first screen will say to remove the A65 Bubble Memory assembly and copy the bootloop. The bootloop is located on the Bubble Memory module label. The following is an example:

7110-1	Part number
PYI03            8251	Date code
FFDBDFFBFBFF9F	
BBFFFBFF77FFBFF	
FFFFFF9FFDFFEFF	Bootloop (hexadecimal characters)
FFFBFDD7DEFFFD	
FDF5FFCF8C9D9BF9	

Carefully copy the bootloop onto a piece of paper. It will be entered into the controller later. It is important to copy the bootloop accurately since entering the incorrect bootloop will harm the Bubble Memory module necessitating its replacement.

After replacing the A65 Assembly and powering the instrument, set the HP-IB address to 11. Do this by pressing:

LCL ..... DEFINE ADDRESS .....11 ENTER

After the address has been programmed and the -hp-3561A and controller have been cabled together, press the CONTINUE key on the controller.

The current bootloop in the Bubble Memory module will be read and displayed on the controller's CRT. Also displayed will be selections to:

1. Edit the bootloop displayed on the controller's CRT
2. Rewrite the displayed bootloop to the Bubble Memory module
3. Exit the bootloop routine and return the -hp-3561A to local control

EDIT mode allows the displayed bootloop to be modified using the cursor arrows, backspace key or space bar. Move the cursor over the incorrect bootloop element and type the correct hexadecimal character. To exit the edit mode, press the ENTER key on the controller and the three selection functions will again be displayed on the CRT.

REWRITE mode causes the CRT displayed bootloop to be written to the -hp-3561A Bubble Memory module. When this is performed, the display will ask if the bootloop is correct. If N, you will be allowed to re-edit. If Y, the bootloop will be written. After writing, the controller reads the new bootloop and compares it to the bootloop just written. If they match, the program is completed. If there is a mismatch, the controller will display the message:

AN ERROR WAS DETECTED IN SENDING THE BOOTLOOP, TRY AGAIN

and display the three selection functions on the CRT. Type 2 to rewrite the bootloop. If the above message is again displayed, perform Test Routine 169 "A65 Bubble Memory Reseed Routine." After which, again try to write the bootloop. If the failure is still present, troubleshoot the HP-IB or Bubble Memory assemblies.

EXIT mode aborts the program in an orderly fashion and returns the -hp-3561A to local control.

```

10      ! THIS PROGRAM IS A SERVICE ROUTINE USED WHEN SERVICING
20      ! THE ATLAS BUBBLE MEMORY BOOTLOOP.  WHEN RUN, THE PROGRAM WILL
30      ! DISPLAY THE CURRENT BOOTLOOP STORED IN THE BUBBLE MEMORY.  IF IT
40      ! APPEARS TO BE CORRECT, THE USER MAY THEN EXIT THE TEST.  IF THERE
50      ! IS AN ERROR IN THE BOOTLOOP THE USER MAY CALL UP A SCREEN EDITOR,
60      ! EDIT THE BOOTLOOP AND THEN WRITE THE NEW BOOTLOOP TO THE BUBBLE
70      ! MEMORY.  IF THERE IS A MISMATCH OF THE BOOTLOOP SENT AND THE
80      ! BOOTLOOP READ, THE USER IS NOTIFIED TO TRY AGAIN.
90      !
100     DIM Bootloop_ready$(1),Current_chr$(1)
110     DIM Key$(160)
120     INTEGER B1_col,B1_row
130     COM New_bootloop$(5)(16),Old_bootloop$(5)(16),INTEGER Bootloop(40)
140     CALL Scr_clr
150     PRINT "BUBBLE BOOTLOOP SERVICE PROGRAM"
160     PRINT ""
170     PRINT "THE BUBBLE BOOTLOOP IS PRINTED ON THE LABEL OVER THE BUBBLE CHIP."
180     PRINT "TURN OFF THE POWER AND PULL THE A65 BUBBLE MEMORY ASSEMBLY AND "
190     PRINT "COPY THE BOOTLOOP CAREFULLY."
200     PRINT ""
210     PRINT "EXTREME CARE IS NEEDED WHEN COPYING THE BOOTLOOP, SINCE WRITING"
220     PRINT "TO A BAD LOOP WILL HARM THE BUBBLE MEMORY."
230     PRINT ""
240     PRINT "WHEN FINISHED COPYING THE BOOTLOOP, REPLACE THE A65 BUBBLE MEMORY"
250     PRINT "ASSEMBLY. POWER UP THE INSTRUMENT, SET THE 3561A HP-IB ADDRESS TO"-
260     PRINT "11 AND PRESS THE CONTINUE KEY."
270     PAUSE
280     !
290     ! START TEST AND GET THE CURRENT BUBBLE BOOTLOOP
300     !
310     CALL Scr_clr
320     CALL Start_bub_tst
330     CALL Get_old_b1
340     FOR I=1 TO 5
350         PRINT Old_bootloop$(I)
360     NEXT I
370     PRINT ""
380     PRINT " CURRENT BUBBLE BOOTLOOP"
390     !
400     ! DISPLAY MENU
410     !
420     Menu_up: !
430     INPUT "ENTER(1.EDIT BOOTLOOP, 2.REWRITE BOOTLOOP, 3.EXIT):",Opt_num
440     IF Opt_num=1 THEN GOSUB Edit_bootloop
450     IF Opt_num=2 THEN GOSUB Rewrite_b1
460     IF Opt_num=3 THEN GOTO Test_done
470     GOTO Menu_up
480     !
490     ! REWRITE BOOTLOOP WILL SEND OUT THE NEW BUBBLE BOOTLOOP THEN READ
500     ! IT BACK AND VERIFY IT WAS PROPERLY SENT AND RECEIVED
510     !
520     Rewrite_b1: !
530     INPUT "ARE YOU SURE THE BOOTLOOP IS CORRECT? (Y OR N)",Bootloop_ready$
540     IF Bootloop_ready$<>"Y" THEN GOTO Menu_up
550     CALL Read_crt
560     CALL Setup_new_b1
570     OUTPUT 711;"CTTS"
580     CALL Send_bootloop
590     OUTPUT 711;"SPTS;"
600     A=SPOLL(711)

```



```

610 IF BIT(A,4)=0 THEN GOTO 600
620 OUTPUT 711:"SSTS:"
630 CALL Get_old_b1
640 Cmp=FNCompare(New_bootloop$(*),Old_bootloop$(*))
650 IF Cmp=1 THEN GOTO Test_done2
660 CONTROL 1,1:6
670 CONTROL 1,0:1
680 PRINT "
690 PRINT "AN ERROR WAS DETECTED IN SENDING THE BOOTLOOP. TRY AGAIN"
700 GOTO Menu_up
710 RETURN
720 !
730 ! EDIT BOOTLOOP IS A SIMPLE SCREEN EDITOR
740 !
750 Edit_bootloop: !
760 CONTROL 1,1:6
770 CONTROL 1,0:1
780 PRINT "
790 PRINT "BOOTLOOP EDITOR
800 PRINT ""
810 PRINT " THE ARROW KEYS, SPACE AND BACKSPACE CAN BE USED TO MOVE THE CURSOR
820 PRINT " WHEN A HEXADECIMAL DIGIT IS ENTERED ON THE KEYBOARD, IT WILL UPDAT
E"
830 PRINT " THE CURRENT CURSOR POSITION WITH THAT DIGIT AND ADVANCE THE CURSOR
840 PRINT ""
850 PRINT "HIT ENTER WHEN YOU ARE SATISFIED WITH THE BOOTLOOP"
860 B1_row=1
870 B1_col=1
880 CALL Intensify(B1_col,B1_row)
890 ON KBD GOSUB Process_keys
900 B1_entered=0
910 REPEAT
920 UNTIL B1_entered>0
930 OFF KBD
940 RETURN
950 !
960 ! PROCESS KEYS FROM THE KEYBOARD
970 !
980 Process_keys: Key$=KBD$
990 REPEAT
1000 DISP ""
1010 Key_code=NUM(Key$[1,1])
1020 SELECT Key_code
1030 CASE 65 TO 70,48 TO 57 ! A TO F,0 TO 9
1040 CALL Print_new_chr(B1_col,B1_row,Key$[1,1])
1050 B1_col=(B1_col MOD 16)+1
1060 IF B1_col=1 THEN B1_row=(B1_row MOD 5)+1
1070 Intensify(B1_col,B1_row)
1080 CASE 97 TO 102
1090 Key$[1,1]=CHR$(Key_code-32)
1100 CALL Print_new_chr(B1_col,B1_row,Key$[1,1])
1110 B1_col=(B1_col MOD 16)+1
1120 IF B1_col=1 THEN B1_row=(B1_row MOD 5)+1
1130 Intensify(B1_col,B1_row)
1140 CASE 32
1150 GOSUB Forward
1160 CASE 255
1170 Key$=Key$[2]

```

```

1180     Key_code=NUM(Key$(1,1))
1190     IF Key_code=66 THEN GOSUB Backup
1200     IF Key_code=60 THEN GOSUB Backup
1210     IF Key_code=62 THEN GOSUB Forward
1220     IF Key_code=94 THEN GOSUB Moveup
1230     IF Key_code=86 THEN GOSUB Movedown
1240     IF Key_code=69 THEN GOSUB Bl_enter
1250     CASE ELSE
1260         BEEP
1270         DISP "INPUT ERROR, LAST KEY IGNORED"
1280     END SELECT
1290     Key$=Key$(2)
1300     UNTIL LEN(Key$)=0
1310     RETURN
1320 Forward: !
1330     Detensify(B1_col,B1_row)
1340     B1_col=(B1_col MOD 16)+1
1350     IF B1_col=1 THEN B1_row=(B1_row MOD 5)+1
1360     Intensify(B1_col,B1_row)
1370     RETURN
1380 Backup: !
1390     Detensify(B1_col,B1_row)
1400     B1_col=((B1_col+14) MOD 16)+1
1410     IF B1_col=16 THEN B1_row=((B1_row+3) MOD 5)+1
1420     Intensify(B1_col,B1_row)
1430     RETURN
1440 Moveup: !
1450     Detensify(B1_col,B1_row)
1460     B1_row=((B1_row+3) MOD 5)+1
1470     Intensify(B1_col,B1_row)
1480     RETURN
1490 Movedown: !
1500     Detensify(B1_col,B1_row)
1510     B1_row=(B1_row MOD 5)+1
1520     Intensify(B1_col,B1_row)
1530     RETURN
1540 Bl_enter: !
1550     Bl_entered=1
1560     Detensify(B1_col,B1_row)
1570     CONTROL 1,1;6
1580     CONTROL 1,0;1
1590     RETURN
1600 Test_done2: !
1610     CALL Scr_clr
1620     PRINT "BOOTLOOP WAS SUCCESSFULLY WRITTEN"
1630     GOTO Test_finished
1640 Test_done: !
1650     CALL Scr_clr
1660 Test_finished: !
1670     OUTPUT 711;"SPTS;RST;"
1680     LOCAL 711
1690     SEND 7;UNL
1700     PRINT "BOOTLOOP SERVICE ROUTINE FINISHED"
1710     END
1720 SUB Intensify(INTEGER Col,Row)
1730 DIM Intensify_chr$(1)
1740 CONTROL 1,1;Row
1750 CONTROL 1,0;Col
1760 ENTER 1;Intensify_chr$
1770 PRINT CHR$(129)

```

```

1780 CONTROL 1,1;Row
1790 CONTROL 1,0;Col
1800 OUTPUT 1;Intensify_chr$
1810 PRINT CHR$(128)
1820 SUBEND
1830 SUB Detensify(INTEGER Col,Row)
1840 DIM Detensify_chr$[1]
1850 CONTROL 1,1;Row
1860 CONTROL 1,0;Col
1870 ENTER 1;Detensify_chr$
1880 CONTROL 1,1;Row
1890 CONTROL 1,0;Col
1900 OUTPUT 1;Detensify_chr$
1910 SUBEND
1920 SUB Print_new_chr(INTEGER Col,Row,New_chr$)
1930 CONTROL 1,1;Row
1940 CONTROL 1,0;Col
1950 OUTPUT 1;New_chr$
1960 SUBEND
1970 SUB Scr_clr
1980 OUTPUT 2;CHR$(255)&"K";
1990 WAIT .2
2000 SUBEND
2010 SUB Start_bub_tst
2020   OUTPUT 711;"TNUM 168;SSTS;"
2030 SUBEND
2040 SUB Get_old_bl
2050 COM New_bootloop$(5)[16],Old_bootloop$(5)[16],INTEGER Bootloop(40)
2060   FOR I=1 TO 40
2070     ENTER 711 USING "#,B";Bootloop(I)
2080   NEXT I
2090   FOR I=1 TO 5
2100     Old_bootloop$(I)=""
2110     FOR J=1 TO 8
2120       Old_bootloop$(I)=Old_bootloop$(I)&FNDechex$(Bootloop(J+(8*(I-1))))
2130     NEXT J
2140   NEXT I
2150 SUBEND
2160 DEF FNDechex$(INTEGER Dec_val)
2170 Hexstr$="0123456789ABCDEF"
2180 High=(Dec_val DIV 16)+1
2190 Low=(Dec_val MOD 16)+1
2200 RETURN Hexstr$(High,High)&Hexstr$(Low,Low)
2210 FNEND
2220 DEF FNHexdec(Hex_val$)
2230 Hexstr$="123456789ABCDEF"
2240 RETURN POS(Hexstr$,Hex_val$[1,1])*16+POS(Hexstr$,Hex_val$[2,2])
2250 FNEND
2260 SUB Read_crt
2270 COM New_bootloop$(5)[16],Old_bootloop$(5)[16],INTEGER Bootloop(40)
2280 CONTROL 1;1,1
2290 FOR I=1 TO 5
2300   ENTER 1 USING "16A";New_bootloop$(I)
2310 NEXT I
2320 SUBEND
2330 SUB Setup_new_bl
2340 COM New_bootloop$(5)[16],Old_bootloop$(5)[16],INTEGER Bootloop(40)
2350 FOR I=1 TO 5
2360   FOR J=1 TO 8
2370     Bootloop((I-1)*8+J)=FNHexdec(New_bootloop$(I)[(2*J-1),(2*J)])

```

```
2380     NEXT J
2390 NEXT I
2400 SUBEND
2410 SUB Send_bootloop
2420 COM New_bootloop$(5)[16],Old_bootloop$(5)[16],INTEGER Bootloop(40)
2430 FOR I=1 TO 40
2440     OUTPUT 711 USING "#,B";Bootloop(I)
2450 NEXT I
2460 SUBEND
2470 DEF FNCompare(S1$(*),S2$(*))
2480 FOR I=1 TO 5
2490     IF S1$(I)<>S2$(I) THEN RETURN 0
2500 NEXT I
2510 RETURN 1
2520 FNEND
```

### 6-50 Test 169 A65 Bubble Memory Reseed Routine

#### TEST DESCRIPTION


Test Routine 169 is used to Reseed the Bubble Memory module. This Routine requires a special electronic Reseed module which plugs into the IC socket of U102 on the A65 Bubble Memory Assembly. This Reseed module is -hp- part number 1818-3304 and is part of the -hp-3561A Service Accessory Kit -hp- part number 03561-84401.

A bubble is generated in the Bubble Memory module by replicating a seed bubble that is always present at the GEN element which is inside the module. If this seed is lost or destroyed, it will be necessary to run this routine.

#### RESEED ROUTINE OPERATING PROCEDURE

1. With the line power switch OFF, remove the A65 Bubble Memory Assembly.
2. Remove U102 and install the Reseed module 1818-3304 into U102's socket being careful to orient pin 1 properly as shown in Figure 6-34.

**Figure 6-34 Reseed Module Installed Properly.**



3. Install U102 into the Reseed module being careful to orient pin 1 properly.
4. Place a clip lead across 47 $\Omega$  resistor R104 effectively connecting U4(1,6) directly to +12V.
5. Install the A65 Assembly into the -hp-3561A using an extender board -hp- part number 03561-66596. An extender board must be used because the Reseed module and U102 IC combination will not have enough clearance to be installed in the instrument.
6. Turn the -hp-3561A power ON.
7. After the power-on routine, program the instrument to run Test 169 by pressing the following front panel keys:

MODE . . . . . TEST SELECT . . . . .169 ENTER NTER

8. Begin the routine by pressing the softkey START SiNGLe TEST.
9. The CRT will ask if the Reseed Module is in place and to press CONTINUE if it is. Press CONTINUE.

The Reseed routine will take less than one second.

10. When the Reseed routine is finished, turn the line power switch off and remove the clip lead and Reseed module, and reinsert U102 into the A65 Assembly.

Although it is not necessary, it is good practice to check the Bootloop of the Bubble Memory whenever it is necessary to Reseed. Do this by running Test 168. \*SEC\* 6-51 Test 170 Format Nonvolatile Memory Routine

### **6-51 Test 170 Format NonVolatile Memory Routine**

#### **TEST DESCRIPTION**

Test Routine 170 is used to format the optional A65 Assembly. The format routine will initialize the CMOS IC with the Bubble Memory information. This test routine will normally only be necessary to run if the A65 CMOS IC or the battery were replaced.

## TEST 170 OPERATING INSTRUCTIONS

Use the -hp-3561A Test Menu to initialize Test 170. Press the softkey START SINGLE TeST to execute. The instructions will be displayed on the CRT display.

## TEST 170 ERROR CODE DESCRIPTIONS

There are two error RETURN CODEs in Test 170. They are listed and explained below.


RETURN CODE	DESCRIPTION
170 2 00	Bubble Initialize Timeout error occurs if the A65 bubble controller does not respond to the processor.
170 6 00	Bubble Bootloop Data error occurs when the processor cannot read data from the bootloop register

## 6-52 Overall Instrument Theory of Operation

### 6-53 Introduction to Theory of Operation

An overview of the -hp-3561A operation is given here to illustrate some of the primary interactions between the individual circuit boards. The 3561A's control circuits and bus structure are described first, followed by a description of the measurement data flow. A detailed circuit description for each circuit board is given in Section Seven. A simplified instrument block diagram is given in Figure 6-34, the assembly locations are given in Figure 6-35, and a detailed block diagram is given in Figure 6-36.

Figure 6-34 -hp-3561A Simplified Block Diagram



## 6-54 Control Circuits and Bus structure

### INSTRUMENT CONTROL

The -hp-3561A is controlled by a 68000 microprocessor on the A40 Assembly. The microprocessor, ROM and other circuits on the A40 assembly are referred to here as the central processor. The central processor directs all activity required for the -hp-3561A to accept, process, and display measurement data. When power is initially applied to the -hp-3561A, the central processor runs a self test and then configures the -hp-3561A circuits to preset conditions. The central processor then moni-

tors the front panel for new instructions. When a front panel key is pressed, the central processor programs the -hp-3561A circuits to implement the keyed instruction.

The -hp-3561A uses the processor bus and the RAM bus for instrument control and data transfer. The processor bus and RAM bus both consists of a 16 bit address bus and a 16 bit data bus. The processor bus is controled by the central processor, and the RAM bus is controlled by the RAM bus arbitrator on the A30 Assembly. Because the -hp-3561A uses a two bus structure, two activities can take place at the same time (e.g., The processor can access the display over the processor bus at the same time as the digital filter is accessing RAM over the RAM bus).

## **PROCESSOR BUS**

The processor address bus and data bus are used by the central processor to send instructions to the various -hp-3561A circuits and to transfer data to display. The processor address bus is a 16 bit single direction bus which is partially decoded on the A40 Assembly to generate select lines. Select lines are used to address a particular functional block. The functional block then decodes the remaining address lines to determine the exact circuit addressed. The processor data bus is a 16 bit bi-directional bus. Over this bus, the processor writes data to, or reads data from the addressed circuit.

## **RAM BUS**

The RAM bus is used by three circuits to transfer data to and from the instrument RAM. The three circuits are the FFT processor, the central processor, and the digital filter. To prevent a bus contention, the RAM bus arbitrator uses a priority decoder to control access to both the RAM address bus and data bus. The FFT processor has top priority, the digital filter second, and the central processor third. To access the RAM bus, a circuit issues a RAM bus request. The RAM bus arbitrator compares the priority of the bus request to the priority of any other bus requests it has received and issues a bus grant to the highest priority requester. The circuit receiving the bus grant has access to the RAM bus until a higher priority bus request is received.

## **6-55 Measurement Data Flow**

### **FFT MEASUREMENTS**

The -hp-3561A uses the Fast Fourier Transform (FFT) to convert time domain data into frequency domain data. The FFT is a mathematical algorithm which is implemented in a microprocessor on the A30 Assembly called the FFT processor. The FFT processor is the heart of the -hp-3561A. Most other circuits in the -hp-3561A are provided to support the FFT processor by either preparing the input data to be transformed, or by transferring the FFT results to the CRT display.



The FFT processor operates on blocks of 1024 time domain data samples resulting in 512 frequency and 512 phase values.

### **INPUT AMPLIFIER (A10 ASSEMBLY)**

The first step in processing the input signal is to scale its amplitude to the correct value for the A/D converter. This scaling is accomplished in the input amplifier circuits on the A10 Assembly. The gain of the input amplifier is set by the front panel range setting. An input sine wave with an amplitude equal to the range setting will be scaled to an amplitude of .228 Vrms at the input to the A15 Assembly.

### **ANTI-ALIAS FILTER AND A/D CONVERTER (A15 ASSEMBLY)**

After it is scaled by the input amplifier, the input signal is passed through the 100 kHz low pass anti-alias filter. This filter prevents aliasing which occurs as part of the sampling process in the A/D converter.

At the output of the anti-alias filter, the input signal has been fully conditioned to be digitized. The analog-to-digital converter always samples the input signal at a 256 kHz rate (except in external sample mode). For each sample, the A/D converter outputs a 13 bit digital value to the digital filter.

### **DIGITAL FILTER (A20 ASSEMBLY)**

The digital filter is a low-pass filter with a pass-band frequency span equal to the selected display frequency span. The digital filter processes data serially, that is the digital filter inputs only one data sample at a time and produces one output value for each input value. The digital filter outputs are stored directly into RAM. The RAM address where the data is stored is determined by the direct memory access (DMA) circuit. Because the FFT processor operates on blocks of 1024 data samples, the DMA circuit stores the digital filter output values in blocks of 1024 outputs each. Each block of 1024 values is called a time record. The first data sample of a time record is determined by one of five possible triggers: input trigger, internal trigger, external trigger, source trigger, or HP-IB trigger. When a trigger is received, the DMA circuit stores the next 1024 digital filter output values into a time record. When the time record has been filled, the DMA circuit issues a DMA interrupt signal to the central processor to indicate that the time record is ready for processing by the FFT processor.

### **FFT PROCESSOR (A30 ASSEMBLY)**

On receipt of a DMA interrupt, the central processor performs a window function on the data if a window is selected, and then issues an FFT RESET signal to the FFT processor. The FFT RESET signal indicates to the FFT processor that a complete time record is stored in RAM and is ready for processing. The FFT processor then performs a fast fourier transform on the time record, resulting in 512 frequency and 512 phase values. The FFT results are then stored into the frequency buffer location of

the instrument RAM. When the FFT processor completes a transform, it issues an FFT interrupt signal to the central processor to indicate that the data is ready to be displayed.

## **POST PROCESSING AND DISPLAY**

When the central processor receives an FFT interrupt signal, it determines whether the data should be directly transferred to the display or whether some post processing is required such as a math function or third octave display. The processor performs any post processing required while the data is stored in the instrument RAM. When the post processing is complete, the processor transfers the data to the appropriate location in the display memory depending on the display type chosen.

## **MEASUREMENTS WHEN THE FREQUENCY SPAN IS LESS THAN 100 kHz**

To obtain maximum frequency resolution when the frequency span is less than 100 kHz, the input data is resampled after it has been digitally filtered. The new sample rate can be calculated by multiplying 256 kHz by 100 and then dividing by the selected frequency span. Thus if a frequency span of 20 kHz is selected, the new sample rate is 51.2 kHz. To obtain a sample rate of 51.2 kHz, four out of every five digital filter outputs are discarded, and only one out of five are stored in RAM.

## **ZOOM MODE OPERATION**

Because the digital filter and the FFT processor can only process signals in a frequency span centered at 0 Hz, the -hp-3561A is equipped with a digital local oscillator. The purpose of the local oscillator is to mix the signals in the selected frequency span down to an equivalent span centered at 0 Hz. The signals can then be digitally filtered, and transformed by the FFT processor. The local oscillator output signal is set to a frequency equal to the center frequency of the selected span (e.g., for a 20 kHz span centered at 50 kHz, the local oscillator will have a frequency of 50 kHz). This signal is then multiplied with the sampled input signal. The multiplication occurs inside the digital filter, but before the digital filtering takes place.

Figure 6-35 Assembly and Cable Locations (Top View of Instrument)







Figure 6-36 Detailed Block Diagram of the -hp-3561A











A65 CMOS/BUBBLE MEMORY  
03561-66565

A80/A81 KEYBOARD/KEYBOARD DRIVER  
03561-66580/03561-66581







## New or Revised Item

This Manual Change Sheet contains important information for correcting manual errors and for adapting the manual to instruments which contain modifications made after the printing of the manual.

Change and correction information in this supplement is itemized by page numbers corresponding to the original manual pages.

To use this supplement:

1. Make all manual ERRATA changes.
2. Make all additional changes that pertain to your instrument serial number.

## Errata

**Page 1-1a**, Figure 5-1 a. Change the figure number and title to Figure 1-1 -hp-3561A With Accessories Supplied.

**Page 2-23**, step 1, -hp-3561A, TRIGger SElect. Change range from 10% to 25%

**Page 2-25**, Figure 2-9. Change the figure number from 2-9 to 2-10.

**Page 2-26**, Figure 2-10. Change the figure number from 2-10 to 2-9.

**Page 2-35**, step 10. Change frequency from 94 kHz to 95 kHz.

**Page 2-42**, Figure 2-16. Change the illustration to show that the frequency synthesizer is connected to the -hp- 3561A rear panel EXT SAMPLE CONNECTOR rather than the -hp- 3561A front panel connector.

**Page 6-10**, top heading. Change AD/DC COUPLING to AC/DC COUPLING.

**Page 6-17/6-18**, Table 6-8. Change the tolerance of the +24V supply from  $\pm 0.12V$  to  $\pm 1.2V$ .

**Page 6-85**, first paragraph. Change the part number of the 5-1/4 inch floppy disc from 03561-69400 to 03561-19400 (two places).

**Page 7-19/7-20**, A10a schematic, Amplifier #3 E. Change the title of Block E from Amplifier #3 to Amplifier #1.

**Page 7-21/7-22**, A10b Schematic, Change inverter U403c to U404c. Change R17, 100 ohm to R517, 100 ohm (located in the 15V1 supply).

**Page 7-35/7-36**, A15a Schematic, 100KHz low Pass Filter A. Change the value of C2 to 750 pF.

**Page 7-35/7-36**, A15a Schematic, Second Pass ADC H. Change -15V14 to -15V15 going to U102(19).

**Page 7-35/7-36**, A15a Schematic, 8-BIT ADC O. Change pin U206(17) to U206(11) signal ADBO.

**Page 7-37/7-38**, A15b Schematic, +5V supply. Change L500 to L501.

**Page 7-63/7-64**, A20a Schematic, DMA Channel Control J. Change the input pin numbers of U109a,b as follows: U109a(14) to 13, U109a(3) to 14, U109b(2) to 3, U109b(3) to 2.

**Page 7-67/7-68**, A20c Schematic, Timing and Control Counter Y. Change the input source of U202(30) from V to U

**Page 7-69/7-70**, A20d Schematic, Clock Generator FF. Change R10 to R5 (U2(1)). Change R6 to R12 (U3(6)).

**Page 7-85**, Table 7-25. Change the failed ram test codes as follows:

Chip code	Failed RAM
4	U300
5	U301
6	U302
7	U303
8	U207
9	U208
A	U209
B	U210
C	U306

**Page 7-91/7-92**, A30a Schematic, RAM access State Machine E. Change TP202 to TP203. Change TP203 to TP202.

**Page 7-91/7-92**, A30a Schematic, RAM Read/Write Generator K. Change the source of U401c(10) from P32(B7) to P31(B7).

**Page 7-93/7-94**, A30b Schematic, FFT Processor O. Change the signal name at U100 (9) from FFTOSA to FFTDSA.

**Page 7-109**, Table 7-32. Change all of the Return Codes from x 1 xx to x 8 xx.

**Page 7-115/7-116**, A40a Schematic, Control/Address Buffer L. Change input pin of U501(3) PA2 to U501(13) PA2.

**Page 7-115/7-116**, A40a Schematic. Interchange J100 pins 4 and 5 with J100 pin 3. J100 pins 4 and 5 now go to the 68000 IC pin 48 and J100 pin 3 now goes to the 68000 IC pin 6.

**Page 7-149/7-150**, A50b Schematic, NOISE SOURCE SYNC GENERATOR EE. Connect U500a(12) to U304(14).

**Page 7-149/150**, A50b Schematic, D/A Converter AA. Change the value of C401 to 27pF.

**Page 7-199/7-200**, A65 Schematic, Bubble Coil Drivers J. Connect U100(2) and U1(2) to ground. Connect U100(13) and U1(13) and U1(13) to +12V

**Page 7-217/7-218**, A70a Schematic. Change the revision from REV A to REV B.

**Page 7-217/7-218**, A70a Schematic, PS Overvoltage Comparators G. Change U202a,b,c,d to U502a,b,c,d.

**Page 7-217/7-218**, A70a Schematic, Isolated PS Overvoltage Comparators H. Change U204a,b to U402a,b.

**Page 7-231/7-232**, A80 Schematic, Address I/O Decoding A. Change the output of U7(14) from LED SELECT2 to LED SELECT1. Change TP LEDS2 to LEDS1. Change the output of U7(13) from LED SELECT1 to LED SELECT2. Change TP LEDS1 to LEDS2.

**Page 7-249/7-250**, A90 Schematic, Video Drive A. Change Q202, Q203, Q205 from PNP to NPN.

**Page 7-249/7-250**, A90 Schematic, Fast Sweep Vertical Drive D. Change the pin numbers of U501d as follows: U501d(1) to (11), U501d(2) to (12), U501d(3) to (13).

**Page 7-249/7-250**, A90 Schematic, High Voltage F. Replace R307 270K with a short circuit. Install R307 270K between CR300/R201 and R300.

#### **Change 1 for all Serial Numbers.**

**Page 1-1a**, Figure 1-1. Change the part number for the cable to the NEMA 5-15P Plug from 8120-1521 to 5041-5820.

**Page 1-6**, Table 1-3. Change Reseed Module part number from 1818-33-5 to 0960-0708.

**Page 1-12**, Table 1-5, -hp-3561A Service Kit. Under Critical Specifications heading, change the reference from Table 1-2 to Table 1-3.

**Page 4-5**, A10 Parts List. Change the part number of A10C301 to 0160-6664.

**Page 4-5**, A10 Parts List. Change the part numbers of A10C501, A10C503, and A10C508 to 0160-6688.

**Page 4-5**, A10 Parts List. Change the part number of A10C510 to 0160-6689.

**Page 4-6**, A10 Parts List. Change A10R202 to 2100-3210 (10K). Change A100R204 to 0757-0451 (24.3K).

**Page 4-7**, A10 Parts List. Change A10R511 to 0698-3540 (15.4K).

**Page 4-7**, A10 Miscellaneous Parts List. Change screw 0515-0158 to 0515-0573.

**Page 4-7**, A10 Parts List. Change the part number of the CONNECTOR - RF SM-SLD in the A10 MISCELLANEOUS PARTS to 1250-1255.

**Page 4-7**, A10 Parts List. Change the part number of the CONNECTOR - RF SMB in the A10 MISCELLANEOUS PARTS to 1250-2142.

**Page 4-9**, A15 Parts List. Change the part number of A15J001 to 1250-1255.

**Page 4-10**, A15 Parts List. Change A15R226 to 0698-8959.

**Page 4-12**, A20 Parts List. Change the revision from REV B to REV C.

**Page 4-13**, A20 Parts List. Change A2OU501 to 1820-1191 (74S175N).

**Page 4-14**, A20 Miscellaneous Parts List. Change screw 0515-0064 to 2200-0149. Change nut 0590-1095 to 0590-0526.

**Page 4-15**, A30 Parts List. Delete A30R406.

**Page 4-16**, A30 Parts List. Delete A30R407 and A30R411.

**Page 4-16**, A30 Parts List. Change A30U100 to 1820-3974.

**Page 4-18**, A40 Parts List. Change the revision from REV B to REV C.

**Page 4-20**, A40 Parts List. Change the part number of A40U006 to 1820-3532.

**Page 4-20**, A40 Parts List. Delete part number 0340-0944 INSULATOR IC NYLON BLACK from A40 MISCELLANEOUS PARTS.

**Page 4-24**, A50 Parts List. Change A50U606 to 1820-3507.

**Page 4-26**, A60 Parts List. Change A60U806 to 1820-1216.

**Page 4-27**, A60 Parts List. Add 03561-0091 GROUNDING SPRING as a miscellaneous part.

**Page 4-28**, A65 Parts List. Change the part numbers of A65C001, A65C002, A65C008, A65C100, A65C200, and A65C204 to 0180-3812.

**Page 4-29**, A65 Parts List. Add 1400-1296; Qty.1; Screw Set, Bubble Memory

**Page 4-30**, A66 Parts List. Delete 4040-0753; Green Extractor from the list. Change the Qty of 4040-0754; Blue Extractor from 1 to 2.

**Page 4-33**, A70 Parts List. Add 4330-0952 CERAMIC BEAD, quantity 2.

**Page 4-33**, A70 Parts List. Add 4330-0496 GLASS BEAD, quantity 2.

**Page 4-34**, A71 Parts List. Change the part number of A71R101 to 8159-0005.

**Page 4-34**, A71 Parts List. Change the part numbers of A71C003 and A71C101 to 0160-6510.

**Page 4-34**, A71 Parts List. Change the part numbers of A71CR303 and A71CR305 to 1901-1244.

**Page 4-35**, A71 Parts List. Reverse Reference Designators A71U001 and A171U100. A71U001 now becomes 1826-0527. A71U100 now becomes 1826-0393.

**Page 4-35**, A71 Parts List. Add 4330-0496 GLASS BEAD, quantity 2.

**Page 4-39**, A82 Parts List. Change the part number of A82J006 to 1250-2142.

**Page 4-40**, A90 Parts List. Change the part number and description of A90R005 to 0757-0413 RESISTOR 392 1% .25W.

**Page 4-41**, A90 Parts List. Change the part number and description of A90R102 to 0757-0408 RESISTOR 243 1% .25W.

**Page 4-43**, A99 Parts List. Change the part number of the 220pF padding capacitor A99C5 to 0160-2544; change the 220pF value to 270pF.

**Page 4-43**, A99 Parts List. Change the part numbers of A99C202, A99C204, A99C206, A99C208, A99C300, A99C302, and A99C304 to 0160-6509.

**Page 4-44**, A99 Parts List. Change the part number of A99J300 to 1250-1255.

**Page 4-44**, A99 Parts List. Change the part number of A99R100 and A99R101 to 0699-1541.

**Page 4-44**, A99 Parts List. Change A99R101 to 0699-1541.

**Page 4-44**, A99 Parts List. Add 4330-0496 GLASS BEAD, quantity 2.

**Page 4-45**, Mechanical Parts List. Change MP008 to 03561-44702. Change MP009 to 03561-44701. Change MP010 to 03561-44703.

**Page 4-45**, Mechanical Parts Lists. Change MP014 to 03561-63701. Change MP019 to 03561-63703

**Page 4-45**, Replaceable Parts List. Change the part number of MP034 to 03561-43601.

**Page 4-45**, Replaceable Parts List. Change the part number of MP036 to 03561-43602.

**Page 4-45**, Replaceable Parts List. Change the part number of MP067 to T-53676.

**Page 4-45**, Mechanical Parts List. Change MP053 to 03561-60614. Change MP066 to 03561-01235.

**Page 4-46**, Replaceable Parts List. Change the part number of S2 to 3101-2306.

**Page 4-46**, Mechanical Parts List. Delete MP078.

**Page 4-47**, Hardware Parts List. Add the following parts:

0515-0074	Screw	Line Switch Mounting	2
0380-1362	12mm Standoff	Line Switch Mounting	2
2190-0004	Lock Washer	Line Switch Mounting	2
0515-0055	Screw	Line Switch Mounting	2

**Page 6-92**, TEST DESCRIPTION. Change the Reseed Module part number from 1818-3304 to 0960-0708.

**Page 6-92**, RESEED ROUTINE OPERATING PROCEDURE, Step 2. Change the part number of the Reseed Module from 1818-3304 to 0960-0708.

**Page 7-19/7-20**, A10a Schematic, Cal Signal Generator B. Change the value of R511 to 15.4K. Change the value of R410 to 32.4 ohm.

**Page 7-19/7-20**, A10a Schematic, A-Weight Filter K. Change the value of RR204 to 24.3K. Change the value of R202 to 10K

**Page 7-69/7-70**, A20d Schematic, Low Frequency Clock Generator GG. Remove the RESET line connecting U709(14) and U708b(13) connects the schematic 20A(H) RESET (NOT).

**Page 7-115/7-116**, A40a Schematic, Interrupt Vector Generator K. Remove the line connected to U3a(1) (I/O PORT #7). Connect U3a(1) to + 5V2. Change U3a(5) to U3a(6). Change U3a(6) to U3a(5). Change the revision of all four A40 Schematics from REV B to REV C.

**Page 7-121/7-122**, A40d Schematic, 20.48 Oscillator U. Change the value of R200 to 47. Change the value of R201 to 510. Change the value of R205 to 475. Change the value of R208 to 475. Change the value of C205 to 12pF.

**Page 7-121/7-122**, A40d Schematic, Clock Output Buffer V. Change the connection of L101 from U103a(13) to U103a(14).

**Page 7-219/7-220**, A70b Schematic, Rectifier Filter M. Change the values of C100 and C101 to 1300.

**Page 7-249/7-250**, A90 Schematic, SLOW SWEEP HORIZONTAL DRIVE B. Change the value of R102 to 243. Change the value of R5 to 392.

# **CHANGE 2 for Instruments With REV C A50 Assemblies**

**Page 4-24**, A50 Parts List. Add A50U309, 1820-3507, SN74S74N, 1820-3507.

**Page 7-149 through 7-152**, A50 Schematics. Change the revision from B to C.

**Page 7-149/7-150**, A50B Schematic, CLOCK N. Add U309 circuits in Figure 1 to the A50B Schematic.

# **CHANGE 3 for Serial Numbers 2338A01970 and greater.**

**Page 4-20**, A40 Parts List. Change the part numbers for the following components:

Reference Designator	Part Number
U106	03561-60357
U200	03561-60358
U201	03561-60359
U202	03561-60360
U203	03561-60361
U303	03561-60350
U502	03561-60351
U600	03561-60352
U601	03561-60353
U602	03561-60354
U603	03561-60355
U701	03561-60356

**Page 4-20**, A40 Parts List. Delete the following components: U300, U301, U302, U304, U305, U306, U700, U702, U703, U704, U707, U708.

**Page 7-107**, Table 7-31 A40W2 Test Signatures. Change the ROM Address Decoding signatures to:

U605(7)	550H	U606(7)	HIGH
U605(9)	5732	U606(9)	HIGH
U605(10)	551H	U606(10)	HIGH
U605(11)	5772	U606(10)	HIGH
U605(12)	AC18	U606(12)	HIGH
U605(13)	AU66	U606(13)	HIGH
U605(14)	AC38	U606(14)	HIGH
U605(15)	AUP7	U606(15)	HIGH

**Page 7-108**, Table 7-31 A40W2 Test Signatures. Change the Power on Test ROMs (U160, U502) and Processor Data Bus signatures to:

+5V	755U		
U106(11)	C2C8	U502(11)	9P3F
U106(12)	7633	U502(12)	0U5P
U106(13)	FU74	U502(13)	964P
U106(15)	FCP3	U502(15)	U125
U106(16)	993C	U502(16)	11UU
U106(17)	1034	U502(17)	2286
U106(18)	H18F	U502(18)	5A7F
U106(19)	4PFC	U502(19)	UCCA

**Page 7-109**, Table 7-32 Power-on Test ROM Return Codes. Replace Table 7-32 with:

Return Code	Failed ROM	Return Code	Failed ROM
0 8 01	U502	0 8 16	U202
0 8 02	U106	0 8 17	U603
0 8 03	U502	0 8 18	U203
0 8 04	U106	0 8 19	U603
0 8 05	U600	0 8 20	U203
0 8 06	U200	0 8 21	U303
0 8 07	U600	0 8 22	U701
0 8 08	U200	0 8 23	U303
0 8 09	U601	0 8 24	U701
0 8 10	U201		
0 8 11	U601		
0 8 12	U201		
0 8 13	U602		
0 8 14	U202		
0 8 15	U602		

**CHANGE 4 for Serial Numbers 2549A03090 and greater.**

**Page 4-25**, A60 Parts List. Add A60C999 0160-6517 CAPACITOR-FXD 100pf, 20% 220V.

**Page 4-27**, A60 Parts List. Add A60X605 1200-0639 20 PIN SOCKET to the A60 miscellaneous parts.

**Page 7-177/7-178**, A60b Schematic, COPY/COMPLIMENT DATA FEEDBACK P. Add C999 at 100pF between U605(11) and ground.

**CHANGE 5 for Serial Numbers 2549A03145 and greater.**

**Page 7-179/7-150**, Schematic A50b, LOCAL OSCILLATOR/NOISE SOURCE MIXER W/LOCAL OSCILLATOR INTERFACE X. Add 2 OR gates from U10 between U201(2) and U704(1) as illustrated in figure 2.

**CHANGE 6 for Serial Numbers 2549A03547 and greater.**

**Page 4-5**, A10 Replacable Parts. Change the part number of A10CR001 to 1906-0325 and delete A10CR002.

**Page 7-19/7-20**, A10a Schematic, INPUT PROTECTION D. Change the reference designator CR2 to CR1.

**CHANGE 7 for Serial Numbers 2549A03585 and greater.**

**Page 4-10**, A10 Replacable Parts. Change the part number and description of A15R115 to 2100-3502 RESISTOR TRMR 200. Delete the part number for A15R123 and change the description to PART OF A15U102. Change the part number and description of A15U102 to 03562-62501 D/A 16-BIT AND MATCHING RESISTOR.

**Page 7-35/7-36**, A15a Schematic, Second Pass ADC H. Change the value of R115 to 200. Change the value of R123 to MATCHED TO U102.

**CHANGE 8 for Instruments with 03561-66599 Revision B Motherboard Assemblies.**

**Page 4-44**, A99 Parts List. Add A99R305 8159-0005 RESISTOR ZERO OHM. Change the part number of A99T100 to T-53677.

**CHANGE 9 for Instruments with A41 or A42 assembly.**

**Page 4-20**, Replaceable Parts List. Insert the replacement pages 4-20A through 4-20H.

**Page 7-95**, Section 7-16 A40 PROCESSOR/ROM ASSEMBLY. Add the following:

#### Note

In instruments with the A41 or A42 assembly, the A40 assembly circuits are modified to use CMOS memory as non-volatile mass storage in place of the bubble memory components. Instruments with the nonvolatile memory option have the 03561-66542 (A42) assembly installed, while those without the option have the 3561-66541 (A41) assembly installed. For simplicity, the A40 designator is used to identify the old A40, and the new A41 and A42 assemblies; use the designator appropriate for the instrument being serviced. Instruments with the A41 or A42 assemblies do not contain either the A65 or A66 assemblies; components for these assemblies are now contained on the A41 or A42 assembly and the A41/A42 references should be substituted for A65 or A66 as appropriate.

**Page 7-113/7-114, A40 Component Locator.** Replace page containing the A40 component locator with the attached replacement page 7-113/7-114.

**Page 7-115/7-116, A40a Schematic.** Replace the A40a schematic with the attached A40a replacement schematic.

**Page 7-117/7-118, A40b Schematic.** Replace the A40b schematic with the attached A40b replacement schematic.

**Page 7-119/7-120, A40c Schematic.** Replace the A40c schematic with the attached A40c replacement schematic.

**Page 7-121a/7-122a, Add the A40e Schematic.**

**Page 7-181, Section 7-25 A65/A66 BUBBLE MEMORY ASSEMBLY.** Add the following:

**Note**

In instruments with the A41 or A42 assembly, the A40 assembly circuits are modified to use CMOS memory as non-volatile mass storage in place of the bubble memory components. These instruments have the CMOS memory and support circuits on the A41 or A42 assembly. Substitute the A41 and A42 designators as required for references to the A65 and A66 assemblies. Schematics and troubleshooting information for the nonvolatile memory components can be found in the A40 PROCESSOR ROM service section.

P/O A50 LOCAL OSCILLATOR/NOISE SOURCE ASSEMBLY  
 03561-66550  
 \*REV 0

I/O CONTROL PORT (M)  
 TP TEST  
 U602  
 P0B2 3 00 00 2 TEST  
 P0B1 3 01 01 2 NC  
 P0B2 3 02 02 2 TRIG0  
 P0B3 3 03 03 2 TRIG1  
 P0B4 3 04 04 2 RANDOM  
 P0B5 3 05 05 2 NC  
 P0B6 3 06 06 2 PER/IMP  
 P0B7 3 07 07 2 NC  
 P0B8 3 08 08 2 CLK  
 P0B9 3 09 09 2 NC  
 P0B10 3 10 10 2 NC  
 P0B11 3 11 11 2 NC  
 P0B12 3 12 12 2 NC  
 P0B13 3 13 13 2 NC  
 P0B14 3 14 14 2 NC  
 P0B15 3 15 15 2 NC  
 P0B16 3 16 16 2 NC  
 P0B17 3 17 17 2 NC  
 P0B18 3 18 18 2 NC  
 P0B19 3 19 19 2 NC  
 P0B20 3 20 20 2 NC  
 P0B21 3 21 21 2 NC  
 P0B22 3 22 22 2 NC  
 P0B23 3 23 23 2 NC  
 P0B24 3 24 24 2 NC  
 P0B25 3 25 25 2 NC  
 P0B26 3 26 26 2 NC  
 P0B27 3 27 27 2 NC  
 P0B28 3 28 28 2 NC  
 P0B29 3 29 29 2 NC  
 P0B30 3 30 30 2 NC  
 P0B31 3 31 31 2 NC  
 P0B32 3 32 32 2 NC  
 P0B33 3 33 33 2 NC  
 P0B34 3 34 34 2 NC  
 P0B35 3 35 35 2 NC  
 P0B36 3 36 36 2 NC  
 P0B37 3 37 37 2 NC  
 P0B38 3 38 38 2 NC  
 P0B39 3 39 39 2 NC  
 P0B40 3 40 40 2 NC  
 P0B41 3 41 41 2 NC  
 P0B42 3 42 42 2 NC  
 P0B43 3 43 43 2 NC  
 P0B44 3 44 44 2 NC  
 P0B45 3 45 45 2 NC  
 P0B46 3 46 46 2 NC  
 P0B47 3 47 47 2 NC  
 P0B48 3 48 48 2 NC  
 P0B49 3 49 49 2 NC  
 P0B50 3 50 50 2 NC  
 P0B51 3 51 51 2 NC  
 P0B52 3 52 52 2 NC  
 P0B53 3 53 53 2 NC  
 P0B54 3 54 54 2 NC  
 P0B55 3 55 55 2 NC  
 P0B56 3 56 56 2 NC  
 P0B57 3 57 57 2 NC  
 P0B58 3 58 58 2 NC  
 P0B59 3 59 59 2 NC  
 P0B60 3 60 60 2 NC  
 P0B61 3 61 61 2 NC  
 P0B62 3 62 62 2 NC  
 P0B63 3 63 63 2 NC  
 P0B64 3 64 64 2 NC  
 P0B65 3 65 65 2 NC  
 P0B66 3 66 66 2 NC  
 P0B67 3 67 67 2 NC  
 P0B68 3 68 68 2 NC  
 P0B69 3 69 69 2 NC  
 P0B70 3 70 70 2 NC  
 P0B71 3 71 71 2 NC  
 P0B72 3 72 72 2 NC  
 P0B73 3 73 73 2 NC  
 P0B74 3 74 74 2 NC  
 P0B75 3 75 75 2 NC  
 P0B76 3 76 76 2 NC  
 P0B77 3 77 77 2 NC  
 P0B78 3 78 78 2 NC  
 P0B79 3 79 79 2 NC  
 P0B80 3 80 80 2 NC  
 P0B81 3 81 81 2 NC  
 P0B82 3 82 82 2 NC  
 P0B83 3 83 83 2 NC  
 P0B84 3 84 84 2 NC  
 P0B85 3 85 85 2 NC  
 P0B86 3 86 86 2 NC  
 P0B87 3 87 87 2 NC  
 P0B88 3 88 88 2 NC  
 P0B89 3 89 89 2 NC  
 P0B90 3 90 90 2 NC  
 P0B91 3 91 91 2 NC  
 P0B92 3 92 92 2 NC  
 P0B93 3 93 93 2 NC  
 P0B94 3 94 94 2 NC  
 P0B95 3 95 95 2 NC  
 P0B96 3 96 96 2 NC  
 P0B97 3 97 97 2 NC  
 P0B98 3 98 98 2 NC  
 P0B99 3 99 99 2 NC  
 P0B100 3 100 100 2 NC  
 P0B101 3 101 101 2 NC  
 P0B102 3 102 102 2 NC  
 P0B103 3 103 103 2 NC  
 P0B104 3 104 104 2 NC  
 P0B105 3 105 105 2 NC  
 P0B106 3 106 106 2 NC  
 P0B107 3 107 107 2 NC  
 P0B108 3 108 108 2 NC  
 P0B109 3 109 109 2 NC  
 P0B110 3 110 110 2 NC  
 P0B111 3 111 111 2 NC  
 P0B112 3 112 112 2 NC  
 P0B113 3 113 113 2 NC  
 P0B114 3 114 114 2 NC  
 P0B115 3 115 115 2 NC  
 P0B116 3 116 116 2 NC  
 P0B117 3 117 117 2 NC  
 P0B118 3 118 118 2 NC  
 P0B119 3 119 119 2 NC  
 P0B120 3 120 120 2 NC  
 P0B121 3 121 121 2 NC  
 P0B122 3 122 122 2 NC  
 P0B123 3 123 123 2 NC  
 P0B124 3 124 124 2 NC  
 P0B125 3 125 125 2 NC  
 P0B126 3 126 126 2 NC  
 P0B127 3 127 127 2 NC  
 P0B128 3 128 128 2 NC  
 P0B129 3 129 129 2 NC  
 P0B130 3 130 130 2 NC  
 P0B131 3 131 131 2 NC  
 P0B132 3 132 132 2 NC  
 P0B133 3 133 133 2 NC  
 P0B134 3 134 134 2 NC  
 P0B135 3 135 135 2 NC  
 P0B136 3 136 136 2 NC  
 P0B137 3 137 137 2 NC  
 P0B138 3 138 138 2 NC  
 P0B139 3 139 139 2 NC  
 P0B140 3 140 140 2 NC  
 P0B141 3 141 141 2 NC  
 P0B142 3 142 142 2 NC  
 P0B143 3 143 143 2 NC  
 P0B144 3 144 144 2 NC  
 P0B145 3 145 145 2 NC  
 P0B146 3 146 146 2 NC  
 P0B147 3 147 147 2 NC  
 P0B148 3 148 148 2 NC  
 P0B149 3 149 149 2 NC  
 P0B150 3 150 150 2 NC  
 P0B151 3 151 151 2 NC  
 P0B152 3 152 152 2 NC  
 P0B153 3 153 153 2 NC  
 P0B154 3 154 154 2 NC  
 P0B155 3 155 155 2 NC  
 P0B156 3 156 156 2 NC  
 P0B157 3 157 157 2 NC  
 P0B158 3 158 158 2 NC  
 P0B159 3 159 159 2 NC  
 P0B160 3 160 160 2 NC  
 P0B161 3 161 161 2 NC  
 P0B162 3 162 162 2 NC  
 P0B163 3 163 163 2 NC  
 P0B164 3 164 164 2 NC  
 P0B165 3 165 165 2 NC  
 P0B166 3 166 166 2 NC  
 P0B167 3 167 167 2 NC  
 P0B168 3 168 168 2 NC  
 P0B169 3 169 169 2 NC  
 P0B170 3 170 170 2 NC  
 P0B171 3 171 171 2 NC  
 P0B172 3 172 172 2 NC  
 P0B173 3 173 173 2 NC  
 P0B174 3 174 174 2 NC  
 P0B175 3 175 175 2 NC  
 P0B176 3 176 176 2 NC  
 P0B177 3 177 177 2 NC  
 P0B178 3 178 178 2 NC  
 P0B179

**Figure 1. Circuit addition to A508, CLOCK N.**










Figure 2. Circuit addition to A508,  
Local Oscillator/Noise Source Mixer W  
and Local Oscillator Interface X


PROCESSOR/ROM ASSEMBLY /NON-VOLATILE MEMORY OPTION  
03561-66541 REV A / 03561-66542 REV A







COPYRIGHT © 1987, BY THE HEWLETT-PACKARD COMPANY



**NOTE:**

THE COMPONENTS SHOWN IN THESE FUNCTIONAL BLOCKS ARE LOADED ONLY FOR THE NON-VOLATILE MEMORY OPTION.

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
BT100	03561-66541	2	1	PC AS CTLR/8KRAM	28480	03561-66541
C1	1420-0301	7	1	BATTERY 3.4V 1.8A-HR LITHIUM THIONYL	28480	1420-0301
C2	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C3	0160-3847	9	3	CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
	0180-0229	7	1	CAPACITOR-FXD 33UF+-10% 10VDC TA	13606	150D336X9010B2-DYS
C4	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C5	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C6	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C7	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C8	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C9	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C10	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C11	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C100	0190-0228	6	1	CAPACITOR-FXD 22UF+-10% 15VDC TA	13606	150D226X9015B2-DYS
C101	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C102	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C103	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C104	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C105	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C106	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C107	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C108	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C109	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C110	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
C200	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C201	0121-0432	0	1	CAPACITOR-V TRMR-AIR 2.1-13.3PF 350V	74970	189-0505-125
C202	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C203	0160-6840	8	2	C-F 390PF 5% 300V MICAS	K01002	HP15391J3ST
C204	0180-0374	3	1	CAPACITOR-FXD 10UF+-10% 20VDC TA	13606	150D106X9020B2-DYS
C205	0160-4790	3	1	CAPACITOR-FXD 12PF +-5% 100VDC CER 0+-30	04222	SA106A120JAA
C208	0180-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
C207	0180-0116	1	1	CAPACITOR-FXD 6.8UF+-10% 35VDC TA	13606	150D685X9035B2-DYS
C208	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C209	0160-4571	8	44	CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C212	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C213	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C216	0160-6840	6		C-F 390PF 5% 300V MICAS	K01002	HP15391J3ST
C217	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C308	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C400	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C401	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C402	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C403	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C404	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C405	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C406	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C407	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C408	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C409	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C500	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C501	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C502	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C503	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C504	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C600	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C700	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C701	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
CR1	1990-1122	9	1	OPT LED LMP G GP LMP1503 TT1H	28480	1990-1122
CR2	1990-1123	0	1	OPT LED LMP R AP LMP1301 TT1H	28480	1990-1123
CR3	1902-0943	5	1	DIODE-ZNR 2.4V 5% DO-35 PD=.4W TC=-.037%	04713	SZ30035-001
CR200	1901-0025	2	1	DIODE-GEN PRP 100V 200MA DO-7	07263	FDH536
CR300	1901-0539	3	1	DIODE-SCHOTTKY SM SIG	28480	1901-0539
CR301	1902-3059	0	1	DIODE-ZNR 3.83V 5% DO-35 PD=.4W	04713	SZ30016-1062
J100	1251-5202	8	1	CONN-POST TYPE .125-PIN-SPCG 5-CONT	22526	65580-105
L100	9140-0748	0	1	INDUCTOR 250UH 25% .25DX.5LG Q=3	24226	CA-253-5
L101	9100-3313	7	1	INDUCTOR RF-CH-MLD 22UH 5% .166DX.385LG	24226	15M222J
L201	9140-0253	2	1	INDUCTOR RF-CH-MLD 300NH 1% .166DX.385LG	24226	15M300F-1
R1	0757-0415	6	3	RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R2	0683-2215	1	1	RESISTOR 220 5% .25W CF TC=0-400	77902	R-25J
R3	0698-3279	0	6	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H

See introduction to this section for ordering information

\* Indicates factory selected values

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
R4	0683-1015	7	1	RESISTOR 100 5% .25W CF TC=0-400	77902	R-25J
R5	0683-9135	8	1	RESISTOR 91K 5% .25W CF TC=0-400	77902	R-25J
R6	0683-1035	1	3	RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R7	0683-1035	1		RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R8	0683-1535	6	1	RESISTOR 15K 5% .25W CF TC=0-400	77902	R-25J
R9	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R100	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R101	0683-1025	9	5	RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R102	0683-2715	6	2	RESISTOR 270 5% .25W CF TC=0-400	77902	R-25J
R103	0683-2715	6		RESISTOR 270 5% .25W CF TC=0-400	77902	R-25J
R104	0683-1025	9		RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R105	0683-1025	9		RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R200	0683-4705	9	4	RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R201	0683-5115	6	1	RESISTOR 510 5% .25W CF TC=0-400	77902	R-25J
R203	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R204	0683-4705	9		RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R205	0757-0415	6		RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R206	0683-4705	9		RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R207	0683-1035	1		RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R208	0757-0415	6		RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R209	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R210	0683-4705	9		RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R400	0683-1025	9		RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R401	0683-3305	2	1	RESISTOR 33 5% .25W CF TC=0-400	77902	R-25J
R402	0698-3279	0		RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R701	0698-3155	1	2	RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R702	0698-5852	9	1	RESISTOR 500 1% .125W F TC=0+-100	19701	SFR25H
R703	0698-3155	1		RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R704	0683-4725	2	1	RESISTOR 4.7K 5% .25W CF TC=0-400	77902	R-25J
R705	0757-0397	3	1	RESISTOR 68.1 1% .125W F TC=0+-100	19701	SFR25H
R706	0757-0417	8	1	RESISTOR 562 1% .125W F TC=0+-100	19701	SFR25H
R707	0683-1025	9		RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R708	8159-0005	0	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20940	106
U408	1820-1851	2	1	IC ENCOD TTL LS	01295	SN70488N
O100	1854-0019	3	1	TRANSISTOR NPN SI TO-18 PD=360MW	07263	S-651B
O200	1854-1028	6	3	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
O201	1854-1028	6		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
O300	1853-0281	9	1	TRANSISTOR PNP 2N2907A SI TO-18 PD=400MW	04713	ST1287
O301	1854-1028	6		TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
O302	1855-0269	7	1	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
O303	1855-0269	7		TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
RP1	1810-0280	8	6	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP100	1810-0280	8		NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP101	1810-0280	8		NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP102	1810-0280	8		NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP103	1810-0280	8		NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP104	1810-0280	8		NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP400	1810-0279	5	1	NETWORK-RES 10-SIP 4.7K OHM X 9	91637	CSC10A01-472G/MSP10A01-472G
TP1	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP2	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP3	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP4	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP100	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP101	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP200	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP201	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP202	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP300	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP400	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP401	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP402	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP403	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP404	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP405	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP406	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP502	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP503	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP600	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034

See introduction to this section for ordering information

\* Indicates factory selected values

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
TP700	1251-0600	0	26	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	27264	16-06-0034
TP701	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	27264	16-06-0034
TP702	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	27264	16-06-0034
TP703	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SQ	27264	16-06-0034
U1	1826-0138	8	1	IC COMPARATOR GP QUAD 14-DIP-P PKG	27014	SL24958
U2	1813-0130	3	1	XTAL CLKOSC 16MHZ MCAN	N02432	HS-102-16.000MHZ
U3	1820-2488	3	2	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN71171N
U4	1820-2096	9	1	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN59197N
U5	1820-0668	7	1	IC BFR TTL NON-INV HEX 1-INP	01295	SN24107N
U6	1820-3532	0	1	IC-16 BIT MICROPROCESSOR /8 MHZ	04713	MC68000PB
U7	1820-2772	8	1	IC FF TTL ALS J-K NEG-EDGE-TRIG	01295	SN71543N
U8	1820-1433	6	1	IC SHF-RGTR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN57194N
U9	1820-2634	1	2	IC INV TTL ALS HEX	01295	SN71332N
U10	1820-3239	4	6	IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U100	1820-3238	3	5	IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U101	1820-1997	7	1	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	27014	GDEA105
U102	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U103	1820-1492	7	1	IC BFR TTL LS INV HEX 1-INP	01295	SN57384N
U104	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U105	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U106	1818-4131	2	1	ICM MROMMB834100	S0167	
U200	1820-2657	8		IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U201	1820-2634	1		IC INV TTL ALS HEX	01295	SN71332N
U202	1820-2657	8		IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U400	1820-2488	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN71171N
U401	1820-2657	8	4	IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U402	1820-2774	0	1	IC GATE TTL ALS NAND DUAL 4-INP	01295	SN71545N
U403	1820-2656	7	1	IC GATE TTL ALS NAND OUAD 2-INP	01295	SN71338N
U404	1820-1217	4	2	IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN53523N
U405	1820-1217	4		IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN53523N
U406	1820-2739	7	1	IC GATE TTL ALS NOR OUAD 2-INP	01295	SN71336N
U407	1820-2657	8		IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U409	1820-2635	2	1	IC GATE TTL ALS AND OUAD 2-INP	01295	SN71172N
U500	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U501	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U502	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U503	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U504	1820-3100	8	1	IC DCDR TTL ALS BIN 3-TO-8-LINE 3-INP	01295	SN71418N
U505	1820-1991	1	2	IC CNTR TTL LS DECD DUAL 4-BIT	07263	SL66293
U800	1820-2757	9	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG OCTL	01295	SN71342N
U601	1818-3183	2	1	IC CMOS 65536 (64K) STAT RAM 150-NS 3-S	54013	HM6264LP-15
U604	1820-1991	1		IC CNTR TTL LS DECD DUAL 4-BIT	07263	SL66293
U705	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U706	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
W1	1251-4700	9	3	CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W2	1251-4700	9		CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W3	1251-4700	9		CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W4	1251-4700	9	1	CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
Y200	0410-1503	1	1	CRYSTAL-QUARTZ 20.48 MHZ HC-18/U-HLDR	33096	
	1400-0249	0	2	CABLE TIE .062-.625-DIA .091-WD NYL	56501	TY-23M-8

See introduction to this section for ordering information  
 \* Indicates factory selected values



Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
BT100	03561-66542	3	1	OPT 001 CTLR 8K RAM NON-VOLT	28480	03561-66542
C1	1420-0301	7	1	BATTERY 3.4V 1.8A-HR LITHIUM THIONYL	28480	1420-0301
C2	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C3	0160-3847	9	3	CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
	0180-0229	7	1	CAPACITOR-FXD 33UF+-10% 10VDC TA	13606	150D336X9010B2-DYS
C4	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C5	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C6	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C7	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C8	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C9	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C10	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C11	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C100	0180-0229	6	1	CAPACITOR-FXD 22UF+-10% 15VDC TA	13606	150D226X9015B2-DYS
C101	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C102	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C103	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C104	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C105	0180-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C106	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C107	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C108	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C109	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C110	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
C200	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C201	0121-0432	0	1	CAPACITOR-V TRMR-AIR 2.1-13.3PF 350V	74970	189-0505-125
C202	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C203	0160-6640	6	2	C-F 390PF 5% 300V MICAS	K01002	HP15391J3ST
C204	0180-0374	3	1	CAPACITOR-FXD 10UF+-10% 20VDC TA	13606	150D108X9020B2-DYS
C205	0160-4790	3	1	CAPACITOR-FXD 12PF +-5% 100VDC CER 0+-30	04222	SA106A120JAA
C206	0160-3847	9		CAPACITOR-FXD .01UF +100-0% 50VDC CER	04222	SA105C103KAA
C207	0180-0116	1	1	CAPACITOR-FXD 6.8UF+-10% 35VDC TA	13606	150D685X9035B2-DYS
C208	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C209	0160-4571	8	52	CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C210	0160-0158	9	1	CAPACITOR-FXD 5600PF +-10% 200VDC POLYE	A02430	HEW-238M
C211	0160-0165	8	1	CAPACITOR-FXD .056UF +-10% 200VDC POLYE	A02430	HEW-238M
C212	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C213	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C214	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C215	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C218	0160-6640	6		C-F 390PF 5% 300V MICAS	K01002	HP15391J3ST
C217	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C218	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C305	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C306	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C307	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C308	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C309	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C310	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C400	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C401	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C402	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C403	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C404	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C405	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C406	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C407	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C408	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C409	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C500	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C501	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C502	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C503	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C504	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C600	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C700	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
C701	0160-4571	8		CAPACITOR-FXD .1UF +80-20% 50VDC CER	04222	SA105E104ZAA
CR1	1990-1122	9	1	OPT LED LMP G GP LMP1503 TT1H	28480	1990-1122
CR2	1990-1123	0	1	OPT LED LMP R AP LMP1301 TT1H	28480	1990-1123
CR3	1902-0943	5	1	DIODE-ZNR 2.4V 5% DO-35 PD=.4W TC=-.037%	04713	SZ30035-001

See introduction to this section for ordering information  
 \* Indicates factory selected values

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
CR200	1901-0025	2	1	DIODE-GEN PRP 100V 200MA DO-7	07263	FDH536
CR300	1901-0539	3	1	DIODE-SCHOTTKY SM SIG	28480	1901-0539
CR301	1902-3059	0	1	DIODE-ZNR 3.83V 5% DO-35 PD=.4W	04713	SZ30016-1062
J100	1251-5202	8	1	CONN-POST TYPE .125-PIN-SPCG 5-CONT	22526	65580-105
L100	9140-0748	0	1	INDUCTOR 250UH 25% .25DX.5LG O=3	24226	CA-253-5
L101	9100-3313	7	1	INDUCTOR RF-CH-MLD 22UH 5% .166DX.385LG	24226	15M222J
L201	9140-0253	2	1	INDUCTOR RF-CH-MLD 300NH 1% .166DX.385LG	24226	15M300F-1
R1	0757-0415	6	3	RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R2	0683-2215	1	1	RESISTOR 220 5% .25W CF TC=0-400	77902	R-25J
R3	0696-3279	0	6	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R4	0683-1015	7	1	RESISTOR 100 5% .25W CF TC=0-400	77902	R-25J
R5	0683-9135	8	1	RESISTOR 91K 5% .25W CF TC=0-400	77902	R-25J
R6	0683-1035	1	3	RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R7	0683-1035	1	1	RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R8	0683-1535	6	1	RESISTOR 15K 5% .25W CF TC=0-400	77902	R-25J
R9	0696-3279	0	1	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R100	0696-3279	0	1	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R101	0683-1025	9	4	RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R102	0683-2715	6	2	RESISTOR 270 5% .25W CF TC=0-400	77902	R-25J
R103	0683-2715	6	1	RESISTOR 270 5% .25W CF TC=0-400	77902	R-25J
R104	0683-1025	9	1	RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R105	0683-1025	9	1	RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R200	0683-4705	8	4	RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R201	0683-5115	6	1	RESISTOR 510 5% .25W CF TC=0-400	77902	R-25J
R203	0696-3279	0	1	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R204	0683-4705	8	1	RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R205	0757-0415	6	1	RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R206	0683-4705	8	1	RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R207	0683-1035	1	1	RESISTOR 10K 5% .25W CF TC=0-400	77902	R-25J
R208	0757-0415	6	1	RESISTOR 475 1% .125W F TC=0+-100	19701	SFR25H
R209	0696-3279	0	1	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R210	0683-4705	8	1	RESISTOR 47 5% .25W CF TC=0-400	77902	R-25J
R400	0683-1025	9	1	RESISTOR 1K 5% .25W CF TC=0-400	77902	R-25J
R401	0683-3305	2	1	RESISTOR 33 5% .25W CF TC=0-400	77902	R-25J
R402	0696-3279	0	1	RESISTOR 4.99K 1% .125W F TC=0+-100	19701	SFR25H
R605	0683-3025	3	1	RESISTOR 3K 5% .25W CF TC=0-400	77902	R-25J
R606	0757-0124	4	1	RESISTOR 39.2K 1% .125W F TC=0+-100	19701	SFR25H
R701	0696-3155	1	4	RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R702	0696-5852	9	1	RESISTOR 500 1% .125W F TC=0+-100	19701	SFR25H
R703	0696-3155	1	1	RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R704	0683-4725	2	1	RESISTOR 4.7K 5% .25W CF TC=0-400	77902	R-25J
R705	0757-0397	3	1	RESISTOR 68.1 1% .125W F TC=0+-100	19701	SFR25H
R706	0757-0417	8	1	RESISTOR 562 1% .125W F TC=0+-100	19701	SFR25H
R709	8159-0005	0	1	RESISTOR-ZERO OHMS 22 AWG LEAD DIA	20940	106
R801	0696-3155	1	1	RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R803	0696-3155	1	1	RESISTOR 4.64K 1% .125W F TC=0+-100	19701	SFR25H
R804	0683-4725	2	4	RESISTOR 4.7K 5% .25W CF TC=0-400	77902	R-25J
R805	0683-4725	2	1	RESISTOR 4.7K 5% .25W CF TC=0-400	77902	R-25J
R806	0683-4725	2	1	RESISTOR 4.7K 5% .25W CF TC=0-400	77902	R-25J
U408	1820-1851	2	1	IC ENCDR TTL LS	01295	SN70488N
Q100	1854-0019	3	1	TRANSISTOR NPN SI TO-18 PD=360MW	07263	S-6516
Q200	1854-1028	6	3	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
Q201	1854-1028	8	1	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
Q300	1853-0281	9	1	TRANSISTOR PNP 2N2907A SI TO-18 PD=400MW	04713	ST1287
Q301	1854-1028	6	1	TRANSISTOR NPN SI PD=350MW FT=300MHZ	04713	SPS3611RLRA
Q302	1855-0269	7	1	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
Q303	1855-0269	7	1	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
Q402	1855-0269	7	1	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
Q403	1855-0269	7	1	TRANSISTOR MOSFET N-CHAN E-MODE TO-72 SI	T01027	SD214
RP1	1810-0280	8	6	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP100	1810-0280	8	1	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP101	1810-0280	8	1	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP102	1810-0280	8	1	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP103	1810-0280	8	1	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP104	1810-0280	8	1	NETWORK-RES 10-SIP 10.0K OHM X 9	91637	CSC10A01-103G/MSP10A01-103G
RP400	1810-0279	5	1	NETWORK-RES 10-SIP 4.7K OHM X 9	91637	CSC10A01-472G/MSP10A01-472G
TP1	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP2	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP4	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP100	1251-0600	0	1	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034

See introduction to this section for ordering information  
 \* Indicates factory selected values

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
TP101	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP102	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP200	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP201	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP202	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP300	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP400	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP401	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP402	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP403	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP404	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP405	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP408	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP500	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP502	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP503	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP600	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP700	1251-0600	0	26	CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP701	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP702	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
TP703	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
U1	1826-0138	8	1	IC COMPARATOR GP OUAD 14-DIP-P PKG	27014	SL24958
U2	1813-0130	3	1	XTAL CLKOSC 16MHZ MCAN	N02432	HS-102-16.000MHZ
U3	1820-2488	3	2	IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN71171N
U4	1820-2096	9		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN59197N
U4	1251-0600	0		CONNECTOR-SGL CONT PIN 1.14-MM-BSC-SZ SO	27264	16-06-0034
U5	1820-0668	7	1	IC BFR TTL NON-INV HEX 1-INP	01295	SN24107N
U6	1820-3532	0	1	IC-16 BIT MICROPROCESSOR /8 MHZ	04713	MC68000P8
U7	1820-2772	8	1	IC FF TTL ALS J-K NEG-EDGE-TRIG	01295	SN71543N
U8	1820-1433	6	1	IC SHF-RGTR TTL LS R-S SERIAL-IN PRL-OUT	01295	SN57194N
U9	1820-2634	1	2	IC INV TTL ALS HEX	01295	SN71332N
U10	1820-3239	4	6	IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U100	1820-3238	3	5	IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U101	1820-1997	7	1	IC FF TTL LS D-TYPE POS-EDGE-TRIG PRL-IN	27014	GDEA105
U102	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U103	1820-1492	7	1	IC BFR TTL LS INV HEX 1-INP	01295	SN57384N
U104	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U105	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U106	1818-4131	2	1	ICM MROMMB834100	S0167	
U200	1820-2657	8		IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U201	1820-2634	1		IC INV TTL ALS HEX	01295	SN71332N
U202	1820-2657	8		IC GATE TTL ALS OR OUAD 2-INP	01295	SN71173N
U306	03561-60306	5	1	3561A OPTION 001 FIRMWARE	28480	03561-60306
U306	1818-4079	7	1	ICM EPROM 2732B 4KX8 250NS C24	34335	AM2732B-DC
U400	1820-2488	3		IC FF TTL ALS D-TYPE POS-EDGE-TRIG	01295	SN71171N
U401	1820-2657	8	4	IC GATE TTL ALS OR QUAD 2-INP	01295	SN71173N
U402	1820-2774	0	1	IC GATE TTL ALS NAND DUAL 4-INP	01295	SN71545N
U403	1820-2856	7	1	IC GATE TTL ALS NAND QUAD 2-INP	01295	SN71338N
U404	1820-1217	4	2	IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN53523N
U405	1820-1217	4		IC MUXR/DATA-SEL TTL LS 8-TO-1-LINE	01295	SN53523N
U406	1820-2739	7	1	IC GATE TTL ALS NOR QUAD 2-INP	01295	SN71336N
U407	1820-2657	8		IC GATE TTL ALS OR QUAD 2-INP	01295	SN71173N
U409	1820-2635	2	1	IC GATE TTL ALS AND OUAD 2-INP	01295	SN71172N
U500	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U501	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U502	1820-3238	3		IC TRANSCEIVER TTL ALS BUS OCTL	01295	SN71492N
U503	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
U504	1820-3100	8	1	IC DCDR TTL ALS BIN 3-TO-8-LINE 3-INP	01295	SN71418N
U505	1820-1991	1		IC CNTR TTL LS DECD DUAL 4-BIT	07263	SL66293
U600	1820-2757	9	1	IC FF TTL ALS D-TYPE POS-EDGE-TRIG OCTL	01295	SN71342N
U601	1818-3183	2	1	IC CMOS 65536 (64K) STAT RAM 150-NS 3-S	54013	HM6264LP-15
U602	1820-1437	0	1	IC MV TTL LS MONOSTBL DUAL	01295	SN57198N
U603	T-48376	0	1	68-PIN PLCC PROGRAMMABLE LOGDV	50364	
U604	1820-1991	1	1	IC CNTR TTL LS DECD DUAL 4-BIT	07263	SL66293
U700	1820-2096	9	3	IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN59197N
U701	1820-2096	9		IC CNTR TTL LS BIN DUAL 4-BIT	01295	SN59197N
U702	1818-4160	7	1	ICM SRAM 66204L 128KX8 120 M32	54013	HM68204L-12SL
U703	1820-1195	7	2	IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN53526N
U704	1820-1195	7		IC FF TTL LS D-TYPE POS-EDGE-TRIG COM	01295	SN53526N
U705	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N

See introduction to this section for ordering information

\* Indicates factory selected values

Table 4-3. Replaceable Parts

Reference Designation	HP Part Number	C D	Qty.	Description	Mfr. Code	Mfr. Part Number
U706	1820-3239	4		IC DRVR TTL ALS BUS OCTL	01295	SN71491N
W1	1251-4700	9	3	CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W2	1251-4700	9		CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W3	1251-4700	9		CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
W4	1251-4700	9	1	CONN-POST TYPE .100-PIN-SPCG 3-CONT	22526	65521-103
X603	1200-1080	5	1	SOCKET-RECP 68-CONT SQUARE DIP-SLDR	09922	QILE68P-410T
Y200	0410-1503	1	1	CRYSTAL-QUARTZ 20.46 MHZ HC-18/U-HLDR	33096	
	1400-0249	0	2	CABLE TIE .062-.625-DIA .091-WD NYL	56501	TY-23M-8

See introduction to this section for ordering information  
 \* Indicates factory selected values



03561-90010



Printed in U.S.A.